

ANNEXURE - B
1X800 MW KOTHAGUDEM FGD
BOQ-CUM-PRICE SCHEDULE FOR HT XLPE POWER CABLES (MAIN SUPPLY)

Sr. No.	Item code	Item description	Unit	Total Quantity (metres)	Lot-I Quantity	Lot-II Quantity	Drum Length (Meters)	UNIT PRICE (EX-WORKS) Rs	Total Price (Ex-works) Rs	Freight % of Quoted Ex-works	Freight Charges Rs.	Type of GST	GST rate in %	GST Charges (Rs.)	Total Price (Rs.)
1.0		11/11 KV AL. CONDUCTOR/ INSULATED/ ARMoured/ UNEARTHED GRADE POWER CABLE													
1.1	507-27151-A	3C-240	MTR	500	500		500								
1.2	507-27009-A	1C-240	MTR	2,000	2,000		500								
1.3	507-27025-A	1C-630	MTR	6,000	1,500	4,500	500								
2.0		3.3/3.3 KV AL. CONDUCTOR/ INSULATED/ ARMoured/ UNEARTHED GRADE POWER CABLE.													
2.1	507-27150-A	3C-185	MTR	2,000	2,000		500								
2.2	507-27053-A	1C-240	MTR	3,000	3,000		500								

NOTES:

- Total Quantity indicated above shall be known as Order Quantities. The total quantity variation shall be as per NIT.
- Lot-I quantity indicated above shall be cleared for manufacturing along with LOI/PO. However, manufacturing of the cables shall be taken up by the successful bidder only after approval of technical and quality documentation.
- Standard drum length shall be as per BOQ cum price schedule against each size of cable. Tolerance on individual drum length shall be $\pm 5\%$. For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply. The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
- Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0% except where the total ordered quantity is one single drum length, in which case it shall be -5% to 0%. Cables consumed for testing and inspection shall be to bidder's account.
- In case of the quantities cleared by BHEL for manufacturing are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches without any price implications.
- Bidder shall indicate unit price of cables inclusive of type test charges, No separate charges shall be payable for type tests.