



BHARAT HEAVY ELECTRICAL LIMITED, BHOPAL


SPECIFICATION CUM COMPLIANCE CERTIFICATE OF 420 kV OIL-SF6 CONDENSER BUSHING

NAME & ADDRESS OF THE SUPPLIER :			
SCOPE: SUPPLY OF 420 kV, 1250A OIL-SF6 CONDENSER BUSHINGS COMPLYING WITH THE SPECIFICATIONS AS BELOW :			
			Spec No. : BCE/PS/420/50, Rev00
			Date : 13-01-2023
S.NO.	DESCRIPTION OF BHEL REQUIREMENT	SPECIFIED / TO BE CONFIRMED BY	REMARKS
1.0	WORKPIECE MATERIAL		
1.1	Item :		
	420KV Oil-SF6 RIP (Resin Impregnated Paper) condenser type bushing.	Vendor to confirm	
2.0	SPECIFICATION :		
2.1	The electrical and mechanical characteristics of bushings shall be in accordance with latest revisions of IEC: 60137:2017 & IEC 62271-211.	Vendor to confirm	
2.1	The bushing shall be suitable for connection with GIS SF6/ Oil Interface as per IEC 62271-211.	Vendor to confirm	
2.2	Valid type test reports as per IEC:60137 (2017) for similar 420 kV Oil-SF6 RIP bushings, conducted within last 7(seven) years prior to the date of bid opening shall be submitted alongwith the bid.	Vendor to confirm and submit the test reports alongwith the bid	
2.2.1	The type tests conducted should have either been conducted in accredited laboratory (accredited based on ISO/ IEC Guide 25/ 17025 or EN 45001 by the national accreditation body of the country where laboratory is located) or witnessed by client / third party.	Vendor to confirm	
2.2.2	Type Tests reports should include the following tests also, (i) Seismic Test (ii) Snap Back Test	Vendor to confirm	

Spec No. : BCE/PS/420/50, Rev00

Date : 13-01-2023

S.NO.	DESCRIPTION OF BHEL REQUIREMENT	SPECIFIED / TO BE CONFIRMED BY	REMARKS
2.2.3	In case valid type test report as mentioned under Sr. Nos. 2.2.2.2.1 & 2.2.2.2.2 above is not available, then vendor has to conduct type test in presence of BHEL / Customer representative before delivery of first lot, at no extra cost.	Vendor to confirm	
2.3	When operating at normal rated voltage there shall be no electric discharge between the conductors and bushing which would cause corrosion or injury to conductors, insulators or supports by the formation of substances produced by chemical action.	Vendor to confirm	
2.4	No radio interference shall be caused by the bushings when operating at the normal rated voltage. All surfaces of the metal parts shall be perfectly smooth with the projecting points or irregularities which may cause corona.	Vendor to confirm	
2.5	End fittings shall be free from cracks, seams, shrinks, air holes and rough edges.	Vendor to confirm	
2.6	End fittings should be effectively sealed to prevent moisture ingress; effectiveness of sealing system must be supported by test documents.	Vendor to confirm	
2.7	All load bearing surfaces shall be smooth and uniform so as to distribute the loading stresses uniformly.	Vendor to confirm	
2.8	Clamps and fittings shall be of hot dip galvanised/stainless steel.	Vendor to confirm	
2.9	Spare Bushing shall be specially packed suitable for long storage with non-returnable.	Vendor to confirm	
2.10	Bushings of identical current and voltage ratings must be interchangeable.	Vendor to confirm	
2.11	Supplier to submit their Quality Plan for review by BHEL.	Vendor to confirm	
2.12	Bottom stress shield insulated with 5mm pressboard is preferable. It shall be duly packed in moisture proof condition and supplied along with bushing.	Vendor to confirm	




Spec No. : BCE/PS/420/50, Rev00

Date : 13-01-2023

S.NO.	DESCRIPTION OF BHEL REQUIREMENT	SPECIFIED / TO BE CONFIRMED BY	REMARKS
2.13	Bushing shall be specially packed to avoid any damage during transit and suitable for long storage, with non-returnable packing wooden boxes with hinged type cover. Without any gap between wooden planks. Packing Box opening cover with nails/screws type packing arrangement shall not be acceptable.	Vendor to Confirm	
2.14	Both bushing oil end & SF6 end shall be fitted with metal housing with positive dry air pressure and a suitable pressure monitoring device shall be fitted on the metal housing during storage to avoid direct contact with moisture with epoxy. Alternatively, oil filled metal housing / tank with suitable arrangement for taking care oil expansion due to temperature variations shall also be acceptable. Tank shall have necessary provision for oil filling, level gauge etc. Manufacturer shall submit drawing/ documents of packing for approval during detail engineering.	Vendor to Confirm	
2.15	Detail method for storage of bushing including accessories shall be brought out in the instruction manual.	Vendor to Confirm	
2.16	Tan delta measurement at variable frequency (in the range of 20 Hz to 350 Hz) shall be carried out on each condenser type bushing (RIP) at manufacturing works as routine test before despatch and the result shall be compared at site during commissioning to verify the healthiness of the bushing.	Vendor to Confirm	
2.17	Tan delta value of RIP condenser bushing at site shall be 0.005 (max) in temperature range of 20 deg C to 90 deg C. The measured tan delta value at site of in-service bushing should not exceed by 0.001 w.r.t factory results (measured at approx. similar temperature conditions) during warranty period.	Vendor to Confirm	



Spec No. : BCE/PS/420/50, Rev00				
Date : 13-01-2023				
S.NO.	DESCRIPTION OF BHEL REQUIREMENT		SPECIFIED / TO BE CONFIRMED BY	REMARKS
2.18	If the bushing does not fulfill the criteria under Cl. No. 2.17 mentioned above, the supplier shall arrange to replace the defective bushing by a new one, within the warrantee period.		Vendor to Confirm	
3.0	Technical Parameters			
3.1	Rated Voltage	420 kV	Vendor to Confirm	
3.2	Rated Current (Min.)	1250 A	Vendor to Confirm	
3.3	Lightning impulse withstand voltage	1425 kVp	Vendor to Confirm	
3.4	Switching impulse withstand voltage	1050 kVp	Vendor to Confirm	
3.5	One minute power frequency withstand voltage	695 kVrms	Vendor to Confirm	
3.6	Tan delta of bushings	≤ 0.005	Vendor to Confirm	
3.7	Max partial discharge level at Um	< 10 pC	Vendor to Confirm	
3.8	Test tap voltage withstand level	2 kVrms	Vendor to Confirm	
3.9	SF6 end Terminal details	As per drg. at Annexure-I	Vendor to Confirm	
3.10	Height of mounting flange (between SF6 side and oil side PCD areas)	200 mm	Vendor to Confirm	
3.11	Oil End Terminal details	Flat rectangular shaped with 2 nos. 14mm dia holes at 40mm pitch.	Vendor to Confirm	
3.12	Oil end side max. bushing dia. (mm)	298 mm	Vendor to Confirm	
3.13	Flange Fixing details - SF6 side	16 holes, dia. 20 mm equally spaced on PCD-640 mm	Vendor to Confirm	
3.14	Flange Fixing details - Transformer side	12 holes, dia. 23 mm equally spaced on PCD-450 mm	Vendor to Confirm	
3.15	CT space min.	300 mm	Vendor to Confirm	




Spec No. : BCE/PS/420/50, Rev00 Date : 13-01-2023			
S.NO.	DESCRIPTION OF BHEL REQUIREMENT		SPECIFIED / TO BE CONFIRMED BY
3.16	Type of Lead	Bottom connected	Vendor to Confirm
4.0	DOCUMENTATION : Following documents in English language should be submitted along with the bid for our evaluation.		Vendor to Confirm
4.1	OGA Drawing		Vendor to submit
4.2	Type test reports		Vendor to submit
4.3	Instruction manual		Vendor to submit
4.4	Quality Plan		Vendor to submit
5.0	GUARANTEE :		
5.1	12 months from the date of commissioning of the transformer and 18 months from the date of supply, whichever is later.		Vendor to Confirm
6.0	ROUTINE TEST INSPECTION:		Vendor to confirm
6.1	Routine tests to be conducted on all bushings as per IEC 60137:2017. The routine tests may be witnessed by BHEL/customer/TPIA at supplier's works.		Vendor to confirm

Prepared By:
Singiren.E.Kandulna
Mgr (CIE)

Checked By:
Kulamani Naik
SDGM (BCE & CIE)

Approved By:
Mahendra Kurre
AGM (BCE & CIE)

ANNEXURE-ISF6 SIDE BUSHING TERMINAL DETAILS*Singh*