

	2x600 MW Ennore STPP AIR CONDITIONING SYSTEM Pre Bid clarification Schedule		Specification No : PE-TS-412-553-A001	
			Section : III	
			Sub section : 3	
			Rev. no. 00	Date : March 22, 2017
		Sheet : 1 of 1		
S.No.	Section/Clause/Page no.	Statement of the referred clause	Clarification required	
1	Page 23 of 697, Clause no 2.1 Technical specification of Air conditioning system SPECIFICATION NO.: - PE-TS-412-553-A001 (REV1)	Bidder shall follow technical specification for AC area and same are also shown in tender drawing. Internal layout shall be provided during detail engineering. heat dissipation data shall be provided during detail engineering	Kindly indicate areas to be air conditioned in Main Power house building covered under AC Plant - I for calculation of AHU capacities for (+) 8.5 & (+) 17.0 m level. Office areas are not visible in presently marked areas.	
2	Page 23 of 697, Clause no 2.1 Technical specification of Air conditioning system SPECIFICATION NO.: - PE-TS-412-553-A001 (REV1)		Kindly also provide Equipment heat dissipation to be considered for heat load calculation of Main Power House building .	