

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
PROJECT ENGINEERING MANAGEMENT

Enq. No.: PE/PG/UPP/E-5782/2017

Package- D/G EOT CRANES UPTO 100T

Project- 2X800MW TANGEDCO UPPUR-BTG

Reply of Pre-Bid Queries are as follows:

1. As per data sheet clause no – 31 – **Type of access to Cabin from crane bridges walkway - By Staircase.** But in data sheet mode of operation is pendent push button and also cabin is not available in CCD.

BHEL Reply: Cabin is not applicable for these cranes. The statement as mentioned at clause no. 31 of data sheet, Sub section IC page no. 257 of 307 of technical specification “Type of access to Cabin from crane bridges walkway” stands deleted

2. In Note points no. – 6, Provision of operation of Hydraulic rail clamp operable from operator’s cabin shall also be provided.

BHEL Reply: Hydraulic rail clamps are not applicable for these cranes. The statement as mentioned at Note of data sheet, Sub section IC page no. 258 of 307 of technical specification “Provision of operation of Hydraulic rail clamp operable from operator’s cabin shall also be provided.” stands deleted.

For and on behalf of BHEL

UPENDRA CHAUDHARY
(DY.MGR/BOP Ordering/BHEL-PEM)