

**EOT Cranes package 5 x 800 MW Yadadri STPP  
PREBID CLARIFICATIONS -3 dated 13.07.2022**

**List of Technical Clarification**

S.#	Enquiry Specification			As per Technical Specifications	Bidders' Comments/Clarifications	BHEL's Response
	Tender Volume / Section	Clause No.	Page No.			
1	IS-1-15-2001/048	2	4 of 9	All facilities , accessories and attachments for single and tandem operation of the cranes.	As per Technical enquir spec " all facilities , accessories and attachments for single and tandem operation of the cranes." - As only one crane in each building and hence tandem operation requirement with Master and Slave crane is not applicable. Kindly confirm-	Bidder's understanding is correct
2	Annexure-3 Scope interface sketch for EOT Cranes				Runway Beam / Gantry Girder input required for the crane related will be provided by the vendor/us. No detailed drawing or selection will be done by Vendor.Kindly confirm-	Bidder's understanding is correct
3	Annexure_1_ TSGENCO Spec on EOT Cranes	5.12.00		Runway rail as per IS 3443	As per spec 2_Annexure_1_ TSGENCO Spec on EOT Cranes clause no. 5.12.00 - Runway rail as per IS 3443 - Please note that the required cranes are Single girder and also for small capacities hence we recommend SQ Bar or Rect bar for cranes.Kindly reply -	Bidder to follow specification and provide rail as per IS-3443