

Pre-bid Clarification

“Each boiler is fired with two separate gas lines, one for COG and other for BFG/LDG. Hence BFG + LDG mixed gas will not be applicable. COG will have exclusive COG while LDG will be dumped in BFG lines whenever recovered.”

Based on the above, CV analyser shall be designed in-line with compositions given in page 2 to 4 of Annexure-(2) of PY56343.