

PRE-BID CLARIFICATION SCHEDULE

S.NO.	SECTION/CLAUSE/PAGE NO	STATEMENT OF THE REFERRED CLAUSE	CLARIFICATION REQUIRED
1	Sl.No.4.b of Price Schedule, Annexure-I	Motorized Actuator with single phase indicating lamps, etc.	Kindly specify Number of the Actuators instead of Sq.mt.if it is true
2	Sl.No.4.b of Price Schedule, Annexure-I	Field Instruments like Pressure Gauge....	Referred clause indicates Flow Transmitter which is neither indicated In P&ID nor in the specification. Kindly confirm the inclusion of same item in the Air washer & UAF.
3	Clause No.4.2.I, Sub-section-C1A, Page No. 15 of 394	Electrical feeder suitable for following Motor Motor Rating 22.5	Referred clause mentioned Motor rating 22.5 KW. Kindly confirm
4	Clause No.7.1.3, Sub-section-C1A, Page No. 25 of 394	Local Control Panel for Air Washer & UAF unit system.....for unit-1,2,3 & 4	Referred clause indicates various instruments of Air Washer as well as UAF unit which are different from your P & I Diagram of same equipments. Kindly confirm which one are to be considered.
5	Sl.No.9 of Specific Technical Requirement , Section-C, Page-161ofm 394	PLC Control System as defined Along with required furniture.	Refer points indicates PLC based Local Panel/Local Control Panel. Kindly confirm that Local Panel/Local Control Panel of Air Washer as well as UAF shall be PLC based or Relay based.

Please read quantity as nos*. instead of Sq.M*.

Spec is clear.
follow the spec.

Spec is clear.
follow the spec.

Follow the P&ID.

Spec is clear.
follow the spec.

Query- At clause no. 4.2 (h) of section: 1, sub- section: C1 A, you have mentioned the casing thickness 3.15 mm whereas at clause no. 6.5 (c) same is mentioned as 2 mm thick. Please clarify the same.

Reply- please note that casing thickness of UAF chamber shall be **3.15 mm** as per clause no. 4.2 (h). Further, please also read casing thickness as **3.15mm** instead of 2 mm for clause no. 6.5 (c).