

Pre bid Queries & BHEL Clarifications dated 29.06.2023

Name of the work : “Supply, E&C of BOS for restoration of PCSS#4 at 40 MW site” of 1x65MW of Solar PV plant of NLCIL at Neyveli, Cuddalore District, Tamilnadu.

Tender Ref. No.:TOAWX00049_NIT-77121 and tender id 2023_BHEL_28905_1 , dated 23.09.2023.

Query raised by the bidder: M/s. EDAC Engineering Ltd,

Sl.No.	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's clarification
1	Vol-1A_TCC	Part-II - Chapter-II Scope	We considered the PEB part as PCSS-4 (inverter room-1nos) Single building, Please confirm the same.	Yes
2	unprice-bid-format_SOQR	Section B: PEB Supply and installation	We have received the GA drawing for the PCSS building which was the PEB part in this tender. Please provide the overall tonnage of the PEB structure to be supplied & installed along with the steel grade.	Weight of Steel Structure is approx. 3.5T . However, the overall tonnage (incl. PUF panels, arch and electrical items) may be worked out as per GA drawing. Regarding steel grade, please refer Cl.9.2.1 of Tech specification (Doc. No. PY60053).

Sd/-
Imran Javed
Dy.Manager/Sub-contracting
PESD , BHEL RC Puram Hyderabad 502032