


PI NO. 140610328 (WO 72513A & 72532A)					
S. no.	Item Description	For Item No. 1 & 2			
		Qty.	Unit	Unit Rate	Value (in Rs.)
1	Supply of NIFPES System for Cable Box along with FEC, CB & conservator isolation valve	1	no.		
2	Heat Sensor or Fire detector or LHD (3 nos. 2-way and 1 nos. 3-way box- 25 meter)	8	no.		
3	Supply of Fire survival cable	50	mtr.		
4	Supply of FRLS Armoured cable along with accessories for connection between Trs. - CB - FEC	300	mtr.		
5	Supply of FRLS Armoured cable along with accessories for connection between Relay panels to control box, DC source etc.	100	mtr.		
6	Supply of 6 mtrs. ERW Class 'C' pipes with support and fittings etc. for connections between Trs. and FEC	1	no.		
7	Supply of 10 mtrs pipes with fittings for connection between FEC and Oil pit	1	no.		
<b>Sub total (Total Supply portion Value)</b>					
1	Installation & commissioning at any Customer site in India	1	no.		
<b>Sub total (Total Service Portion Value)</b>					
<b>Total (Supply+I&amp;C+ Civil work)</b>					

## Note:-

- Length indicated against item 4, 5 & 6 are only for evaluation purpose. For additional length of item 4, 5 & 6 if required at site to be provided on producing certificate from customer on pro-rata basis.
- Supplier To comply RDSO specification for NIFPS with no technical deviation. Supplier may add items and accessories to meet specification criteria

  
 (KAUSHALENDRA SINGH)  
 प्रबंधक (अभियंता) काठमांडू  
 Manager (Design) Tric. Engg.  
 १०९ बस स्टेशन, झांसी  
 H.H.E.L. JHANSI

Vendor to quote for total (supply + I&C).  
 - supply portion value shall be 80% of total value.  
 - I&C portion value shall be 20% of total value.

1  
