

Qualifying Requirements

S No	ITEM	QUALIFYING REQUIREMENTS
1	Ukai cable	Complete Type testing reports as per relevant IEC for both types of cables
	400kV	Manufacturing works to be same as mentioned in the approved TT reports
	220kV	Proof of 2 Years of continuous operation of both types of cables manufactured in this works.
		Should have supplied both types of cables to atleast 3 projects