

Qualifying Requirements

S No	ITEM	QUALIFYING REQUIREMENTS
1	Libya Cable	Complete Type testing reports as per latest relevant IEC standards.
	400kV	Manufacturing works to be same as mentioned in the approved TT reports
		Proof of 2 Years of continuous operation of cable manufactured in this works.
		Should have supplied the cable to atleast 3 projects