

2X800 MW TELANGANA SUPER THERMAL POWER PROJECT PHASE - I AT KARIMNAGAR- TELANGANA

LIST OF ADDITIONAL CLARIFICATIONS REQUIRED

Ref.: Clarifications to Queries Issued vide Corrigendum No. 12

Sl. No.	CLARIFICATION NO.	SPECIFICATION CLAUSE No.	BHEL's REPLY	FURTHER CLARIFICATION REQUIRED Dated:01-04-2017	BHEL RESOLUTION Dated:03-04-2017
1.	Technical Queries				
1.1	Corrigendum No. 12	Annexure – 35 Free Issue items (Electrical) From BHEL (Rev.1)	Sl. No. 6 Motors for Pumps – 1 lot	a) According to Annexure – 35 Rev.02 dated 30.03.2017, various pumps/compress indicated under “Free Supply items” are supplied with motor. b) According to Sl. No 6 of Annexure – 35, Rev.1 “Free issue items (Electrical)” motor for pumps are free issue. Please clarify whether the free issue motors are limited to the free issue mechanical equipments indicated in Sl. No. (a) above only (or) Will be supplied for all pumps used in the ash handling system including the pumps supplied by bidder also.	Pl. note the free issue motors are limited to the free issue mechanical equipments indicated in Annexure – 35.
1.2		General – Erection and Commissioning		Please confirm for Erection & Commissioning of various free issue items, M/s BHEL will arrange commissioning personal from equipment supplier to assist the bidder during commissioning.	Noted
1.3		Startup & Commissioning spares		Please confirm that supply of start up & Commissioning spares for Free issue items is in BHEL's scope.	Noted
2.0	-	Annexure – 36 Sub Supplier Questionnaire	Format revised	(See Note Below)	To be replaced with Annexure 36 - SUB VENDOR QUESTIONNAIRE_R1 NTPC format attached.

NOTE for BIDDERS: Bidders has to submit credentials/details in the attached NTPC SUB-VENDOR QUESTIONNAIRE Format (Annexure-36 Rev-1) to comply with PQR criteria properly indexed along with offer required for seeking approval of customer. In case NTPC does not approve credentials of the bidder, the bidder will be technically rejected