

CORRIGENDUM-1 TO TENDER SPECIFICATION BHEL: PSSR: SCT: 1855

Sub: Civil & Architectural Works of Main Plant Area of Unit 2 (excluding pile and pile caps), at 2 x 800 MW Uppur Power Project, Ramanathapuram Dist., Tamil Nadu

Some of the bidders sought clarifications in regard to TENDER SPECIFICATION BHEL PSSR SCT 1855 and BHEL's clarifications are furnished below.

S.NO	CLAUSE REFERENCE	BIDDER'S QUERY	BHEL REPLY/ CLARIFICATION
1	Volume II, Price Bid, Part C, Item No. 108 a	Item No.108.0 (a) & (b) is same.	Description for Item no. 108 a is revised as "Each layer compacted so as to achieve at least 90% maximum dry density as per IS-2720 (Part-VII)"
2	Volume II, Price Bid, Part C, Item No. A2611	A2611 filling by Moorum/ Gravel - But Gravel is may not available, so, we shall consider only Moorum for this item. Moreover, as per weightage factor as mentioned in the BOQ rate for the item is coming as same item no. A2612 which is for filling by borrowed earth.	Tender condition prevails.
3	Volume IA Part I Chapter II, Clause 1.2.9	Release of construction drawing.	Drawings will be released progressively after finalisation of contract.
4	Volume IA Part I Chapter III, Clause 1.3.3	Confirmation about hindrance free disposal yard from starting date of works.	Bidder to refer clause no. 1.3.3 of Technical Conditions of Contract
5	Volume IA Part I Chapter III, Clause 1.3.4	Scope of construction power. If it is chargeable, then clarification about the following: i) Electricity tariff is fixed or variable. Penal recovery against 'power factor' provision. ii) Any other hidden recovery.	Refer clause no. 1.3.4 of Technical Conditions of Contract- Electricity is chargeable as per the prevailing rates of TANGEDCO under LT tariff at the nearest substation. Rate provided in Clause 1.3.4.2 is only for reference. Power factor is necessarily be adhered to. In case of failure, if penalty levied by customer, the same will be recovered from the contractor. If any penalty levied by state electricity authority or customer or BHEL owing to lapses observed in safety/ statutory requirement, the same will be recovered from the contractor.

CORRIGENDUM-1 TO TENDER SPECIFICATION BHEL: PSSR: SCT: 1855

S.NO	CLAUSE REFERENCE	BIDDER'S QUERY	BHEL REPLY/ CLARIFICATION
6	Volume IA Part I Chapter III, Clause 1.3.5	Scope of construction water. If it is in contractor scope, then confirmation about approved source, no. of sources and distance from site. Deep boring is allowable or not at site.	The contractor shall make his own arrangement for water for construction and drinking purpose. All statutory norms of the government body or TANGEDCO is to be complied with. Any penalty levied by any government authority or customer on this account will be recovered from contractor.
7	Volume IA Part I Chapter III, Clause 1.3.6	Approved source of stone quarry and distance from site.	Finalising location of the source and obtaining approval of the same from the BHEL as well as BHEL's customer is in the scope of contractor.
8	Volume IA Part I Chapter III, Clause 1.3.6	Specific scope of supply of materials for client and contractor.	Refer clause no. 1.3.6.2 of Technical Conditions of Contract. BHEL will provide Cement & reinforcement steel for civil works only for incorporation in permanent work as free supply.
9	Volume IA Part I Chapter IV, Clause 1.4.6	Scope of providing of temporary road and drain for construction, and for movement inside plant.	Temporary approach for contractor's machineries is in the scope of contractor at their own cost. Construction of permanent road is included in the scope of work of this tender and work for permanent road may be taken up as soon as possible after discussion with BHEL/site in-charge by the successful contractor to expedite the progress of the project.
10	Volume IA Part I Chapter IV	Clarification required for mobilisation of T&P is related with penalty or not? If total work front and drawing not release at the starting of works, then also total T&P mobilisation is required from our end for make it idle.	Refer note (1) of Clause no. 1.4.2 for clarification regarding mobilisation of tools & plants.
11	Volume IA Part I Chapter X	Clarification about BOCW recovery.	Bidder to refer clause no. 1.10.3 of Technical Conditions of Contract
12	--	Architectural materials specification, detail job description, dimensions of materials and specific approved vendor list for works and materials.	After award of work to successful bidder, successful bidder shall submit list of suppliers to BHEL for approval.

CORRIGENDUM-1 TO TENDER SPECIFICATION BHEL: PSSR: SCT: 1855

S.NO	CLAUSE REFERENCE	BIDDER'S QUERY	BHEL REPLY/ CLARIFICATION
13	--	Specific requirement of staging and shuttering materials and methodology.	Submission of methodology for works under scope of this tender is in the scope of contractor and approval for the same is to be obtained from BHEL/ TANGEDCO before start of work. All necessary materials required for successful execution of the work is in the scope of contractor. Note 1 of clause no. 1.4.2 shall be referred for clarification for mobilisation of the same.
14	--	If the works is sequentially and related with other agency.	Refer clause no. 1.3.3 and 1.10.8.11 of Technical Conditions of Contract
15	--	Release of payment should be as per contract. Provision for paying Interest for delay in bill payment.	Tender condition prevails. Bidder to refer Clause 2.21.3 of Sl No: 12 of Volume IA Part II, Chapter 1.
16	--	Binding wire for reinforcement works.	Binding wire shall be of 20G annealed soft iron PVC coated wire Refer Volume IA Part II Chapter 2, Clause 10.22.00.d
17	--	Uses of crushed stones sand in concrete, plastering etc., instead of river sand, as the river sand are banned by Govt.	Refer clause no. 1.3.6.3 and 1.3.6.4 of Technical Conditions of Contract
18	--	Borrowed earth also banned by Govt. another suitable option for filling materials.	Refer Volume IA Part II Chapter 2, Clause 15.06.00 of Technical Conditions of Contract

NOTE:

1. ALL OTHER CONDITIONS REMAIN UNCHANGED.
2. BIDDERS ARE REQUESTED TO CONSIDER THIS CORRIGENDUM AS PART OF TENDER SPECIFICATION AND QUOTE ACCORDINGLY.

-sd-
Asha Alex
DGM / SCT