

Corrigendum 1 dated August 07, 2020 to Tender Specification BHEL: PSSR: SCT: 1905 for Erection Works of Static and Rotary Equipments in Turbine Building of Unit 3 of Kudankulam Nuclear Power Project, Radhapuram Taluk, Thirunelveli District, Tamil Nadu

A. Some of the Bidders had asked queries in the published Tender Specification. The clarifications issued by BHEL are furnished below:

SI No.	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's clarification
1	TECHNICAL CONDITIONS OF CONTRACT (TCC) VOLUME-IA PART-I CHAPTER – II SCOPE OF WORKS Clause 1.2.2.2	Erection of electrical panels issued along with the equipment is part of scope of contractor	What is the number of panels and where should these be erected	Erection of electrical panels is not in the scope of contractor.
2	TECHNICAL CONDITIONS OF CONTRACT (TCC) VOLUME-IA PART-I CHAPTER – II SCOPE OF WORKS Clause 1.2.2.7	Equipment Manufacturer's recommendations regarding de-preservation/ preservation during storage at site store and after erection at designated location shall be strictly followed by the contractor till the completion and handed over of the system to the NPCIL.	Since erection of the system is not covered in the scope, is it contractor's responsibility up till handing over to NPCIL	The contractor responsibility lies up to completion of said contract.
3	TECHNICAL CONDITIONS OF CONTRACT (TCC) VOLUME-IA PART-I CHAPTER – II SCOPE OF WORKS Clause 1.2.4.2 item ii (h)	Draining, cleaning and its preservation by wrapping fireproof sheet	Is the fire proof sheet supplied by NPCIL	Fire proof tarpaulin will be provided by BHEL at free of cost.

SI No.	Reference clause of Tender Document	Existing provision	Bidder's query	BHEL's clarification
4	TECHNICAL CONDITIONS OF CONTRACT (TCC) VOLUME-IA PART-I CHAPTER IV Clause 1.4.1	Major T&P list Minimum Quantity column	In the tabular column min qty required, you are indicating for certain items as number required. Does it mean that this min qty has to be retained at the site throughout the contract period or is the min number is to be mobilized as and when required. The total weight for Non ODC transporting from storage to site of erection in contractor scope is only 98 MT for a period of 8 months	Please refer Clause no 1.4.3 in VOLUME IA PART I CHAPTER IV, which is self-explanatory.
5	TECHNICAL CONDITIONS OF CONTRACT (TCC) VOLUME IA PART I CHAPTER IV Clause 1.4.1 SI No. 21	Welding generator machine- 5 nos	Can welding rectifier/ Inverter be used in place of generator.	Welding rectifier / inverter may be used in place of welding generator. However Welding Procedure Specification (WPS) shall be approved by NPCIL.
6	Volume IB SPECIAL CONDITIONS OF CONTRACT, Chapter I, Clause 1.7.6 & Chapter II, Clause 2.1	1.7.6 "Preservation..... Commissioning till handing over"  2.1 "services for ..... Trial run & commissioning....."	Commissioning of the equipment is not feasible in 8 months. Clarify if covered in scope.	Commissioning Is not in the scope of the contractor.
7	VOLUME II PRICE BID Part A: Instructions to Bidders SI No. 3 & Part C	BHEL has prefixed the weightages for the amount of individual items of Bill of Quantity with respect to the 'Total Amount' in Part-C	Prefixed weightage not indicated as part of Bid in Part C. Please inform the weightage allotted to individual items of Scope	There is only one item in Part C of Price Bid. Hence weightage is indicated as 1. Rate per MT are to be arrived based on total quoted amount. Payment shall be made for the MT of equipments erected.

**Corrigendum 1 dated August 07, 2020 to Tender Specification BHEL: PSSR: SCT: 1905**

<b>SI No.</b>	<b>Reference clause of Tender Document</b>	<b>Existing provision</b>	<b>Bidder's query</b>	<b>BHEL's clarification</b>
8	TECHNICAL CONDITIONS OF CONTRACT (TCC) VOLUME IA PART I CHAPTER VII, Clause 1.7.1	PVC, ORC, Secured Advance & Advance for Mobilization are not applicable for this tender	Since this is a unit rate contract with no PVC or ORC, if the contracted works are not completed within the stipulated time period (8 months) due to reasons not attributable to the contractor, will the contract stand closed for the value of works executed. Please clarify.	Contract will be closed only after completion of entire scope of work.

Note:

- 1) All other conditions of the tender specification remain unchanged.
- 2) Bidders are requested to consider this corrigendum as part of tender specification and quote accordingly.

-Sd-  
 Sreenath N G  
 Dy. Manager / Subcontracts