

Corrigendum 1 dated 13-11-2022 to Tender Specification BHEL PSSR SCT 2057

Tender Specification BHEL PSSR SCT 2057 - Balance structural works of coal handling plant and ash handling plant area and Non plant structures of Unit-1&2 Package-I at 2x660MW Udangudi STPP.

1.0 Some of the bidders had raised queries in the published tender specification. The Clarifications issued by BHEL are furnished below: -

SI No	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
1	BOQ Ref no-2301 (C)	1. Primer Painting – 12,651 MT	We understand primer paint shall be applied after Blast cleaning of Metal surface- Please confirm. Kindly provide the separate line item for the scope of Work by allocating the additional weightage.	Yes. Primer painting shall be applied after blast cleaning of Metal surface. Tender condition prevails.
2	TCC – 2.06.04	Bending of plates and rolled sections to the required shape for fabrication shall be done by plate bending machine or cold bending process Without resorting to heating, hammering, angle smithy and black smithy process.	We understand bending of plates not required for the scope of work to be performed by bidder.	Tender condition prevails.
3	GCC – 2.14	The quantities given in the contract are tentative and may change to any extent (both in plus side and minus side). The derived item rates (as mentioned above) for individual items shall remain firm irrespective of any variations in the individual quantities. No compensation becomes payable in case the variation of the final executed contract value is within the limit of Minus (-) 15% of awarded contract value	We understand design of the CHP might be completed. Hence the quantity shall not vary more than (+/-) 10% and also indicating the quantity variation of (-) 15 % is not viable. We request BHEL to revise the percentage to +/- 10%.	Tender condition prevails.
4	BOQ Ref no-2307	Supplying, fabrication, erection and alignment of factory made electroformed galvanized grating units with mild steel having minimum galvanisation conforming to IS:2062 in flooring, platforms, drain and	The weightage provided for the scope is not meeting the Markets rates. We request BHEL to revise the percentage suitably considering the prevailing market rates.	Tender condition prevails.

Corrigendum 1 dated 13-11-2022 to Tender Specification BHEL PSSR SCT 2057

SI No	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
		trench covers, walk-ways, passages, staircases with edge binding strips and anti-skid nosing in treads etc. including fixing clamps, fittings, fixtures, all taxes, duties, packing, grinding, drilling, welding, edge preparation, etc. all complete.		
5	BOQ Ref no-2312	Providing and fixing in positing of high strength structural bolts (of property class 8.8 and product grade `C' as per IS: 1367) and conforming to IS: 3757 and high strength structural hardened and tempered nuts (of property class `8' as per IS: 1367) conforming to IS: 6623 with hardened and tempered washers as per IS: 6649 etc. up to and inclusive of 39 mm diameter and up to 300 mm long for structural steel work etc all complete.	The weightage provided for the scope is not meeting the Markets rates. We request BHEL to revise the percentage suitably considering the prevailing market rates.	Tender condition prevails.
6		8 nos. Pick and Carry cranes of minimum capacity 10 T each: As per work requirement at site.	The quantity has been reduced compared with the earlier BOQ. By considering the same, we request BHEL to modify the total requirement shall be as 05 nos.	Tender condition prevails. As per the tender condition, the mobilization of the tools & plants shall be as per the work requirements at site
7	BOQ -ref A2329	Design, supply, fabrication, erection of stop log gates, sluice gates etc in CW Pumps/Sea water Intake/Outfall pumps made out of SS 316L with embedment's required, lifting beams, special tools & plants, spare parts for three years, machining, casting, all materials such as structural steel, cast steel, stainless steel, brass used for seals, rubber seals, gears, ball and roller bearing, branch bushings, greasing, bolts, nuts, lugs,	The scope is not related to CHP Package hence requesting to remove the items from the bidder scope.	The scope of works covers Balance structural works of coal handling plant and ash handling plant area and Non plant structures of Unit-1&2. The referred items are related to the scope of the works.

Corrigendum 1 dated 13-11-2022 to Tender Specification BHEL PSSR SCT 2057

SI No	Reference Clause	Existing Provision	Bidder's query	BHEL's clarification
		threaded fasteners etc., cleaning, blasting(SA 2 1/2) to near white metal surface, along with a second stage concreting to true plumb and levels, submission of drawings / fabrication drawings for engineers approval etc all complete as per approved drawings. The leakage through rubber seal shall not be more than 5 lit/min/metre length of seal under maximum head.(only weight of stainless steel including embedment's shall be considered for payment purpose).(supply of stainless steel is in the scope of contractor only)		
8	BOQ -ref A2332, B2332	Supplying, fabricating, erecting in position and testing / examining bolted and / or welded structural steel work for stationary coarse screens made out of stainless-steel SS 316L mesh over SS 316L frame including cutting, straightening if required, edge preparation, bolting / welding of joints, cleaning, fittings etc all complete.	The scope is not related to CHP hence requesting to remove the items from the bidder scope.	The scope of works covers Balance structural works of coal handling plant and ash handling plant area and Non plant structures of Unit-1&2. The referred items are related to the scope of the works.

All other conditions of the tender specification remain unchanged.

Bidders are requested to consider this corrigendum as part of tender specification and quote accordingly.

-Sd-
Moses Prashanth Kumar
Manager/SCT