

CORRIGENDUM-2 TO TENDER SPECIFICATION BHEL: PSSR: SCT: 2112
REPLY TO BIDDERS QUERIES

Desc: Package 1 and Package 2 for Erection, Testing & Commissioning of Illumination works including Handling of materials at BHEL stores / storage yard, transporting to site of erection and supply & application of final painting, for Units-1 and Unit-2 and BOP areas at 2X660MW Udangudi Thermal Power Project, Kallamoli, Tiruchendur Taluk, Tuticorin District, Tamil Nadu.

S.NO.	Reference Clause Of Tender document	Existing Provision	Bidders Query	BHEL's Clarification
1.	TCC 1.11.1.1	For Poles and Masts: Foundation for Poles and Masts are not part of this tender. The dimension of the foundation and anchor bolt pits shall be checked by the contractor for their correctness as per drawings. Further, top elevation of foundations shall be checked with respect to bench mark etc. All materials required for the above shall be part of contractor's scope within the quoted rate. No extra payment will be made for materials to be arranged by contractor.	Here it is mentioned that "Foundation for Poles and Masts are not part of this Tender". Please clarify	Tender condition prevails Clarification: <i>Construction of Foundation for Poles and Masts is not in the scope of this contract. However, checking of the foundation and anchor bolt pits as specified in the tender specifications is in the scope of this contract.</i>
2.	TCC 1.13.5.15	STREET LIGHTING/FLOOD LIGHTING POLES INSTALLATION: The lighting poles and lighting Tower shall be erected by the contractor at locations shown in the street lighting layout. Installation of necessary wiring/ cabling including underground cabling as required, junction/ switch box and mounting of assembled fittings. All the above erection work shall be done by contractor for lighting masts including making of foundations. For loop-in-loop out, the cables from trench to junction box, shall run through the conduits..	As per "TCC 1.11.1.1 Clause "it is mentioned that "Foundation for Poles and Masts are not part of this Tender". Here in this clause it is mentioned that "All the above erection work shall be done by contractor for lighting masts including making of foundations". Please clarify.	Please refer to Corrigendum-1

Note:

- All other conditions remain unchanged.
- Bidders are requested to consider this corrigendum as part of tender specification and quote accordingly.

-sd-
MOHAMMAD HUSSAIN
Dy. Manager/ SCT