

CORRIGENDUM-3 TO TENDER SPECIFICATION BHEL: PSSR: SCT: 1662

Sub: Piling and Pile Cap Works for Coal Handling Plant and Ash Handling Plant (Inside and Outside Plant Boundary) Containing Package-1 and Package-2 for 2 X 660 MW sets Ennore SEZ Super Thermal Power Project at Ash dyke of North Chennai TPS, Chennai, Tamil Nadu State

1. **Some of the Bidders had raised queries in the published Tender Specification & subsequent Corrigendum. The Clarification issued by BHEL are furnished below:**

S.No.	Ref.	Clause ref.	Bidders Query	BHEL Reply
1.	Point No. 32 of CORRIGENDUM - 1 DT: 26-07-2017 TO TENDER SPECIFICATION BHEL PSSR SCT 1662	Item no.2512 in Bill of Quantities	Please confirm the vertical, lateral and uplift capacities of piles for 450mm, 500mm, 600mm, 760mm and 900mm dia. Piles, as requested by our Piling Vendors for quoting.	760 dia - 250T Compn. 60T Tension and shear 10.5T & 8T 600 dia - 150T Compn. 40T Tension and shear 5.5T 450 dia - 100T Compn. 25T Tension and shear 3.5T

NOTE:

1. ALL OTHER CONDITIONS REMAIN UNCHANGED.
2. BIDDERS ARE REQUESTED TO CONSIDER THIS CORRIGENDUM AS PART OF TENDER SPECIFICATION AND QUOTE ACCORDINGLY.

AGM / SCT & Purchase