



భారత్ హెవీ ఎలక్ట్రికల్స్ లిమిటెడ్
भारत हेवी इलेक्ट्रिकल्स लिमिटेड

Bharat Heavy Electricals Limited

Site office, 5 X 800 MW Yadadri Thermal Power Project
Dhamaracharla (M), Nalgonda(Dist), Telangana 508355

Ref: YTPS: SCT: 202312-185:Corr 2.

Date: 10.02.2024

To,

All Bidders

Sub: **Corrigendum-2:**

Job: YTPS: SCT: 202312-185- Erection, Testing & Commissioning of FGD Inlet & Out Let Gates and its associated works for UNIT-1& 2 of 5X800 MW Yadadri Thermal Power Project, Veerlapalem village, Damercherla Mandal, Nalgonda District, Telangana State.. Tender Specification No. YTPS: SCT: 202312-185 & Date – 27.01.2024

Bidders to kindly take note of following:

- Clarifications with painting extract for FGD duct supporting structures. (Attached)
- Below clause have been modified as given in table

SL NO	Description	Existing as	Revised as
1	SL NO E of Annexure 1 (PRE-QUALIFYING REQUIREMENTS (PQR)) - Page 20 of NIT	Approval of Customer (if applicable) : "NOT Applicable"	Approval of Customer : "Applicable"
2	CL 19 of NIT : Reverse Auction - Page 14 of NIT	BHEL shall be resorting to Reverse Auction (RA) (Guidelines as available on www.bhel.com on "supplier registration page".) for this tender. RA shall be conducted among all the techno-commercially qualified bidders. Price bids of all techno-commercially qualified bidders shall be opened and same shall be considered for RA. In case any bidder(s) do(es) not participate in online Reverse Auction, their sealed envelope price bid along with applicable loading, if any, shall be considered for ranking	Reverse Auction (RA) is not applicable for this enquiry.

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.


PAKALAPATI VINEEL
Deputy Manager/SCT & Purchase
BHEL-PSSR-5X800MW YADADRI TPP



भारत हेवी इलेक्ट्रिकल्स लिमिटेड
भारत हेवी इलेक्ट्रिकल्स लिमिटेड

Bharat Heavy Electricals Limited

Site office, 5 X 800 MW Yadadri Thermal Power Project
Dhamaracharla (M), Nalgonda(Dist), Telangana 508355

Ref: YTPS: SCT: 202312-185:Corr 2.

Date: 10.02.2024

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

Thanking You,


For and on behalf of
Bharat Heavy Electricals Limited


P Vineel

Dy Manager / Purchase & SCT

PAKALAPATI VINEEL
Deputy Manager/SCT & Purchase
BHEL-PSSR-5X800MW YADADRI TPP

S. No	Page No.	Clause no.	Short Description	Details	Concern / Query	Response by BHEL & Date
1	9 & 12 / 391	9.0	Assessment of Capacity shall be assessed based on its Load and performance and average annual turnover. On page 12 - However new vendor shall be considered qualified based on only load and performance. (... Pre-qualified on average annual turnover criterion	We are bidding as new vendor, registered our company in Nov 21. Technically and financially we are meeting tender requirement. 1. Please guide us, what performance data & financial data, we need to furnish to qualify? 2. Method of calculation for New Vendor qualification may please be shared with us.	Refer to clause 9.IV.III- Pg No-11/391 IN NIT
2	69/391	1.7.2	PVC & ORC	PVC & ORC Clauses are not applicable	In later part clause 2.17 P-115/391 & 2.12.1 P-110/391 PVC anc ORC are applicable	Pvc & ORC clauses are not applicable .Refer clause no-35- For order of precedence-Pg -18/391
3	14/391	18.0	Validity	Offer validity Three months	In later part validity is 6 months (96/391 cl. 1.13)	Offer validity for 3 months
4	11 & 22/391	--	Pre-Qualification	Criteria Format	Please provide the format.	Annexure-1-- PG 19/391 Refer clause no-35-For order of precedence-Pg -18/391
5	58/391	1.2.13	Supply of Paint	Painting and application	For cost estimation purpose : 1. Branc names and tech specs of each Paint and Primer to be specified 2. Thickness of paint to be specified	Refer Painting Schedule [attached here with]
6	63/391	1.2.13 - VI	Radiography	Radiography Testing	No Radiography is in the bidder scope	Radiography not applicable for gates and structure
7	64/391	1.3.11.4	Electrode storage	Storage of Electrode shall be done in Air Conditioned	Electrode Storage room will have Heaters (not AC)	Electrode storage room should be humidity controlled as per clause 1.3.11- Page-64/391
8	336 / 391	7	Important	Modular Bio Toilets	Conventional Toilet having water flushing with Soak Pit to be allowed	No tender condition prevails
9	156 / 391	1.7.4	Payment of running bills	within 30 days	As BHEL is not giving intrest free advance, therefore BHEL is requested to change timeline to 7 to 14 working days max from the date of receipt of tax invoice alongwith approved measurement sheet	No tender condition prevails
10	106/391	2.8.6	Fees and Regn fee of Boiler / Electrical Inspectorate	Boiler Inspector and related welding work	We have not considered any activity related to IBR welder	Fees Nil


 SR. MANAGER
 BOILER ERECTION
 BOILER INSPECTORATE
 BHEL-PSSR-5X800MW YADADRI TPs
 VEERLAPALEM, DAMARCHERLA,
 Dist. Telangana-508 355.


 SR. MANAGER
 ADDL. MECHANICAL
 MECHANICAL
 BHEL-PSSR-5X800MW YADADRI TPs
 VEERLAPALEM, DAMARCHERLA,
 Dist. Telangana-508 355.

SR. MANAGER
 BOILER ERECTION
 BOILER INSPECTORATE
 BHEL-PSSR-5X800MW YADADRI TPs
 VEERLAPALEM, DAMARCHERLA,
 Dist. Telangana-508 355.

BHEL Tender YTPS: SCT: 202312-185

Date 03rd Feb 2024

Erection Testing & Commissioning of FGD Inlet and Outlet Gates for 5x800 MW Yadadru TPS

S. No	Page No.	Clause no.	Short Description	Details	Concern / Query	Response by BHEL & Date
11	82 / 391	1.12.1.157	Idle charges	Contractor shall not claim anything extra like idle charges	<p>1. Duration of the contract is only 3 months for each package. If the work stops or delays for the reasons not attributed to bidder, idle charges should be payable. Even for significant delay in receiving clearance from BHEL, Idle charges should be payable on submission of proper records and justified reasons.</p> <p>2. In case Package 1 and 2 are awarded to same bidder, there are all possibilities of Idle time between Package 1 finish and Package 2 start. In that case also Idle charge should be payable</p>	No tender condition prevails
12	111/391	2.12.3.5	Max amount of ORC	Limited to 5,00,000/- per month	There should not be any cap / upper limit	ORC not Applicable
13	111/391	2.12.3.6	ORC Limit	Lower limit 1,00,000/-	Lower limit should be min payable 2,00,000/-	ORC not Applicable
14	113/391	2.14.1	Quantity variation	Limit of minus 15% of contract value, no compensation becomes payable	Minus limit should be 10% or less	Tender condition prevails
15	114/391	2.15.5	Man hour rate for Extra work	Rs 108/- per man hour including tools and consumables	<p>1. Rate 108/- is very less. Consumables should be paid extra at actual.</p> <p>2. Rate for skilled manpower should be more than unskilled manpower</p>	Tender condition prevails
16	264/391	--	Medical Centre	Medical Centre & Facilities	We understand all type of Medical Centre / Facilities / Ambulance / Male Nurses etc shall be provided by BHEL on cost sharing basis by each contractor. Bidder need not to provide any separate first aid / medical centre and medical staff.	Tender condition prevails
17	320 / 391	C	Medical Centre	calculation formula is linked with duration of contract	All calculations should be linked with Contract Value + average No. of workers in the month	Tender condition prevails

Handwritten signature
8/2/24
Sr. MANAGER
KVKSV PRASAD RAO
SR. MANAGER
INSPECTION
BHEL-PSSR 5x800 MW YADADRU TPP
VEERLAPALEM, DAMARCHIERLA,
Nalgonda Dist. Telangana-508 355.

Handwritten signature
ADDITIONAL GENERAL MANAGER
MECHANICAL
BHEL-PSSR 5x800 MW YADADRU TPP
VEERLAPALEM, DAMARCHIERLA,
Nalgonda Dist. Telangana-508 355.

SI No	SURFACE LOCATION	PGMA	SURFACE PREPARATION	PRIMER		FINISH		TOTAL DFT IN (µm min.)
				PAINT	DFT (µm min.)	PAINT	DFT (µm min.)	

30	Duct structure between ducts	FW 260	Blast cleaning to Sa 2½ (Near white metal) with surface profile 35-50µm	<p>Primer Coat: One coat of epoxy based Zinc phosphate primer to IS 13238; DFT- 100µm</p> <p>Intermediate Coat: One coat of Epoxy based MIO pigmented intermediate coat; DFT- 100µm</p>	100	<p>Finish coat: One coat of Epoxy based finish coat to IS 14209; DFT- 100µm</p> <p>+ One coat of Aliphatic acrylic polyurethane paint to IS 13213; Shade no: 631 of IS 5</p>	75	300
----	------------------------------	--------	---	---	-----	--	----	-----