

Corrigendum 2 dated March 17, 2021 to Tender Specification BHEL: PSSR: SCT: 1945 for the work of Erection, Testing, Commissioning & Trial Operation including Handling of Materials at BHEL / Client's Stores / Storage Yard, Transportation to site of erection, supply and application of painting of Steam Turbine, Turbo Generator & auxiliaries including BOI of Package-A Consisting of (Unit-1 & Unit-3) and BOP of Stage 1 (Unit 1 and Unit 2) and Package-B consisting of (Unit 2 & Unit 4) and BOP of Stage 2 (Unit 3, Unit 4 and Unit 5) of 5 x 800MW Yadadri TPS for TSGENCO at Veerlapalem Village, Dameracherla Mandal, Nalgonda Dist, Telangana State

A. Some of the Bidders had asked queries in the published Tender Specification. The clarifications issued by BHEL are furnished below:

SI No	Ref Clause	Description	Bidder Query	BHEL Reply
1	Notice Inviting Tender Clause 33.4	The ratio of total amounts for Package A: Package B is 1:1.033	The clarification provided in the Corrigendum is not reasonable. We request to consider the proposal of Bidder submitted vide our previous queries dated 05-03-2021 and revise the clause suitably.	Matter is reviewed and found in order. No change in tender conditions published.
2	TCC VOLUME-IA PART-I CHAPTER VII-TERMS OF PAYMENT Clause 1.7.3.1.1.7	INTEGRAL PIPING-13.60%	The percentage allocated towards piping is very high considering the quantity of Work as per the CHAPTER -IX- BILL OF QUANTITY and also the description mentioned in the BBU is not matching with the description in the Bill of quantities. We request to reduce the percentage of Piping in the BBU along with the scope description.	Matter is reviewed and found in order. No change in tender conditions published.
3	TCC VOLUME-IA PART-I CHAPTER IV-T&PS and MMEs TO BE DEPLOYED BY CONTRACTOR Clause 1.4.3	For loading, transportation and erection, all necessary T&P such as Trailers, Cranes, Winches, welding generators, slings, jacks, sleepers, rails etc., are to be arranged by the contractor.	Kindly specify the Min and max weight of the component to be transported from the storage area and also request to incorporate the separate line item for handling of components weight more than 30 T from Storage area to erection in line with the similar kind of	Min And Max Weight can be derived from VOLUME-IA PART-I CHAPTER -IX BILL OF QUANTITY Shipping list. For handling of component weighing more than 30 T-Tender Conditions Prevail

SI No	Ref Clause	Description	Bidder Query	BHEL Reply
			package awarded BHEL. The BOQ has been enclosed for reference.	
4	TCC VOLUME-IA PART-I CHAPTER XIV- ERECTION Clause 1.14.1.77	Contractor has to fabricate and erect temporary spool pieces wherever required due to non-receipt of valves in time and after receipt of valves the spool pieces are to be replaced with regular valves at no extra charges to BHEL. For spool pieces' materials will be supplied free of cost by BHEL.	At this stage we cannot assume such quantum of Works to conclude our costing. Hence kindly consider our request and treat such work as Extra works.	Tender Conditions Prevail
5	TCC VOLUME-IA PART-I CHAPTER XIV- ERECTION Clause 1.14.1.78	Wherever hanger and support materials of piping are not received from manufacturing unit in time, to suit the erection schedule contractor shall erect the piping system on temporary supports to ensure the progress of work.	At this stage we cannot assume such quantum of Works since the scope includes fabrication, Erection and dismantling which consumes more manpower. Hence kindly consider our request and treat such works as Extra works.	Tender Conditions Prevail
6	TCC VOLUME-IA PART-II CHAPTER 1 SI No: 19	Single composite average labour man-hour rate, including overtime if any, supervision, use of tools and tackles and other site expenses and incidentals, consumables for carrying out any major rework / repairs / rectification / modification / fabrication as certified by site as may arise during the course of erection, testing, commissioning or	Wages of Manpower is increasing periodically and contractor also has to survive during the execution of Work. We request to revise the Man-hour rate keeping the quarterly increase of wages in view.	Tender Conditions Prevail

SI No	Ref Clause	Description	Bidder Query	BHEL Reply
		extra works arising out of transit, storage and erection damages, payment, if found due will be at Rs 108/- per man hour.		

Note:

- 1) All other conditions of the tender specification remain unchanged.
- 2) Bidders are requested to consider this corrigendum as part of tender specification and quote accordingly.

-Sd-
Vinod Jaseja
Sr. Dy. Gen. Manager / Subcontracts