

Project: SAGARDIGHI TPP 1X660MW UNIT-5, PHASE-III

PS NO: PS4092152/S-II Rev-00

Enquiry No.: SGKNIC0041

Vendors have to make their Technical & Financial offer considering following changes in BHEL specification PS4092152/S-II Rev-00.

(A) Frequency response: 0 Hz to 10 KHz (-3dB)

For following tables;

1.2 Relative Shaft Vibration Measurement

1.3.1 Rotor Expansion Measurement, Bearing Before HP Turbine (MAD11)

1.3.2 Rotor Expansion Measurement, Bearing behind Last LP Turbine (MAD15)

1.5 Axial Shift

1.6 Reference Phase Measurement (Key Phasor)

(B) For Table 1.5 Axial Shift :

Sensor Tip Diameter: 8 mm or 10 mm*

Body Thread size: M10 X 1 or M12 X 1.25*

**if this option is chosen, vendor has to offer suitable mounting bracket for the same, subject to BHEL approval.*