

Annexure 1

D. M. P L A N T

TECHNICAL SPECIFICATIONS

FLOW MAX Ltr / hr.	500
OUTPUT Ltrs/Reg	2000
<u>Working Pressure</u>	
Minimum Kg/Cm ²	1
Maximum Kg/Cm ²	2.5
Size of piping's M M	20
Size & Type of Valve M M	20
Material of Const	F R P
<u>CHEMICAL / REGENERATION</u>	
HCl 30 % Conc. Ltrs	18
NaOH Flake Kgs	2
Minimum Output Per day	1000 Ltr.
Raw Water	500 PPM
End water	25 PPM

*Chandan Kumar
12.8.13*