


SPECIAL CONDITION ANNEXURE – A

PR No.: 129199597


1. The indented items are required for NPCIL / Gorakhpur Haryana Anu Vidyut Pariyojina (GHAVP) -1 & 2, 700MWe Steam Generator Project.
2. Two-part bid, open tender to be floated.
3. **End Use and End User Certificates will not be provided by BHEL.**
4. Supply of Seamless steel pipe as per DIN EN 10216-2 Grade 1.5415(16Mo3) and technical specification **TDC-D157-001 Rev 02 Dt 06.11.2019**. Supplier to confirm.
5. Supplier to give clause by clause confirmation for all clauses mentioned in TDC. Deviations shall be mentioned in the offer itself.
6. **For offer acceptance**, Suppliers should have the capability and experience to produce the alloy steel tubes / pipes as per quality standards. Also, Supplier should have supplied the alloy steel tubes / pipe for the nuclear application / Nuclear Power Corporation of India Limited / any Thermal Power station.
7. **As a documentary proof of supplier's experience** in manufacturing the intended items, Signed Test Certificates (Signed by Customer/TPI), Shipping release document/ supply invoice copy with specifications and details of Customer shall be submitted along with offer.
8. Offers received will be evaluated by BHEL and NPCIL. Final acceptance of the offers will be based on NPCIL recommendation.
9. Supplier has to comply with the generic approved Quality Plans enclosed with the indent.
10. Supplier has to submit Quality Documents (QAP – Quality Assurance Plan, Manufacturing Process Plan and associated procedures, Material Sampling and Testing Plan (MSTP) and related test procures as per QAP for approval from BHEL & NPCIL after awarding the contract.
11. The actual production of material is permitted only after approval of all documents required for manufacturing / inspection / testing activities by BHEL and NPCIL.
12. Inspection agency for imports are BHEL & NPCIL or NPCIL appointed third party inspection (TPI) agency. Inspection agency for indigenous supply are BHEL and NPCIL.


07/06/2021
Engineering

M. ARUN KUMAR
Deputy Manager
Engg & RPD / ATP
BHEL, TRICHY - 620 014


07/06/2021
Quality Assurance

O.R. NITHIN
Deputy Manager
Quality Assurance
BHEL, TRICHY - 620 014



Materials Planning


07.06.21


SPECIAL CONDITION ANNEXURE – A

PR No.: 129199597


13. Chemical composition and mechanical tests shall be carried out in labs certified as per ISO/IEC 17025 or NABL / Government approved labs.
14. Non-destructive examination shall be performed by Ultrasonic Examination only as per clause No:8.1 of TDC-D157-001 Rev 02.
15. Leak Tightness Test shall be performed by Hydrostatic Test only as per clause No:9.0 of TDC-D157-001 Rev 02
16. Supplier shall submit Test Certificates of finished materials for our review. Dispatch clearance will be given after acceptance of Test Certificates by BHEL & NPCIL.
17. Documentation: Three sets of documents containing (i.) Test Certificates and respective test reports (ii.) copies of the approved quality documents and test procedure, (iii.) design change requisitions (if any) and (iv.) Drawing etc. to be provided along with the supply of items.
18. All the items shall be procured from single source on full package basis.
19. Supplier to submit his technical and commercial bid conforming to the above points as given in this annexure.


07/06/2021
Engineering


M. ARUN KUMAR
Deputy Manager
Engg & RPD / ATP
BHEL, TRICHY - 620 014


07/06/2021
Quality Assurance

O.R. NITHIN
Deputy Manager
Quality Assurance
BHEL, TRICHY - 620 014


07.06.21
Materials Planning

ASHWIN KUMAR MAROLI
Manager
Advanced Technology Products
BHEL, TRICHY - 620 014


O.R. NITHIN
Deputy Manager
Quality Assurance
BHEL, TRICHY - 620 014