

Date -30.11.2017

**AMENDMENT OF TECHNICAL SPECIFICATION OF 765kV Reactor and NGR
ARIYALUR PROJECT**

DOCUMENT No. TB-394-316-102, Rev. No.-00

- (1) Section -1, Cl. No. 1.2.1 (sl. No. 8 of neutral grounding reactor (NGR))
should be read as mentioned below**

8.	Rated short time current (rms) (60 secs.)	240A(However the NGR shall be designed for a current rating of 600A rms short time current to ensure mechanical robustness which will be verified during design review)
----	---	---

- (2) Section -1, Cl. No. 1.4.2 (Note sl. No. 3)- It is not applicable for this
contract.**

Saib Kumar
30/11/2017