ANNEXURE I

<u>Specifications for Third Party certifications tests for Conformance to IEC 61850 Sampled Measured Values, GOOSE Publish and Subscription</u>

1.0 Details of the Device to be Tested

Device Name : BHEL-MU

Device Type : Merging unit for process bus

Functions in the device : Sampled Measured Values publish (IEC61850-9-2)

GOOSE publish and subscribe (IEC61850-8-1)

Manufacturer's name : BHEL, INDIA

2.0 The following documents shall be provided at the time of test:

- 1. Protocol Implementation Extra Information for Testing (PIXIT)
- 2. Protocol Implementation Conformance Statement (PICS)
- 3. Model Implementation Conformance Statement (MICS)
- 4. Technical Issues Conformance Statement (TICS)
- 5. IED Configuration Description file (ICD)
- 6. Instruction Manuals for the operation of the Device to be tested.

3.0 The testing agency must provide the following details in the quotation

- 1. Procedures adopted for testing along with the test tools
- 2. Approximate time
- 3. Testing Charges

4.0 Additional information

Detailed test report and test certificate should be issued by the Testing Agency

For any Technical Clarifications please contact –

Mrs V Shyamala, DGM(TPS) e-mail ID: shyamala@bhelrnd.co.in