

ANNEXURE -1 FOR PURCHASE INDENT NO.637511051

ITEM NO-1

Distribution board with 12 WAY 30 AMP. WITH IN COMING SWITCH

Triple pole neutral 12 way 30 Amp. MCB distribution board with metal door complete with 12 numbers Triple pole MCB (C curve) rating 30/32 Amp. (make – Legrand/ L&T/ C&S/ scheneder only). Distribution board should be supplied with one number triple pole ICTPN fuse switch unit CH type rating 100 Amp. with 3 Nos. 100 Amp. HRC fuses TC type (make – EE power control only) and suitable cable termination chamber.

Quantity – 15 Nos.

ITEM NO-2

Distribution board with 08 WAY 60 AMP. WITH IN COMING SWITCH

Triple pole neutral 8 way 63/60 Amp. fuse distribution board (CH63TN8) with 24 Nos. 63 Amp. HRC fuse TIS type. Distribution board should be supplied with one number triple pole ICTPN fuse switch unit rating 200 Amp. with 3 Nos. 200 Amp. HRC fuses TF type (make – Legrand/ L&T/ C&S/ scheneder/ EE power control only).and suitable cable termination chamber.

Quantity – 07 Nos.

ITEM NO-3

Distribution board with 06 WAY 100 AMP. WITH IN COMING SWITCH

Triple pole neutral 6 way 100Amp. fuse distribution board 9SM100 TN6) with 100 Amp. HRC fuse TCP type . Distribution board should be supplied with one number triple pole ICTPN fuse switch unit rating 315 Amp. CH type with 3 Nos. 300 Amp. HRC fuses TKF type (make – Legrand/ L&T/ C&S/ scheneder/ EE power control only).and suitable cable termination chamber.

Quantity – 06 Nos.

