

Technical Specifications

MCB

SL.NO	DESCRIPTION	SPECIFICATION
1	MCB DISTRIBUTION BOARD 4 WAY 15 AMPS	TPN, 4 ways, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018) with one number 32 amps 10KA 4 pole MCB as Incomer, outgoing 16 amps 10 KA single pole MCB 12 Nos, per way 4 Nos, (MCB as per IS/IEC 60947: Part 2: 2016), with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
2	MCB DISTRIBUTION BOARD 8WAY 15 AMPS	TPN, 8 ways, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 100 amps 10KA, 4 pole MCB as incomer. Each Phase controlled with 32 amps' double pole MCB, outgoing 16 amps 10 KA single pole MCB 24 Nos, per way 8 Nos, MCB (as per IS/IEC 60947: Part 2: 2016), with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
3	MCB DISTRIBUTION BOARD 12WAY 15 AMPS	MCB DISTRIBUTION BOARD 12WAY 15 AMPS Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
4	MCB DISTRIB.BOARD 8WAY 15A PHA CONROL	TPN,8 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 63 amps 10KA 4 pole MCB as Incomer, each phase controlled with 32 amps' double pole MCB, outgoing 16 amps 10 KA single pole MCB 24 Nos, per way 8 Nos, (MCB as per IS/IEC 60947: Part 2: 2016), with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
5	MCB DISTRIBUTION BOARD 12 WAY 15 AMPS	TPN, 12 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 32 amps 10KA, 4 pole MCB as Incomer, outgoing 16 amps 10 KA single pole MCB 36 Nos, per way 12 Nos MCB (as per IS/IEC 60947: Part 2: 2016), with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent

6	MCB DISTRIB.BOARD 12WAY 16A PHA CONTROL	TPN 12 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 63 amps 10KA, 4 pole MCB as Incomer, Each Phase controlled with 32 amps' double pole MCB, outgoing 16 amps 10 KA single pole MCB 36 Nos, per way 12 Nos MCB (as per IS/IEC 60947: Part 2: 2016) with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
7	MCB DISTRIBUTION BOARD 8 WAY 32 AMPS MDS	MCB DISTRIBUTION BOARD 8 WAY 32 AMPS MDS Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
8	MCB DISTRIBUTION BOARD 12W32A PHA CONTRL	12 way,32A, TPN, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 125 amps MCCB, 16KA, 4 pole MCB as Incomer, Each Phase controlled with 63 amps double pole MCB, outgoing 32 amps 10 KA, single pole MCB 36 Nos, per way 12 Nos, (MCB as per IS/IEC 60947: Part 2: 2016, with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
9	MCB DISTRIBUTION BOARD 12 WAY 32 AMPS	TPN 12 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 125 amps 16KA, 4 pole MCCB as Incomer, outgoing 32 amps 10 KA single pole MCB 36 Nos, per way 36 Nos, (MCB as per IS/IEC 60947: Part 2: 2016) with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
10	MCB DISTRIBUTION BOARD 8W 32A, PHA CONTRL	TPN 8 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 100 amps 16KA 4 pole MCB as Incomer, Each Phase controlled with 63 amps' double pole MCB, outgoing 32 amps 10 KA single pole MCB 24 Nos, (MCB as per IS 8828: 1996(Reaffirmed 2006) and IS/IEC 60947: Part 2: 2016) per way 8 Nos, with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent

11	MCB DISTRIBUTION BOARD 8 WAY 32 AMPS	TPN 8 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 100 amps 16KA 4 pole MCB as Incomer, Each Phase controlled with 63 amps' double pole MCB, outgoing 32 amps 10 KA single pole MCB 24 Nos, (MCB as per IS/IEC 60947: Part 2: 2016) per way 8 Nos, with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
12	MCB DISTRIBUTION BOARD 8WAY 63AMPS	TPN, 8 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 100 amps 16KA, 4 pole MCB as Incomer, outgoing 63 amps 10 KA single pole MCB 24 Nos, per way 8 Nos, (as per IS/IEC 60947: Part 2: 2016), with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
13	MCB DISTRIBUTION BOARD 8W 63A PHA.CONTRL	TPN 8 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 125 amps 16KA, 4 pole MCB as Incomer, Each Phase controlled with 80 amps double pole MCB, outgoing 63 amps 10 KA single pole MCB 24 Nos, per way 8 Nos (MCB as per IS/IEC 60947: Part 2: 2016) with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
14	MCB DISTRIBUTION BOARD 12WAY 63AMPS	TPN, 12 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 125 amps 16KA 4 pole MCB as Incomer, outgoing 63 amps 10 KA single pole MCB 36 Nos, per way 12 Nos, (MCB as per IS/IEC 60947: Part 2: 2016), with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent

15	MCB DISTRIBUTION BOARD 12W 63A PHA.CONTRL	TPN 12 way, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 125 amps 16KA 4 pole MCB as Incomer, Each Phase controlled with 80 amps' double pole MCB, outgoing 63 amps 10 KA single pole MCB 36 Nos, per way 12 Nos, (MCB as per IS/IEC 60947: Part 2: 2016 with 100 Amps copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts, and with 35 sqmm cage terminals with safety shutters. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
16	16A 230V RCBO WITH METAL CLAD PLUG&SOCKE	surface mounting metal box Distribution Board as per IS 8623, 1993 (Reaffirmed 2018), with IK08 protection, with 16amps metal covered porcelain base plug, socket controlled by 16amps -10kA -30mA SPN RCBO are confirming with IS/IEC 60947: Part 2: 2016. Supplied with neutral links of single pole socket, mounting key holes, Top and bottom removable gland plates with knockouts. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
17	20A 230V MCB WTH METAL CLAD PLUG&SOCKET	surface mounting metal box Distribution Board as per IS 8623, 1993 (Reaffirmed 2018), with metal covered porcelain base plug and socket with controlled by 20amps miniature circuit breaker, supplied with neutral links of single pole socket, mounting key holes, Top and bottom removable gland plates with knockouts. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
18	SINGL PHASE 4 WAY 15 A DISTRIBUTION BOARD	Surfacing Single phase, 4 ways, IP 42 protection distribution board, metal door, as per IS 8623, 1993 (Reaffirmed 2018), with one number 63 amps 10KA 2 pole MCB as Incomer and outgoing is 16 amps, 10 KA, single pole MCB, (MCB as per IS/IEC 60947: Part 2: 2016) with copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
19	SINGL PHASE 8 WAY 15 A MCB DISTRIB.BOARD	Surfacing Single phase, 8 way, IP 42 protection distribution board, metal door, as per IS/IEC 60947: Part 2: 2016, with one number 63 amps 10KA, MCB as Incomer, outgoing 15 Amps 10 KA single pole MCB, (MCB as per IS/IEC 60947: Part 2: 2016) with copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent

20	SINGL PHASE 12 WAY 16 A MCB DISTRI.BOARD	<p>Surface mounting Single phase with neutral double door (metal door), IP 43 MCB distribution board, as per IS 8623, 1993 (Reaffirmed 2018) comprising of 60/63A,2pole,10KA, MCB for Incomer 1no and 15/16A,1pole,10KA, MCB for outgoing 12Nos, miniature circuit breakers as IS/IEC 60947: Part 2: 2016). Din rail mounting type with copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts.</p> <p>Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent</p>
21	SINGLE PHASE 4 WAY 30/32 A MCB D.B.	<p>Surface mounting Single phase with neutral double door (metal door), IP 43 MCB distribution board, as per IS 8623, 1993 (Reaffirmed 2018) comprising of 60/63A, 2pole, 10KA, MCB for Incomer 1no and 30/32A, 1pole, 10KA, MCB for outgoing 4Nos, miniature circuit breakers as IS/IEC 60947: Part 2: 2016). Din rail mounting type with copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts.</p> <p>Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent</p>
22	SINGLE PHASE 8 WAY 30/32 A MCB D.B.	<p>Surface mounting Single phase with neutral double door (metal door), IP 43 MCB distribution board, as per IS 8623, 1993 (Reaffirmed 2018) comprising of 60/63A, 2pole, 10KA, MCB for Incomer 1no and 30/32A, 1pole, 10KA, MCB for outgoing 4Nos, miniature circuit breakers as IS/IEC 60947: Part 2: 2016). Din rail mounting type with copper bus bar, neutral bar, earth bar and cable ties for cable management. Top and bottom removable gland plates with knockouts.</p> <p>Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent</p>
23	6WAY/80AMPS. VTPN MCCB DB.	<p>Supply of surface mounting VTPN Distribution Board of metal door type as per IS 8623 , 1993 (Reaffirmed 2018) with IP43 protection with MCB, ELM and MCCBs provides are confirming to IS/IEC 60947 : Part 2 : 2016.The DB should consists of 6ways ,80amps rating triple pole MCB output (18modules -80A 10Ka -D curve triple pole MCB) are controlled by one number of 250Amps, 4 pole, 25kcalcu MCCB with 300mA ELM & rotary handle attached incomer and duly wired with insulated 250Amps rating copper conductor bus bars, two neutral bars per phase, two earth bars per phase, with supply of additional sets of spreader links with bolts & nuts, top & bottom cable end boxes.</p> <p>Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent</p>

24	6WAY/63AMPS. VTPN MCCB DB.	Supply of surface mounting VTPN Distribution Board of metal door type as per IS 8623 , 1993 (Reaffirmed 2018) with IP43 protection with MCB,ELM and MCBs provides are confirming to IS/IEC 60947 : Part 2 : 2016.The DB should consists of 6ways ,80amps rating triple pole MCB output (18modules -80A 10Ka -D curve triple pole MCB) are controlled by one number of 250Amps, 4 pole, 25kalcu MCCB with 300mA ELM & rotary handle attached incomer and duly wired with insulated 250Amps rating copper conductor bus bars, two neutral bars per phase, two earth bars per phase, with supply of additional sets of spreader links with bolts & nuts, top & bottom cable end boxes. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
25	MCB TRIPLE POLE15AMPS LOADSTAR MDS	Triple Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, breaking capacity 3ka, surface mounting suitable for 240/415 volt 50Hz., AC supply Rated for 15 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
26	MCB FOUR POLE 15AMPS LOADSTAR MDS	Four Pole, Miniature Circuit Breaker as perIS/IEC 60947: Part 2: 2016, breaking capacity 3ka, surface mounting suitable for 240/415 volt 50Hz., AC supply Rated for 15 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
27	MCB SINGLE POLE 32AMPS LOADSTAR MDS	Single Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, breaking capacity 3ka, surface mounting suitable for 240/415 volt 50Hz., AC supply Rated for 32 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
28	MCB DOUBL POLE 32AMPS LOADSTAR MDS	double Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, breaking capacity 3ka, surface mounting suitable for 240/415 volt 50Hz., AC supply Rated for 32 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
29	MCB TRIPLE POLE 32AMPS LOADSTAR MDS	Triple Pole, miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016 breaking capacity 3ka, surface mounting suitable for 240/415 volt 50Hz., AC supply Rated for 32 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
30	MCB TRIPLE POLE 63AMPS LOADSTAR MDS	Triple Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, Instantaneous Tripping Range C, surface mounting suitable for 415 volt 50Hz., AC supply Rated for 63 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent

31	MINIATURE CIRCUIT BREAKER 32A FOUR POL	MINIATURE CIRCUIT BREAKER 32A FOUR POL Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
32	MCB 15 AMPS TRIPLE POLE LEXIC LEGRAND	MCB 15 AMPS TRIPLE POLE LEXIC LEGRAND Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
33	MCB SINGLE POLE 6 AMPS	Single Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, Instantaneous Tripping Range C, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 240/415 volt 50Hz., AC supply Rated for 6 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
34	MCB SINGLE POLE 15/16 AMPS	Single Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, Instantaneous Tripping Range C, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 240/415 volt 50Hz., AC supply Rated for 15/16 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
35	MCB DOUBLE POLE 15/16AMPS LEXIC LEGRAND	Double Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, breaking capacity 10ka, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 15/16 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
36	MCB 15 AMPS FOUR POLE LEXIC LEGRAND	Four Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, breaking capacity 10ka, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 16 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
37	MCB SINGL POLE 32AMPS LEXIC LEGRAND	Single Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, breaking capacity 10ka, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 240/415 volt 50Hz., AC supply Rated for 32 Amps Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent

38	MCB DOUBLE POLE 32 AMPS	Double Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, Instantaneous Tripping Range C, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 32 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
39	MCB TRIPLE POLE 32AMPS	Triple Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, Instantaneous Tripping Range C, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 32 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
40	MCB FOUR POLE 40 AMPS	Four Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, Instantaneous Tripping Range C, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 40 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
41	MCB SINGLE POLE 63 AMPS LEXIC LEGRAND	Single Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, breaking capacity 10ka, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 240/415 volt 50Hz., AC supply Rated for 63 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
42	MCB DOUBLE POLE 63 AMPS LEXIC LEGRAND	Double Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, breaking capacity 10ka, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 63 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent
43	MCB THREE POLE 40 AMPS	Three Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, Instantaneous Tripping Range C, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 40 Amps. Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent

44	MCB FOUR POLE 63AMPS	<p>Four Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016, Instantaneous Tripping Range C, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 63 Amps.</p> <p>Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent</p>
45	MCB FOUR POLE 100 AMPS	<p>Four Pole, Miniature Circuit Breaker as per IS/IEC 60947: Part 2: 2016 breaking capacity 10ka, with integrated label holder, Bi connect upper and lower terminals, 35 sqmm cage terminals with safety shutters, air channel for low temperature rise clip on auxiliaries. Suitable for 415 volt 50Hz., AC supply Rated for 100 Amps.</p> <p>Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent</p>
46	20AMPS SPMCB with ELCB.	<p>Metal covered Plug & socket 20amps rating with 30mA/20amps SPN RCBO assembled, wired in metal enclosure IP 20 protection metal box and it suitable for 230volt single phase AC 50HZ operation.</p> <p>Make: Legrand/L&T/ Siemens /Hager/C & S/GE/Indoasian/Havells/ Schneider/ABB and Equivalent</p>

Annexure B

Pre-Qualification Criteria

SL. No	Pre-Qualification Criteria	Vendor's Confirmation /Acceptance
Only those vendors who satisfies the following conditions will get qualified to participate in the tendering process. If the vendor does not qualify as per PRE-Qualification criteria, the technical offer of such BIDDER / VENDOR offer will not be evaluated/Considered.		
1.	The Vendor / Bidder should submit following details which are necessary for qualifying their offer.	
2.	The Vendor / Bidder should submit at least one Purchase Order reference towards the supply of MCB DISTRIBUTION BOARD/MCB in the last 3 years to BHEL (or) any-other Organisation. The Purchase order should be in the name of the Bidder.	
3.	BHEL reserves the right to visit the vendor's works for verifying the manufacturing facilities and any other credential furnished by the vendor. In case the information furnished with the offers found to be false / incorrect, the offer shall be rejected.	

Supplier's Signature & Seal

Annexure – A- Additional Terms and Conditions for GeM Enquiry

The terms and condition mentioned in this document are applicable in addition to the GeM General Terms and Conditions. Bidders shall furnish pointwise confirmation/details.

<u>To be filled by bidder</u>		
Description of the Equipment:		
GeM Tender No. & Date		
Name of the firm (Bidder)		:
Address		:
Contact person 1		Contact person 2
Name:		Name:
Designation:		Designation:
Office Phone:		Office Phone:
Mobile:		Mobile:
e-mail:		e-mail:
Offer/Quotation reference with date		:
SI	Terms and conditions	Vendor's confirmation
1.	<p>Payment terms:</p> <p>1. Payment terms for Non MSME Suppliers: 90 days from the date of Vehicle/Gate entry date at BHEL Stores (Against submission of GST invoice, GeM invoice, LR copy, Last Movement e-Way Bill & subjected to Material acceptance by BHEL)</p> <p>2. Payment terms for Eligible Micro & Small Enterprises (MSEs): 45 days from the date of Vehicle/Gate entry date at BHEL Stores (Against submission of GST invoice, GeM invoice, LR copy, Last Movement e-Way Bill & subjected to Material acceptance by BHEL)</p> <p>3. Payment terms for Eligible Medium Enterprises: 60 days from the date of Vehicle/Gate entry date at BHEL Stores (Against submission of GST invoice, GeM invoice, LR copy, Last Movement e-Way Bill & subjected to Material acceptance by BHEL)</p> <p>Note:</p> <p>1. In case of MSME, the supplier should upload UDYAM Registration Certificate in proof of their MSME Status.</p>	
2.	Delivery Period: Within 56 days from the date of GeM contract	
3.	<p>Liquidated Damages: LD terms shall be as per GeM General Terms and Conditions.</p> <p>Note: Vehicle/Gate entry date at consignee location will be considered for LD calculation (I.e. LD will be calculated for the Period from Contract delivery due date to date of Vehicle/Gate entry date at BHEL Stores).</p>	
4.	Response to Tenders for Indigenous supplier will be entertained only if the vendor has a valid GST registration number which should clearly mentioned in the offer. Indicate the GST registration number. If any specific exemption is available, a declaration with due supporting documents need to be furnished for considering the offer.	GST Registration No. _____
5.	Performance Bank Guarantee: Not Applicable	
6.	Kindly Indicate the HSN Code for all items	HSN CODE : _____
7.	Rate quoted in GeM portal should be on FOR destination basis inclusive of all taxes, P&F, freight etc. Transit Insurance is under Supplier scope. Please indicate how much GST percentage is included in quoted price.	GST in %: _____

Vendor's Seal & Signature

Bid Specific Additional Terms and Conditions

1.	<p>Technical: Supply shall be as per technical Specifications indicated in the enquiry. Bidder shall comply the technical specification as per the enquiry.</p>
2.	<p>Firm Price: The quoted / finalised rates shall be Firm till execution of the supplies. Offer with PVC clause will not be considered.</p> <p>Note: In single packet bid system RA is not applicable. hence suppliers to quote their best price while submitting their offer itself.</p>
3.	<p>Bid evaluation:</p> <p>Evaluation of bids will be in Single packet bid system.</p> <p>In the single packet bid system, all vendors who submitted financial bids will be ranked at the time of the opening of the financial bids.</p> <p>On opening the bids, initial ranking will be made based on the offered prices of all the suppliers, but their bids may or may not be Technically Suitable.</p> <p>Submitted bids will be evaluated based on the ranking at the time the bids are opened. As it is not mandatory for the buyer to evaluate all the bids in the single packet bid process, so buyer can evaluate the minimum number of bids as per the Splitting or MSE/MII Purchase Preference (if applicable).</p> <p>In case of rejection of offer(s) on evaluation, only the remaining offers will be considered for final ranking and order will be processed accordingly.</p>
4.	<p>Delivery period: As indicated in GeM Enquiry only.</p>
5.	<p>Payment terms:</p> <ol style="list-style-type: none"> 1. Payment terms for Non MSME Suppliers: 90 days from the date of Vehicle/Gate entry date at BHEL Stores (Against submission of GST invoice, GeM invoice, LR copy, Last Movement e-Way Bill & subjected to Material acceptance by BHEL) 2. Payment terms for Eligible Micro & Small Enterprises (MSEs): 45 days from the date of Vehicle/Gate entry date at BHEL Stores (Against submission of GST invoice, GeM invoice, LR copy, Last Movement e-Way Bill & subjected to Material acceptance by BHEL) 3. Payment terms for Eligible Medium Enterprises: 60 days from the date of Vehicle/Gate entry date at BHEL Stores (Against submission of GST invoice, GeM invoice, LR copy, Last Movement e-Way Bill & subjected to Material acceptance by BHEL) <p>Note: In case of MSME, the supplier should upload UDYAM Registration Certificate in proof of their MSME Status.</p>
6.	<p>Liquidated Damages: LD terms shall be as per GeM General Terms and Conditions. Note: Vehicle/Gate entry date at consignee location will be considered for LD calculation (i.e. LD will be calculated for the Period from Contract delivery due date to date of Vehicle/Gate entry date at BHEL Stores).</p>
7.	<p>Delivery term: The quote shall be on FOR BHEL STORES (Consignee address) basis inclusive of Packing, forwarding, Freight also to yours account. Transit Insurance is under Supplier scope.</p>
8.	<p>If Guarantee / Warranty period is applicable as per tender specification, No deviation is permitted and deviated offers are liable for rejection.</p>
9.	<p>Repair & replacements: Within the guarantee period vendor has to replace / rectify the defective/damaged items on free of cost within a reasonable time of reporting from our end.</p>
10.	<p>Documents to be submitted</p>

	<p>01. Duly Filled, signed and stamped Annexure – A (Additional Terms and Conditions for GeM Enquiry), Annexure-B (Pre-Qualification Criteria) and Specification document along with supporting documents. Annexure A and B are available along with Specification document.</p> <p>02. Documents required as per technical specification</p> <p>03. Product Catalogues (if any).</p> <p>04. MSME UDYAM Certificate (if applicable).</p> <p>05. If MII Purchase Preference is applicable as per the GeM enquiry, Self-certification for local content declaration as per Make In India Policy, bidder shall submit Local content certificate with details of minimum local content percentage and Location at which the local value addition is made.</p> <p>Note: All the pages of documents are to be signed and sealed by authorized signatory of the company. Any query during enquiry stage shall be replied within two days failing which offer may be rejected as non-responsive.</p>
11.	<p>Inspection and testing requirements:</p> <p>Inspection and testing requirements are to be carried out as per the specification and BHEL Technical specifications in the enquiry. If applicable all test certificates are to be submitted while supply. If required by BHEL, test certificates to be produced before supply.</p>
12.	<p>PACKING AND MARKING:</p> <p>The supplier shall arrange for securely protecting and packing the stores to avoid loss or damages during transit. (Wherever if applicable).Also, Supplier to comply for packing & marking as per Technical specification.</p>
13.	<p>Response to Tenders for Indigenous supplier will be entertained only if the vendor has a valid GST registration Number (GSTIN) which should be clearly mentioned in the offer. If the dealer is exempted from GST registration, a declaration with due supporting documents need to be furnished for considering the offer. Dealers under composition scheme should declare that he is a composition dealer supported by the screen shot taken from GSTN portal. The dealer has to submit necessary documents if there is any change in status under GST.</p>
14.	<p>Supplier shall mention their GSTIN in all their invoices (incl. credit Notes, Debit Notes) and invoices shall be in the format as specified/prescribed under GST laws. Invoices shall necessarily contain Invoice number (in case of multiple numbering system is being followed for billing like SAP invoice no, commercial invoice no etc., then the Invoice No. which is linked/uploaded in GSTN network shall be clearly indicated), Billed to party (with GSTIN) & Shipped to party details, item description as per PO, Quantity, Rate, Value, applicable taxes with nomenclature (like IGST, SGST, CGST & UTGST) separately, HSN/ SAC Code, Place of Supply etc. Wherever E-Invoice is applicable, the tax invoice/ CN / DN submitted by the vendor must contain the QR code generated in E-Invoice Portal & IRN.</p>
15.	<p>All invoices shall bear the HSN Code for each item separately (Harmonized System of Nomenclature)/ SAC code (Services Accounting Code).</p>
16.	<p>Invoices will be processed only upon completion of statutory requirement and further subject to following:</p> <ul style="list-style-type: none"> • Vendor declaring such invoice in their GSTR-1 Return/ IFF • Receipt of Goods or Services and Tax invoice by BHEL.
17.	<p>As the continuous uploading of tax invoices in GSTN portal (in GSTR-1/ IFF) is available for all (i.e. both Small & Large) tax payers, all invoices raised on BHEL may be uploaded immediately in GST portal on dispatch of material /rendering of services. The supplier shall ensure availability of Invoice in GSTN portal before submission of invoice to BHEL. Invoices will be admitted by BHEL only if the invoices are available in GSTN portal (in BHEL's GSTR-2A/ GSTR-2B).</p>
18.	<p>In case of discrepancy in the data uploaded by the supplier in the GSTN portal or in case of any shortages or rejection in the supply, then BHEL will not be able to avail the tax credit and will notify the supplier of the same. Supplier has to rectify the data discrepancy in the GSTN portal or issue credit note or debit note (details also to be uploaded in GSTN portal) for the shortages or rejections in the supplies or additional claims, within the calendar month informed by BHEL.</p>
19.	<p>In cases where invoice details have been uploaded by the vendor but failed to remit the GST amount to GST Department (Form PMT-08 or Form GST RET-01 to be submitted) within stipulated time, then GST paid on the invoices pertaining to the month for which GST return not filed by the</p>

	vendor will be recovered from the vendor along with the applicable interest (currently 24% p.a) and all subsequent bills of the vendor will not be processed till filing of the GST return by the vendor
20.	In case GST credit is denied to BHEL due to non-receipt or delayed receipt of goods and/ or tax invoice or expiry of timeline prescribed in GST law for availing such ITC, or any other reasons not attributable to BHEL, GST amount claimed in the invoice shall be disallowed to the vendor.
21.	Where any GST liability arising on BHEL under Reverse Charge (RCM), the vendor has to submit the invoices to BHEL well within the timeline prescribed in GST Law, to enable BHEL to discharge the GST liability. If there is a delay in submission of invoice by the vendor resulting in delayed payment of GST by BHEL along with Interest, then such Interest payable or paid shall be recovered from the vendor.
22.	GST TDS will be deducted as per Section 51 of CGST Act 2017 and in line with Notification 50/2018 –Central Tax dated 13.09.2018. GST TDS certificate will be generated in GSTN portal subsequent to vendor accepting the TDS deduction in the GSTN portal & the vendor can directly download the Certificate from the GSTN Portal.
23.	<p>As per the provisions of Section 194Q of the Income Tax Act, we BHARAT HEAVY ELECTRICALS LIMITED, HPBP, TRICHY having PAN AAACB4146P, had turnover in the preceding financial year for more than Rs 10 Crores.</p> <p>Hence, we are liable as buyer to deduct tax at source on the payment for invoices issued by Supplier on or after 1st July 2021. Accordingly, discontinue charging TCS u/s 206C(1H) on invoices issued from 1st Jul 2021 onward.</p> <p>We shall deduct the eligible TDS u/s 194Q on the payments for invoices issued on or after 1st Jul 2021. TDS deducted so, shall be deposited to the Income Tax Department, and TDS certificate to this effect. Tax credit of such TDS shall reflect in FORM26AS of the supplier at the end of same quarter in which TDS is deducted.</p> <p>For Suppliers who have not filed Income Tax returns for the last 2 preceding assessment years, TDS deduction at higher rates will be applicable as per Section 206AB and Section 206CCA of Income-tax act.</p>
24.	BHEL will be deducting TDS u/s 194Q TDS. Hence TCS shall not be claimed in Supplier's Invoice.
25.	GST CREDIT: Suppliers are advised to get registered to GSTN portal. Tenderer under "GST credit" shall be preferred.
26.	Any change in applicable rates of Tax or any other statutory levies (Direct / Indirect) or any new introduction of any levy by means of statute and its corresponding liability for the deliveries beyond the agreed delivery date for reasons not attributable to BHEL will be to vendors account. BHEL will not reimburse the same and any subsequent claim in this respect will be summarily rejected.
27.	<p>MSE /START-UP VENDOR:</p> <p>UDYAM Registration certificate shall be submitted by MSE vendors to avail MSE benefits. Start-up category certificate shall be submitted by start-up companies to avail exemption (if applicable as per GeM enquiry) in Annual Turnover/Past experience (if PQC stipulates requirement of Annual Turnover/Past experience).</p>
28.	<p>Make in India Policy:</p> <p>Refer the Tender document regarding public procurement policy (Preference to Make in India), Order 2017. If MII Purchase Preference is applicable as per the tender documents, Bidders shall ensure to apply for Make In India preference while quoting through GeM portal. Otherwise offer will not be considered.</p> <p>The local supplier at the time of tender, bidding or solicitation shall be required to provide self-certification that the item offered meets the minimum local content and shall give details of the Location(s) at which the local value addition is made."</p>

29.	<p>Fraud Prevention Policy</p> <p>Bidder along with its associate /collaborators /sub-contractors /sub-vendors / consultants / service providers shall strictly adhere to BHEL Fraud Prevention Policy displayed on BHEL website http://www.bhel.com and shall immediately bring to the notice of BHEL Management about any fraud or suspected fraud as soon as it comes to their notice.</p>
30.	<p>Breach of contract, Remedies and Termination:</p> <p>In case of breach of contract, wherever the value of security instruments like performance bank guarantee available with BHEL against the said contract is 10% of the contract value or more, such security instruments to the extent of 10% contract value will be encashed. In case no security instruments are available or the value of the security instruments available is less than 10% of the contract value, the 10% of the contract value or the balance amount, as the case may be, will be recovered in all or any of the following manners:</p> <p>a. from dues available in the form of Bills payable to defaulted supplier against the same contract.</p> <p>b. from the dues payable to defaulted supplier against other contracts in the same Region/Unit /any other region/unit</p> <p>c. In-case recoveries are not possible with any of the above available options, Legal action shall be initiated for recovery against defaulted supplier.</p> <p>Further, levy of liquidated damages, debarment, termination, de-scoping, short-closure, etc., will be applied as per provisions of the contract</p>
31.	<p>CONFLICT OF INTEREST:</p> <p>A bidder shall not have conflict of interest with other bidders. Such conflict of interest can lead to anti-competitive practices to the detriment of Procuring Entity's interests. The bidder found to have a conflict of interest shall be disqualified. A bidder may be considered to have a conflict of interest with one or more parties in this bidding process, if:</p> <p>a) they have controlling partner (s) in common; or</p> <p>b) they receive or have received any direct or indirect subsidy financial stake from any of them; or</p> <p>c) they have the same legal representative/agent for purposes of this bid; or</p> <p>d) they have relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another Bidder; or</p> <p>e) Bidder participates in more than one bid in this bidding process, Participation by a Bidder in more than one Bid will result in the disqualification of all bids in which the parties are involved. However, this does not limit the inclusion of the components/ sub-assembly/ Assemblies from one bidding manufacturer in more than one bid: or</p> <p>f) In cases of agents quoting in offshore procurements, on behalf of their principal manufacturers, one agent cannot represent two manufacturers or quote on their behalf in a particular tender enquiry. One manufacturer can also authorise only one agent/dealer. There can be only one bid from the following:</p> <ol style="list-style-type: none"> 1. The principal manufacturer directly or through one Indian agent on his behalf; and 2. Indian/foreign agent on behalf of only one principal; <p style="text-align: center;">or</p> <p>g) A Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the contract that is the subject of the Bid, or</p> <p>h) In case of a holding company having more than one independently manufacturing units, or more than one unit having common business ownership/Management, only one unit shall quote. Similar restrictions would apply to closely related sister companies. Bidder must</p>

	proactively declare such sister/common business/ management units in same/similar line of business.
32.	<p>Resolution of Disputes: The Parties agree that if at any time (whether before, during or after the arbitral or judicial proceedings), any Disputes (which term shall mean and include any dispute, difference, question or disagreement arising in connection with construction, meaning, operation, effect, interpretation or breach of the contract/tender which the Parties are unable to settle mutually), arise inter-se the Parties, the same may, be referred by either party to Conciliation to be conducted through Independent Experts Committee to be appointed by competent authority of BHEL from the BHEL Panel of Conciliators.</p> <p>Notes: No serving or a retired employee of BHEL/Administrative Ministry of BHEL shall be included in the BHEL Panel of Conciliators. Any other person(s) can be appointed as Conciliator(s) who is/are mutually agreeable to both the parties from outside the BHEL Panel of Conciliators. The proceedings of Conciliation shall broadly be governed by Part-III of the Arbitration and Conciliation Act 1996 or any statutory modification thereof and as provided in Annexure X to this Terms and conditions. The Annexure X together with its appendices will be treated as if the same is part and parcel hereof and shall be as effectual as if set out herein in this terms and conditions. Except as provided elsewhere in this Contract, in case amicable settlement is not reached between the parties, in respect of any dispute or difference; arising out of the formation, breach, termination, validity or execution of the Contract; or, the respective rights and liabilities of the Parties; or, in relation to interpretation of any provision of the Contract; or, in any manner touching upon the Contract, then, either Party may, by a notice in writing to other Party, refer such dispute or difference to sole arbitration of an arbitrator appointed as per the Arbitration and Conciliation Act, 1996 (India) or statutory modification or re-enactment thereof and the rules made thereunder and for the time being in force. The Arbitrator shall pass a reasoned award and the award of the Arbitrator shall be final and binding upon the parties. This contract shall be governed, construed and interpreted in accordance with the laws of India. Subject as aforesaid, the provisions of Arbitration & Conciliation Act 1996 (India) or statutory modification or re-enactment thereof and the rules made thereunder and for the time being in force shall apply to the arbitration proceeding under this clause. The seat of arbitration shall be Trichy, Tamil Nadu, India The cost of arbitration shall be borne as per the award of the Arbitrator. Subject to arbitration in terms of clause above, the Courts at Trichy, Tamil Nadu, India shall have exclusive jurisdiction over any matter arising out of or in connection with this Contract. Notwithstanding the existence or any dispute or difference and/or reference for the arbitration, the vendor/contractor shall proceed with and continue without hindrance the performance of its obligation under this Contract with due diligence and expedition in a professional manner except where the Contract has been terminated by either Party in terms of this Contract. In Case of Contract with Public Sector Enterprise (PSE) or a Government Department, the following shall be applicable: In the event of any dispute or difference relating to the interpretation and application of the provisions of commercial contract(s) between Central Public Sector Enterprises (CPSEs)/Port Trusts inter se and also between CPSEs and Government Departments/Organizations (Excluding disputes concerning Railways, Income Tax, Customs & Excise Departments, such dispute or difference shall be taken up by either party for its resolution through AMRCD as mentioned in DPE OM No.05/003/2019-FTS-10937 dtd. 14TH December, 2022 and the decision of AMRCD on the said dispute will be binding on both the parties.”</p>
33.	Set off : BHEL shall have the right to recover any money which in the sole opinion of BHEL is due from the supplier from any money due to the supplier under this Contract or any other contract or from the Security Deposit/BG furnished by the supplier under this Contract or any other contract.

34.	<p>Cartel Formation:</p> <p>The Bidder declares that they will not enter into any illegal or undisclosed agreement or understanding, whether formal or informal with other Bidder(s). This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process. In case, the Bidder is found having indulged in above activities, suitable action shall be taken by BHEL as per extant policies/ guidelines.</p>
35.	<p>The offers of the bidders who are under suspension and also the offers of the bidders, who engage the services of the banned firms /principal/agents, shall be rejected. The list of banned firms is available on BHEL web site www.bhel.com</p>
36.	<p>The following documents are to be sent along with consignment to store: One Original for Recipient copy of tax invoice + One Duplicate for Transporter copy of tax invoice + One extra copy of tax invoice + Delivery challan + LR COPY+E-Way bill (Part A & Part B)+ Test Certificates (if applicable).</p>
37.	<p>Seller Tax invoice, LR copy, E-Way bill, Courier docket etc. are to be uploaded in GeM portal while updating dispatch details in GeM portal</p>
38.	<p>Seller Tax invoices (Original for Recipient + Duplicate for Transporter) either in Original hard copies or Digitally Signed Soft copies along with copy of LR/Courier docket + Part B of E-Way bill are to be sent to the buyer for bill processing</p>
39.	<p>Bidder financial standing: The bidder should not be under liquidation, court receivership or similar proceedings, should not be bankrupt. Bidder to upload undertaking to this effect with bid.</p>
40.	<p>Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.</p>
41.	<p>Any other conditions which might have been quoted by the seller and are in contravention to the terms prescribed in the Enquiry documents and which have not been specifically accepted in by purchaser will not be applicable to the contract.</p>
42.	<p>Without prejudice to Buyer's right to price adjustment by way of discount or any other right or remedy available to Buyer, Buyer may terminate the Contract or any part thereof by a written notice to the Seller, if:</p> <ul style="list-style-type: none"> The Seller fails to comply with any material term of the Contract. The Seller informs Buyer of its inability to deliver the Material(s) or any part thereof within the stipulated Delivery Period or such inability otherwise becomes apparent. The Seller fails to deliver the Material(s) or any part thereof within the stipulated Delivery Period and/or to replace/rectify any rejected or defective Material(s) promptly. The Seller becomes bankrupt or goes into liquidation. The Seller makes a general assignment for the benefit of creditors. A receiver is appointed for any substantial property owned by the Seller. The Seller has misrepresented to Buyer, acting on which misrepresentation Buyer has placed the Purchase Order on the Seller.
43.	<p>BHEL may negotiate the L1 rate, if not meeting our budget / estimated cost. BHEL may re-float the tender opened, if L1 price is not acceptable to BHEL.</p>
44.	<p>In case of any queries before bid submission, the supplier may reach us at the mail id govindaraj@bhel.in</p>