

 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION</b> <b>FOR</b> <b>ELECTRICAL WORKSHOP ITEMS</b> (under warranty)	<b>SPECIFICATION NO.</b> <b>EM-8893-99-EWS-GTS-3</b>	
		Rev. No	00
	<b>(4 X 40 MW) TEESTA IV HEP</b>	Rev Date	06/07/2021


**GENERAL TECHNICAL SPECIFICATIONS**

 M. D. Mushtaq Dy Engineer	 Shiwani Gupta Manager
<b>PREPARED BY</b>	<b>CHECKED &amp; APPROVED BY</b>

 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION  FOR  ELECTRICAL WORKSHOP ITEMS  (under warranty)</b>	<b>SPECIFICATION NO.  EM-8893-99-EWS-GTS-3</b>	
		Rev. No	00
	<b>(4 X 40 MW) TEESTA IV HEP</b>	Rev Date	06/07/2021

### SECTION 1 – SCOPE OF ENQUIRY

1. This Specification covers the design, manufacture, inspection and testing at vendor's work, proper packing and delivery as per Particular Technical Specification (annex III) for Electrical Workshop equipment of **(4 X 40 MW) Teesta IV HEP**.
2. It is not intent to specify herein all the details of design and manufacture. However, the equipment shall conform in all respect to high standards of design engineering and workmanship and shall be capable of performing in continuous commercial operation up to vendors guarantee.
3. The general terms and conditions, instructions to tender and other attachment referred to elsewhere be hereby made part of the tender specification.
4. The tenderer shall be responsible for and governed by all requirements stipulated herein after.
5. **Deviation**, if any should be brought out very clearly on deviation sheet of Specific Technical specifications (Schedule of Technical Deviation- Annexure II). Otherwise it would be presumed that the tender offer is in line with what has been stated / asked for in specifications.
6. The offer should be complete with technical data, catalogue, brochures and drawings, as applicable.
7. The bid shall be in English language and MKS system of unit.

 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION FOR ELECTRICAL WORKSHOP ITEMS (under warranty)</b>	<b>SPECIFICATION NO. EM-8893-99-EWS-GTS-3</b>	
	<b>(4 X 40 MW) TEESTA IV HEP</b>	Rev. No	00
		Rev Date	06/07/2021

## SECTION 2 – General Conditions

### 1. SCOPE OF SUPPLY

The scope of supply indicating technical specification & Bill of quantity shall be as per Particular Technical specification (Details of Equipment's annexure - III) along with all essential accessories required for the successful operation of the equipment's.

#### Details of Equipment:

SL NO.	ITEM/ TECHNICAL DETAILS	Approved Make:
1	Analog Multimeter for AC & DC (portable), DC/AC voltage – 60mV-1000V DC/AC current- 1.5mA-30A Resistance- 0 to 50 kW	Make/ Model: Simpson / 260-8P; Megger / 8 mk7

### 2. CODES AND STANDARDS

All relevant National and International standards shall be specified and followed.

### 3. DESIGN CRITERIA

- 3.a. Workshop Equipment shall be used for testing various electrical equipment/ devices during Commissioning, Operation and Maintenance of plant.
- 3.b. The equipment will be kept in a clean but hot, humid and tropical atmosphere when not in use. Equipment will be placed in dust laden, hot, humid atmosphere during its use.
- 3.c. For continuous operation at specified rating, temperature rise of various equipment/ components shall be limited to the permissible value stipulated in the relevant standards and this specification.
- 3.d. The equipment and component thereof shall be capable of withstanding the mechanical forces and thermal stresses of the short circuit current without any damage and deterioration of material.

### 4. SPECIFIC REQUIREMENTS & RATINGS

- 4.a. The bidder may note that the equipment ranges, ratings, quantities as detailed herein, are the minimum requirement only. The equipment shall be furnished in strict accordance with the same. All accessories for the equipment not covered here, but are necessary for satisfactory and trouble free operation of the equipment, shall be supplied by the Bidder. Bidder may also quote for optional accessories.
- 4.b. Equipment shall be complete with applicable accessories like power supply main leads, screened guard leads, screened line test leads, earth leads, connectors and clips, leather carrying case and any other accessories required for completing the equipment.

 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION FOR ELECTRICAL WORKSHOP ITEMS (under warranty)</b>	<b>SPECIFICATION NO. EM-8893-99-EWS-GTS-3</b>	
	<b>(4 X 40 MW) TEESTA IV HEP</b>	Rev. No	00
		Rev Date	06/07/2021

4.c. The Equipment shall be designed suitably for satisfactory operation and storage in wide range of temperature variations prevailing at projects sites:

Teesta IV: 8°C to 37°C.

4.d. The portable Equipment shall be suitable for hand held operation, rugged in construction and suitable for field use.

4.e. Power supply for AC operation Equipment shall be 240 V AC, 50 Hz single phase.

4.f. All Equipment shall be dust and moisture proof.

4.g. Calibration tests shall be done on all Equipment, wherever applicable and calibration certificates are to be furnished with Equipment.

4.h. Equipment shall be of shock proof.

4.i. Equipment shall meet National or International relevant safety standards.

4.j. Manufacturers name plate:

The following data shall be shown in accordance with the relevant standard

- Manufacturers name and address
- Works serial number and date of manufacture
- Main technical data

4.k. Warning Plates:

Warning plates / caution for the safety of Equipment & human beings with Dos and Don'ts to be inscribed on the Equipment / Recorders / all electrical equipment in English.

## 5. ERECTION & COMMISSIONING

Erection & Commissioning of supplied item is in vendor's scope, at site.


## 6. TESTING & INSPECTION

6.a. The manufacturer shall carry out all acceptance and routine tests as per relevant standards and specification in line with BHEL specifications. Charges for all these routine and acceptance tests and calibration for all the Equipment shall deem to be included in the bid price.

6.b. Equipment shall be completely assembled, wired, adjusted and tested in factory as per the latest edition of relevant standards.

6.c. The Bidder shall submit the Test Certificates/Reports for all the acceptance and routine tests as per relevant standards, specifications and in line BHEL approval. Based on approved Test Certificates/ Reports, the BHEL will give the dispatch clearance. Only after clearance vendor can dispatch the material.

6.d. Bidder shall also submit the Test Certificates for all the acceptance and routine tests as per relevant standards, specifications along with the equipment as per TABLE-2, Annexure - I.

 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION FOR ELECTRICAL WORKSHOP ITEMS (under warranty)</b>	<b>SPECIFICATION NO. EM-8893-99-EWS-GTS-3</b>	
	<b>(4 X 40 MW) TEESTA IV HEP</b>	Rev. No	00
		Rev Date	06/07/2021

## 7. DOCUMENTATION

### 7.a. To be submitted with bid:

The Bidder shall submit all documents as per TABLE-1, Annexure - I along with the bid.

The Bidder shall ensure that the all-necessary information required to fully describe the equipment are submitted with the bid.

### 7.b. To be submitted after award of order:

The Bidder shall submit all documents as per TABLE-2, Annexure - I.

After award of contract for BHEL and/ or end customer approval and also along with equipment.

## 8. DELIVERY

The delivery of Equipment shall be completed as per NIT (Notice Inviting Tender)

### 9. While quoting Bidder shall have to furnish unit rate for each item. Purchaser reserves the rights to add/delete quantity of any item during detailed engineering as finally required for the project. Unit rate quoted shall be applicable for price adjustment in such cases.

### 10. All the equipment shall be procured from reputed manufacturers and make of equipment shall be subjected to the approval of BHEL/ BHEL's Customer.

## 11. PERFORMANCE GUARANTEE

The bidder shall guarantee that the equipment offered shall meet the requirement as stipulated in this specification and as confirmed by them in Particular Technical Specifications (Schedule of Guaranteed Technical Particular-Duly filled in Annexure – IV If Any). In case the performance of equipment is not as per performance guarantee, the bidder will have to replace the equipment at site free of cost.


## 12. DEVIATION

The Bidder shall indicate the deviation, if any, in Specific Technical Specifications (Schedule of Technical Deviation) Annexure II, along with the justification for the deviation. Deviation mentioned anywhere else will not be entertained.

## 13. PACKAGE & CONSIGNMENT DATA

The Bidder shall pack all the equipment, their accessories and spares in road -worthy package. Bidder to indicate the number of packages of consignment together with the size (L x W x H) and weight for transporting the equipment along with their bid. Vendor has to submit packing list and other documents as per TABLE 2, Annexure - I along with items supplied.

Each package shall be legibly marked with the following information:

 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION FOR ELECTRICAL WORKSHOP ITEMS (under warranty)</b>	<b>SPECIFICATION NO. EM-8893-99-EWS-GTS-3</b>	
		<b>Rev. No</b>	<b>00</b>
	<b>(4 X 40 MW) TEESTA IV HEP</b>	<b>Rev Date</b>	<b>06/07/2021</b>

**Applicable for TEESTA HEP:**

ELECTRICAL WORKSHOP EQUIPEMENTS for (4 X 40 MW) Teesta IV – HEP

BHEL Purchase Order No:

Job No:

8893-99W

Supplier's Name:

Manufacturer's Name:

Name of the Equipment:

Quantity:

Weight:

Annexure -I

**Table 1**

**LIST OF DOCUMENTS TO BE SUBMITTED ALONG WITH BID**


SI.No	Documents	No of copies
1	Annexure – III Details of Equipment (Duly Filled)	2 copies
2	Product Catalogue for all equipment/ Equipment referred in Specific Technical specifications (Details of Equipment's)	2 copies
3	Schedule of Deviation referred in Specific Technical Specifications - Annexure -I I Schedule of Technical Deviation	2 copies

**NOTE:** All above documents to be submitted strictly, failing which the offer may likely be rejected.

**Table 2**

**LIST OF DOCUMENTS TO BE SUBMITTED AFTER AWARD OF ORDER FOR BHEL / END CUSTOMER APPROVAL and ALONG WITH EQUIPMENT**

SI.No	Documents	No of copies
1	Product catalog with complete specifications, model nos. physical dimensions etc.	3 copies (2 for CUSTOMER + 1 for BHEL)
2	Test Certificates of all acceptance and routine tests (as applicable for equipment).	3 copies (2 for CUSTOMER + 1 for BHEL)
3	Calibration certificates as applicable.	3 copies (2 for CUSTOMER + 1 for BHEL)
4	Guarantee certificate as per NIT	2 copies (1 for CUSTOMER + 1 for BHEL)
5	Instruction manual of individual equipment	7 copies (6 for CUSTOMER + 1 for BHEL)

 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION</b> <b>FOR</b> <b>ELECTRICAL WORKSHOP ITEMS</b> (under warranty)	<b>SPECIFICATION NO.</b> <b>EM-8893-99-EWS-GTS-3</b>	
	<b>(4 X 40 MW) TEESTA IV HEP</b>	Rev. No	00
		Rev Date	06/07/2021

	Instruction manual of individual equipment shall clearly indicate in English the installation and connection method. Operating, Maintenance and Calibration methods shall be provided in the manual.	1 for BHEL)
6	OGA diagram, Line diagram, Foundation diagram, any relevant document/diagram, necessary for Erection and commissioning at site	7 copies (6 for CUSTOMER + 1 for BHEL)

**Annexure – II**

**Schedule of Technical Deviation**

Sr No.	Item	Deviation	Justification for Deviation

**Use extra sheet if required.**

**Note:** Bidder has to indicate clearly the deviations if any w.r.t. specification. Bidder has to indicate all the deviations on this annexure – II only, deviations mentioned elsewhere in Bidder's offer will not be considered.