


 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR MECHANICAL WORKSHOP		SPECIFICATION NO. EM-RAMM-MWS-PTS-05
	3 X 40 MW RAMMAM STAGE-III HEP, NTPC		Rev. No 00
			Rev Date 18/02/2025

PARTICULAR TECHNICAL SPECIFICATIONS

Bahuman pawar	Shiwani Gupta
PREPARED BY	CHECKED & APPROVED BY

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR MECHANICAL WORKSHOP		SPECIFICATION NO. EM-RAMM-MWS-PTS-05	
	3 X 40 MW RAMMAM STAGE-III HEP, NTPC		Rev. No	00
			Rev Date	18/02/2025

Annexure I


Details of Equipments

Bidder must quote the material code number, material description & quantity offered in their quotation /bid, as specified below. Bidder's alternate description can also be given in separate column.

Completeness of Equipment


Each of the equipment listed shall be complete with applicable accessories like power supply main leads, screened guard leads, screened line test leads, earth leads, connectors and clips, leather carrying case, fastners/washers/nuts/anchoring bolts/etc required for erection and commissioning and any other accessories required for completing the equipment.

Sl. No	Item specification	Qty	Approved Make	Catalogue No
1	<p>HYDRAULIC TRANSVERSE JACK (CAPACITY 5, 10 & 25 TONNES)</p> <p>(i) The jacks shall be robust and simple in construction, manufactured with stringent quality control measures at every stage of production and in accordance with acceptable standards. The body, piston, pumps and all other accessories shall be conforming to standard mark and design. All the accessories shall be in the scope of supply. The equipment shall be complete in all respects.</p> <p>(ii) The body of the jacks containing the hydraulic oil shall be as per the IS standards and shall be able to withstand the pressure and load upto the marked capacity. The steel used shall be of good quality and high performance during loading condition. A suitable size handle shall be fixed on the body for handling the jack.</p> <p>(iii) The piston operating head shall be suitably hinged to the base of the jack body and shall give friction free movement to the piston meant for pressing the oil from the jack sump. The locking arrangement shall ensure the non-return of the jack screw during loading conditions.</p>	1 No. each	HMC, Sun-Run, Atlas, V-TECH Power Hydraulic, Gemini power hydraulics, Aeco, VANKOS & COMPANY / BHEL approved vendor	

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR MECHANICAL WORKSHOP		SPECIFICATION NO. EM-RAMM-MWS-PTS-05
	3 X 40 MW RAMMAM STAGE-III HEP, NTPC		Rev. No 00
			Rev Date 18/02/2025

	<p>(iv) The operating rod of standard length made of drop forged steel with proper hand ripping cross cuts at one end, shall be supplied along with the jacks.</p> <p>(v) The top of the jack shall be suitably flame hardened and shall ensure no chipping with the shift operation of the equipment.</p> <p>The technical requirements are as follow:</p> <table border="1" data-bbox="321 630 954 856"> <thead> <tr> <th>Capacity</th><th>Height</th><th>Lift</th><th>Transverse</th><th>No. of unit</th></tr> </thead> <tbody> <tr> <td>5 T</td><td>500 mm</td><td>250 mm</td><td>250 mm</td><td>1 No.</td></tr> <tr> <td>10 T</td><td>500 mm</td><td>250 mm</td><td>250 mm</td><td>1 No.</td></tr> <tr> <td>25 T</td><td>650 mm</td><td>300 mm</td><td>400 mm</td><td>1 No.</td></tr> </tbody> </table>	Capacity	Height	Lift	Transverse	No. of unit	5 T	500 mm	250 mm	250 mm	1 No.	10 T	500 mm	250 mm	250 mm	1 No.	25 T	650 mm	300 mm	400 mm	1 No.			
Capacity	Height	Lift	Transverse	No. of unit																				
5 T	500 mm	250 mm	250 mm	1 No.																				
10 T	500 mm	250 mm	250 mm	1 No.																				
25 T	650 mm	300 mm	400 mm	1 No.																				

(To be ticked/filled by bidder, relevant catalogues to be provided with offer)**

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR MECHANICAL WORKSHOP		SPECIFICATION NO. EM-RAMM-MWS-PTS-05
	3 X 40 MW RAMMAM STAGE-III HEP, NTPC		Rev. No 00
			Rev Date 18/02/2025

Annexure II

SCHEDULE OF GUARANTEED TECHNICAL PARTICULARS

(Bids are liable to be rejected if the Bidder does not furnish the technical data in the schedule given below)

SL. NO	Description	To be filled by the Bidders
1	HYDRAULIC TRANSVERSE JACK (CAPACITY 5 TON)	
1	Name of manufacture	
2	Type, Model, year of manufacturing	
3	Standard to which confirm	
4	Capacity	
5	Height	
6	Lift	
7	Transverse	
8	Gross weight	

SL. NO	Description	To be filled by the Bidders
2	HYDRAULIC TRANSVERSE JACK (CAPACITY 10 TON)	
1	Name of manufacture	
2	Type, Model, year of manufacturing	
3	Standard to which confirm	
4	Capacity	
5	Height	
6	Lift	
7	Transverse	
8	Gross weight	

SL. NO	Description	To be filled by the Bidders
3	HYDRAULIC TRANSVERSE JACK (CAPACITY 25 TON)	
1	Name of manufacture	
2	Type, Model, year of manufacturing	
3	Standard to which confirm	
4	Capacity	
5	Height	
6	Lift	
7	Transverse	
8	Gross weight	

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR MECHANICAL WORKSHOP		SPECIFICATION NO. EM-RAMM-MWS-PTS-05
	3 X 40 MW RAMMAM STAGE-III HEP, NTPC		Rev. No 00
			Rev Date 18/02/2025


Annexure III

Deviation Statement (Technical)



Sr No.	Item	Deviation	Justification for Deviation

Use extra sheet if required.

Note: Bidder has to indicate clearly the deviations if any w.r.t. specification. Bidder has to indicate all the deviations on this annexure – III only, deviations mentioned elsewhere in Bidder's offer will not be considered.

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP	SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
		Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP	Date	30/01/2025


GENERAL TECHNICAL SPECIFICATIONS

 Sachin Lonkar	 Shiwani Gupta
PREPARED BY	APPROVED BY

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP	SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
		Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP	Date	30/01/2025

SECTION 1 – SCOPE OF ENQUIRY

1. This Specification covers the design, manufacture, inspection and testing at vendors work, if required, proper packing and delivery to site of MECHANICAL WORKSHOP EQUIPMENTS as mentioned in different sections of this specification for **3 x 40 MW RAMMAM STAGE-III HEP**
2. It is not intent to specify herein all the details of design and manufacture. However the equipment shall conform in all respect to high standards of design engineering and workmanship and shall be capable of performing in continuous commercial operation up to vendors guarantee.
3. The general terms and conditions, instructions to tender and other attachment referred to elsewhere be hereby made part of the tender specification.
4. The tenderer shall be responsible for and governed by all requirements stipulated herein after.
5. **Deviation**, if any should be brought out very clearly on deviation sheet Annex-II. Otherwise it would be presumed that the tender offer is in line with what has been stated/asked for in this specification.
6. The offer should be complete with technical data, catalogue, brochures and drawings, as applicable.
7. The bid shall be in English language and MKS system of unit.

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP		SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
			Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP		Date	30/01/2025

SECTION 2 – GENERAL CONDITIONS

1. SCOPE OF SUPPLY

The scope of supply shall be as per enquiry along with all essential accessories required for the successful operation of the equipment.

2. CODES AND STANDARDS


All relevant National and International standards shall be specified and followed.

3. DESIGN CRITERIA

- 3.a. Mechanical Workshop Equipment shall be used for testing various mechanical equipment/ devices during Commissioning, Operation and Maintenance of plant.
- 3.b. The equipment will be kept in a clean but hot, humid and tropical atmosphere when not in use. Equipment will be placed in dust laden, hot, humid atmosphere during its use.
- 3.c. For continuous operation at specified rating, temperature rise of various equipment/ components shall be limited to the permissible value stipulated in the relevant standards and this specification.
- 3.d. The equipment and component thereof shall be capable of withstanding the mechanical forces and thermal stresses of the short circuit current without any damage and deterioration of material.

4. SPECIFIC REQUIREMENTS & RATINGS


- 4.a. The bidder may note that the equipment ranges, ratings, quantities as detailed herein, are the minimum requirement only. The equipment shall be furnished in strict accordance with the same. All accessories for the equipment not covered here, but are necessary for satisfactory and trouble free operation of the equipment, shall be supplied by the Bidder. Bidder may also quote for optional accessories.
- 4.b. The instrument shall be designed suitably for satisfactory operation and storage in wide range of temperature variations prevailing at projects sites.
- 4.c. Analog instruments shall be provided with knife-edge pointer and anti-parallax mirror.
- 4.d. Instrument/meters suitable for DC supply should be provided with re-chargeable batteries, charger and low battery charge indication.
- 4.e. The portable instruments shall be suitable for hand held operation, rugged in construction and suitable for field use.

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP	SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
		Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP	Date	30/01/2025

- 4.f. Power supply for AC operation Instrument shall be 240 V AC, 50 Hz.
- 4.g. All mechanical instruments shall be dust and moisture proof.
- 4.h. Calibration tests shall be done on all instruments, wherever applicable and calibration certificates are to be furnished with instruments.
- 4.i. Equipments shall be of shock proof.
- 4.j. Instruments shall meet National or International relevant safety standards.
- 4.k. Manufacturers name plate:
The following data shall be shown in accordance with the relevant standard
- Manufacturers name and address
 - Works serial number and date of manufacture
 - Main technical data
- 4.l. Warning Plates:
Warning plates / caution for the safety of instrument & human beings with Dos and Don'ts to be inscribed on the instruments / Recorders / all electrical equipment in English.

5. TESTING & INSPECTION

- 5.a. The QAP shall be finally approved by BHEL /customer and the same shall be applicable for testing & inspection requirement, without any cost implication.
- 5.b. The manufacturer shall carry out all acceptance and routine tests as per relevant standards and specification in line with BHEL /customer approved QAP. Charges for all these routine and acceptance tests for all the equipments shall deem to be included in the bid price. Additional Charges shall not be applicable/paid in lieu of QAP Approval at later stage.
- 5.c. Equipment shall be completely assembled, wired, adjusted and tested in factory as per the latest edition of relevant standards.
- 5.d. The Bidder shall submit the Test Certificates/Reports for all the acceptance and routine tests as per relevant standards, specifications and in line with QAP for BHEL /customer approval. Based on approved Test Certificates/ Reports, the customer will issue the Material Dispatch Clearance Certificates (MDCCs). Only after receipt of MDCC, vendor can dispatch the material.
- 5.e. Bidder shall also submit the Test Certificates for all the acceptance and routine tests as per relevant standards, specifications along with the equipment as per TABLE-2.

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP	SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
		Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP	Date	30/01/2025

6. DOCUMENTATION

6.a. To be submitted with bid:

The Bidder shall submit all documents as per TABLE-1, along with the bid.

The Bidder shall ensure that the all-necessary information required to fully describe the equipment are submitted with the bid.

6.b. To be submitted after award of order:

The Bidder shall submit all documents as per TABLE-2.

After award of contract for BHEL and/ or end customer approval and also along with equipment.

7. DELIVERY

The delivery of Equipment shall be completed as per NIT (Notice Inviting Tender)

8. While quoting Bidder shall have to furnish unit rate for each item. Purchaser reserves the rights to add/delete quantity of any item during detailed engineering as finally required for the project. Unit rate quoted shall be applicable for price adjustment in such cases.

9. All the equipment shall be procured from reputed manufacturers and make of equipment shall be subjected to the approval of BHEL/ BHEL's Customer.

10. DEMONSTRATION/INSTALLATION & HANDING OVER TO BHEL / CUSTOMER


The bidder shall be responsible for demonstration/Installation of the supplied equipment at site to BHEL / BHEL's customer and ensure handing over the same to the satisfaction of BHEL / BHEL's customer.

11. PERFORMANCE GUARANTEE

The bidder shall guarantee that the equipment offered shall meet the requirement as stipulated in this specification. In case the performance of equipment is not as per performance guarantee, the bidder will have to replace the equipment at site free of cost.

12. DEVIATION

The Bidder shall indicate the deviation, if any, in Schedule of Technical Deviation as per Annexure - II, along with the justification for the deviation.

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP	SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
		Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP	Date	30/01/2025

13. PACKAGE & CONSIGNMENT DATA

The Bidder shall pack all the equipment, their accessories and spares in road -worthy package. Bidder to indicate the number of packages of consignment together with the size (L x W x H) and weight for transporting the equipment along with their bid.

Each package shall be legibly marked with the following information:

1. Tools and plant for 3 x 40 MW RAMMAM STAGE-III HEP

BHEL Purchase Order No:

Supplier's Name:

Manufacturer's Name:

Name of the Equipment:

Item Code of the equipment:

Quantity:

Weight:


 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP	SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
		Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP	Date	30/01/2025

Table-1

LIST OF DOCUMENTS TO BE SUBMITTED ALONG WITH BID:


Sl.No	Documents	No of copies
1	Details of Equipments as per Specific technical Specifications (Duly Filled)	2 copies
2	Product Catalogue for all equipments/ instruments referred in Specific technical Specifications	2 copies
3	Schedule of Deviation as per Annexure - II	2 copies

NOTE: All above documents to be submitted strictly, failing which the offer may likely be rejected.

Table-2

LIST OF DOCUMENTS TO BE SUBMITTED AFTER AWARD OF ORDER FOR BHEL / END CUSTOMER APPROVAL & ALONG WITH EQUIPMENT:

Sl.No	Documents	No of copies
1	Product catalog with complete specifications, model nos. physical dimensions etc.	3 copies (2 for customer + 1 for BHEL)
2	Quality Assurance Plan along with test certificates and calibration certificates for MDCCs	4 copies (3 for customer + 1 for BHEL)
3	Test Certificates of all acceptance and routine tests as applicable.	3 copies (2 for customer + 1 for BHEL)
4	Calibration certificates as applicable.	3 copies (2 for customer + 1 for BHEL)
5	Guarantee certificate as per NIT.	2 copies (1 for customer + 1 for BHEL)
6	Instruction manual of individual equipment Instruction manual of individual equipment shall clearly indicate in English the installation and connection method. Operating, Maintenance and Calibration methods shall be provided in the manual.	7 copies (6 for customer + 1 for BHEL)

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP	SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
		Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP	Date	30/01/2025


Annexure – II

Schedule of Technical Deviation

Sr No.	Item	Deviation	Justification for Deviation

Use extra sheet if required.

Note: Bidder has to indicate clearly the deviations if any w.r.t. specification. Bidder has to indicate all the deviations on this annexure – II only, deviations mentioned elsewhere in Bidder's offer will not be considered.

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-I FOR MECHANICAL WORKSHOP	SPECIFICATION NO. EM-RAMMAM-MWS-GTS-00	
		Rev. No	00
	3 x 40 MW RAMMAM STAGE-III HEP	Date	30/01/2025

Spare Parts III-A

Following spare items shall be supplied along with items (as applicable)

Sl No	Description	Quantity
1	Indicating Lamp (each used type)	2 Nos
2	Fuses (each used type)	5 Nos
3	Plugs and Sockets (each used type)	4 Nos
4	Belts (each used type)	5 Nos