


 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION PART-II</b> <b>FOR</b> <b>ELECTRICAL WORKSHOP EQUIPMENTS</b> <b>TESTING DEVICES</b>	<b>SPECIFICATION NO.</b> <b>EM-VYASI-EWS-PTS-04</b>	
		<b>Rev. No.</b>	<b>01</b>
<b>2 x 60 MW VYASI HEP</b>		<b>Date</b>	<b>20.04.22</b>

**PARTICULAR TECHNICAL SPECIFICATIONS**

 Sachin Lonkar	 Shiwani Gupta
<b>PREPARED BY</b>	<b>CHECKED &amp; APPROVED BY</b>

 <b>BHEL-EMRP</b> <b>MUMBAI</b>	<b>TECHNICAL SPECIFICATION PART-II</b> <b>FOR</b> <b>ELECTRICAL WORKSHOP EQUIPMENTS</b> <b>TESTING DEVICES</b>	<b>SPECIFICATION NO.</b> <b>EM-VYASI-EWS-PTS-04</b>	
		<b>Rev. No.</b>	<b>01</b>
	<b>2 x 60 MW VYASI HEP</b>	<b>Date</b>	<b>20.04.22</b>

### (1) Details of Equipments

Bidder must quote the make, model No, material description & quantity offered in their quotation /bid, as specified below. Bidder's alternate description can also be given in separate column.

#### Completeness of Equipment

Each of the equipment listed shall be complete with applicable accessories like power supply main leads, screened guard leads, screened line test leads, earth leads, connectors and clips, leather carrying case and any other accessories required for completing the equipment. Bidder has to mention technical details & quantity of each item under this category along with offer.

Sl. No	Item / Technical Details	Qty	Details of Equipment offered by the Bidder	
			Make	Model & Catalogue No.
1	<b>Automatic Turn ratio tester</b> <ul style="list-style-type: none"> <li>• Operation voltage: 230V, AC 50Hz, 1 ph</li> <li>• Test voltage: 230 V AC</li> <li>• Accuracy: <math>\pm 0.5\%</math> of FSD</li> <li>• humidity: Up to 90%.</li> <li>• Operating temperature: (-)10°C to 50°C</li> </ul>	1 No.	Shivananda, Udeyraj, Tinsley, Megger, Venguard, DV Power OR Any other reputed make	

