




 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR ELECTRICAL WORKSHOP EQUIPMENTS TESTING DEVICES	SPECIFICATION NO. EM-VYASI-EWS-PTS-19	
		Rev. No.	00
2 x 60 MW VYASI HEP		Date	26.11.21

PARTICULAR TECHNICAL SPECIFICATIONS

 Sandesh Patil	 Shiwani Gupta
PREPARED BY	CHECKED & APPROVED BY

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR ELECTRICAL WORKSHOP EQUIPMENTS TESTING DEVICES	SPECIFICATION NO. EM-VYASI-EWS-PTS-19	
		Rev. No.	00
	2 x 60 MW VYASI HEP	Date	26.11.21


(1) Details of Equipments

Bidder must quote the make, model No, material description & quantity offered in their quotation /bid, as specified below. Bidder's alternate description can also be given in separate column.

Completeness of Equipment

Each of the equipment listed shall be complete with applicable accessories like power supply main leads, screened guard leads, screened line test leads, earth leads, connectors and clips, leather carrying case and any other accessories required for completing the equipment. Bidder has to mention technical details & quantity of each item under this category along with offer.

Sl. No	Item / Technical Details	Qty	Details of Equipment offered by the Bidder	
			Make	Model & Catalogue No.
1	High voltage insulation oil testing devices with accessories <ul style="list-style-type: none"> • Test Voltage:0-100 kV AC • Input Voltage:230V AC , 50Hz 	2 Nos.	Udeyraj, Motwane, Sivananda, RE, Ajit OR Any other reputed make.	

 BHEL-EMRP MUMBAI	TECHNICAL SPECIFICATION PART-II FOR ELECTRICAL WORKSHOP EQUIPMENTS TESTING DEVICES	SPECIFICATION NO. EM-VYASI-EWS-PTS-19	
		Rev. No.	00
	2 x 60 MW VYASI HEP	Date	26.11.21

(2) Technical Deviation Statement (if any)

Sr No.	Item	Deviation	Justification for Deviation

Note: Bidder has to indicate clearly the deviations if any w.r.t. specification. Bidder has to indicate all the deviations on this sheet only, deviations mentioned elsewhere in Bidder's offer will not be considered.