



अंतर कार्यालय ज्ञापन / Inter Office Memorandum

प्रेषक/From : Nishant Singh, Sr Engineer, HVDC TBEM	सेवा में/To: Sh Sandeep Kumar Dy. Manager TBMM
संदर्भ/ Ref : CB-SS02-PI - CLAR	
दिनांक/Date: 16-MAR-2020	

Purchase indent no. 06I2000599 & 06I2000600 Rev 0 dtd. 15-FEB-2020

Project : SS02 Fatehgarh II and Bhadla II POWERGRID

Item: 765kV Circuit Breaker

Subject: Clarifications to all bidders

The following clarifications may please be issued to all vendors:


Additional notes in clause 1.2.1

- Following accessories are clarified as bidder's scope of supply*
 - 1.1 Structure for equipment support, ladder and platform etc.*
 - 1.2 Foundation Bolts for circuit breaker, CB ladder, CB Platform, common control cubicle etc.*
 - 1.3 Cable tray arrangement to be mounted on breaker structure.*
 - 1.4 Breaker Terminal Pad*
- Following are not in Bidder's scope of supply (BHEL Supplied Item)*
 - 2.1 Terminal Connectors*
- 3. Special cables (i.e screened/FO Cable, if required) other than 1100V LT Power and control cables required for CB/CSD/Relay Panel Interfacing shall be in Bidder's scope. The trench route length from circuit breaker to CRP is 250m approximately. Total requirement of special cable is to be estimated and supplied by bidder based on the trench route length and no. of runs etc.*
- 4. All wiring necessary for interface of existing CRP with bidder supplied CSD is deemed to be included in the scope of bidder.*


Prepared By: Nishant Singh (Sr Engineer)


16/03/2020

Checked By: Sanjeev K. Shrivastava (DGM)


16/03/2020

Approved By: Aruna Gulati (AGM)


16/03/20