



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 01

Ref: PSER:SCT:KDM-E2340:TCN-01

Date : 24-12-2024

Sub	Tender Change Notice (TCN) - 01.	
Job	Supply, Erection, Testing, Commissioning and Operation & Maintenance (O&M), for Construction Power sources & general illumination of all the working areas, at 2 X 800 MW, Stage-II Koderma Thermal Power Project, Jharkhand.	
Ref	1.0	Tender no. PSER:SCT:KDM-E2340:24
	2.0	BHEL's NIT, vide reference no. PSER:SCT:KDM-E2340:10810 Date: 16-12-2024
	3.0	Other References, if any.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. The clarifications to bidder's queries/ amendment are attached as Annexure-A to this TCN-01. Bidder shall quote their offer accordingly.
2. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
3. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD.

Sr. Manager / SCT

Encl.: As Above

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339 8000

Job: Supply, Erection, Testing, Commissioning and Operation & Maintenance (O&M), for Construction Power sources & general illumination of all the working areas, at 2 X 800 MW, Stage-II Koderma Thermal Power Project, Jharkhand.

Tender No.: PSER-SCT:KDM-E2340:24

ANNEXURE-A OF TCN-01

Sl. No	Reference Clause of Tender Document	Existing Provision	Bidder's query	BHEL reply/clarification
1	Price Schedule SCH-3 Electrical Supply SI No. 5 (Area Lighting & Yard Lighting) 5.1	Supply of steel tubular swaged poles, 9 mtr long made of sheet steel having ultimate tensile strength 42 kg F/sq. mm conforming to BIS: 2713 (part-II) complete with 300x300x6 mm thick MS base plate for welding at site and size as per configuration given in BIS for 410 SP-28 (113 kg- pole weight)	5.1- Supply of Steel tubuler swaged poles, 9 mtr long is not mentioned arm type.	Sl. no 5.1 of SCH-3- ELECTRICAL SUPPLY of VOLUME-III-PRICE SCHEDULE- REV-00 shall be read as: Supply of steel tubular swaged poles, 9 mtr long made of sheet steel having ultimate tensile strength 42 kg F/sq. mm conforming to BIS: 2713 (part-II) complete with 300x300x6 mm thick MS base plate for welding at site and size as per configuration given in BIS for 410 SP-28 (113 kg- pole weight) with single arm bracket length 1.5 meter.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector - II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Supply, Erection, Testing, Commissioning and Operation & Maintenance (O&M), for Construction Power sources & general illumination of all the working areas, at 2 X 800 MW, Stage-II Koderma Thermal Power Project, Jharkhand.	
Ref	1.0	Tender no. PSER:SCT:KDM-E2340:24
	2.0	BHEL's NIT, vide reference no. PSER:SCT:KDM-E2340:10810 Date: 16-12-2024 .
	3.0	BHEL's TCN-01, vide reference no. PSER:SCT:KDM-E2340:TCN-01 Date: 24-12-2023
	4.0	All other pertinent issues till date.

Dear Sir/Madam,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALTLAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 033-2339 8000