



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT:SAL-C2029:TCN-01

Date: 07-03-2020

Sub	Tender Change Notice (TCN) - 01.	
Job	Civil Work for Installation of DCFS Absorber over Existing Pile Cap and Associated Civil Works at 3x250 MW Bongaigaon TPP, Salakati, Assam.	
Ref	1.0	Tender no PSER:SCT:SAL-C2029:20.
	2.0	BHEL's NIT, vide reference no PSER:SCT:SAL-C2029:7893 Date: 25-02-2020.
	3.0	Other References, if any.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1) Clarification of bidder's query attached vide Annexure-A to TCN-01.
- 2) Introduction of the following clause no. 39.0 in NIT :

"The contractor shall, at all stages of work deploy skilled/ semi-skilled tradesmen who are qualified and possess certificate in particular trade from CPWD Training Institute/ Industrial Training Institute/ National Institute of Construction Management and Research (NICMAR), National Academy of Construction, CIDC or any similar reputed and recognized Institute managed/ certified by State/ Central Government. The number of such qualified tradesmen shall not be less than 20% of total skilled/ semi-skilled workers required in each trade at any stage of work. The contractor shall submit number of man days required in respect of each trade, its scheduling and the list of qualified tradesmen along with requisite certificate from recognized Institute to Engineer-in-Charge for approval. Notwithstanding such approval, if the tradesmen are found to have inadequate skill to execute the work of respective trade, the contractor shall substitute such tradesmen within two days of written notice from Engineer-in-Charge. Failure on the part of contractor to obtain approval of Engineer-in-Charge or failure to deploy qualified tradesmen will attract a compensation to be paid by contractor at the rate of Rs. 100 per such tradesman per day. Decision of Engineer-in-Charge as to whether particular tradesman possesses requisite skill and amount of compensation in case of default shall be final and binding."

- 3) Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 4) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

Sr. Engineer (SCT)

Encl: As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339-8000

ANNEXURE-A TO TCN-01				
JOB: Civil Work for Installation of DCFS Absorber over Existing Pile Cap and Associated Civil Works at 3x250 MW Bongaigaon TPP, Salakati, Assam.				
TENDER NO - PSER:SCT:SAL-C2029:20				
CLARIFICATION OF BIDDER'S QUERY				
Sl. No	Reference clause of tender document	Existing Provision	Bidder's Query	BHEL's Clarification
1	CL. NO. 26.4.11 of VOL-IF-TCC-CML, Page no 17 of 30	1 NO PORTABLE AUTOMATIC CONCRETE BATCHING PLANT WITH PRINTING FACILITY (OUTPUT 30 CUM / HR.)	We request you for amendment of this equipments by suitable capacity batch mix plant can be used.	Please read cl. no. 26.4.11 of T&P list in VOL-IF-TCC-CML as "1 no. portable automatic concrete batching plant with printing facility (Output 15 to 30 cum/ hr)" instead of "1 no. portable automatic concrete batching plant with printing facility (Output 30 cum/ hr)".
2	CL. NO. 26.4.14 of VOL-IF-TCC-CML, Page no 17 of 30	1 NO TRUCK MOUNTED CONCRETE MIXER CUM PUMP ALONG WITH PLACING BOOM MINIMUM 36 M	For this type of job only BP of suitable capacity and transit mixer as stipulated in the tender shall be sufficient. We request you to kindly amend this by deliting this items.	Shall be as per tender provision.
3	Price Schedule	pile, Load tests	Capacity of the pile. Not indicated. To quote the rates of load for Initial and Routine we need the capacity of the pile.	Shall be provided to the successful bidder during execution.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
 Power Sector - Eastern Region,
 Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
 Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Civil Work for Installation of DCFS Absorber over Existing Pile Cap and Associated Civil Works at 3x250 MW Bongaigaon TPP, Salakati, Assam.	
Ref	1.0	Tender no PSER:SCT:SAL-C2029:20.
	2.0	BHEL's NIT, vide reference no PSER:SCT:SAL-C2029:7893 Date: 25-02-2020.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:SAL-C2029:TCN-01, Dated 07-03-2020.
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 23398000