



Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II ,

SALT LAKE CITY , KOLKATA ,WEST BENGAL, INDIA

Phone : 033-23398220,033-23211690 FAX : 033-23211960

Sub	TENDER CHANGE NOTICE (TCN-01 DTD. 06/07/2019)
Job	“SUPPLY & APPLICATION OF THERMAL DRY TYPE (CERAMIC FIBRE BLANKET) INSULATION OF TURBINE (KWU DESIGN) WITH MATTRESSES FOR TDBFP-TURBINE OF 500 MW UNIT AT UNIT 7, MEJIA TPS, DVC, WEST BENGAL”.
Ref	TENDER NO.: PSER:PUR:MJA-S367:19 (ENQ:19:PP:0015:PUR:45) Date 02/07/2019

1) [With reference to above, following clarifications, relevant to tender, may please be noted and complied with while submitting the offer.](#)

Sl. no.	Description/ Tender clause	As appeared in tender	Modified as
1	Scope of works (Annexure-I): point no 1.7 of Types of Insulation	DRIVE TURBINE OF BFP, ESV, MCV, Aux CV: Turbine shall be insulated by asbestors free rock wool mattresses. There are different temperature zone in turbine. Insulation thickness shall be decided by vendor to maintain clod surface temp at 60 Deg Celsius. Insulation shall be finally covered with metal (Aluminum sheet as per IS: 737) sheathing.	DRIVE TURBINE OF BFP, ESV, MCV, Aux CV: Turbine shall be insulated by asbestors free rock wool mattresses. There are different temperature zone in turbine. Insulation thickness shall be decided by vendor to maintain clod surface temp at 60 Deg Celsius. Insulation shall be finally covered with cementing & painting along with proper preservation of the materials.
2	Scope of works (Annexure-I): point no 6.2 (D) of Method of Application	Mattresses insulation shall be lagged with minimum 0.9 mm thickness aluminum (IS: 737: Gr-19000) sheets.	Mattress insulation for Turbine and ESV, MCV chest shall be cover with cementing & painting along with proper preservation of the materials. Mattress insulation of Aux CV shall be lagged with metal (Aluminum sheet as per IS: 737) sheathing.

2) ‘No deviation certificate’ is attached. Bidder to submit their offer along with stamped & signed copy of this TCN & ‘No deviation certificate’ as per attached format only.

3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

Sr. Engineer (PURCHASE)

(Signature, date & seal of authorized representative of the contractor)

[ANNEXURE - IV](#)

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

To,
Bharat Heavy Electricals Limited,
POWER SECTOR – EASTERN REGION
2nd FLOOR, Block-DJ, Plot- 9/1, SECTOR
SALT LAKE CITY, KOLKATA – 700 091
FAX – 033-2321-1960

Job: “SUPPLY & APPLICATION OF THERMAL DRY TYPE (CERAMIC FIBRE BLANKET) INSULATION OF TURBINE (KWU DESIGN) WITH MATTRESSES FOR TDBFP-TURBINE OF 500 MW UNIT AT UNIT 7, MEJIA TPS, DVC, WEST BENGAL”.

E-Tender No.: PSER:PUR:MJA-S367:19 (ENQ:19:PP:0015:PUR:45) Date 02/07/2019, TCN-01 DTD. 06/07/2019.

Dear Sir/Madam,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/modified the tender documents as appeared in the website/newspapers and in case of observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT *and confirm our acceptance to **reverse auctioning process*** and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the contractor)