



## Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II ,

SALT LAKE CITY , KOLKATA ,WEST BENGAL, INDIA

Phone : 033-23398220,033-23211690 FAX : 033-23211960

Sub	TENDER CHANGE NOTICE (TCN-01 DTD. 01/02/2022)
Job	SUPPLY OF RESIN BONDED MINERAL WOOL INSULATION TO 2X660 MW MAITREE STPP, RAMPAL, BAGHERHAT, BANGLADESH.
Ref	TENDER NO.: PSER:PUR:PMX:423:068( ENQ:21:PP:0015:PUR:86) Date 27/01/2022.

With reference to above, following clarifications, relevant to tender, may please be noted and complied with while submitting the offer.

- 1) Clarifications to bidders' queries are attached at [Annexure-Clarification](#).
- 2) Due date of submission of offer against the subject tender is extended **from 03/02/2022 (14:00 hrs. IST) to 04/02/2022 (16:30 hrs. IST)**. **Techno-commercial bid shall be opened on 04/02/2022 (16:30 hrs. IST)**.
- 3) **BIDDERS TO QUOTE THEIR OFFER CONSIDERING THE LATEST SCOPE & PROVISIONS/TERMS AND CONDITIONS OF THE TENDER.**
- 4) Revised 'No deviation certificate' is attached. Bidder to submit their offer along with stamped & signed copy of this TCN & 'No deviation certificate' as per attached format only.
- 5) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

ENGINEER (PURCHASE)

Encl: As above.

(Signature, date & seal of authorized representative of the contractor)

**ANNEXURE - 2**

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

To,  
Bharat Heavy Electricals Limited,  
POWER SECTOR – EASTERN REGION  
2nd FLOOR, Block-DJ, Plot- 9/1, SECTOR  
SALT LAKE CITY, KOLKATA – 700 091  
FAX – 033-2321-1960

**Job: “SUPPLY OF RESIN BONDED MINERAL WOOL INSULATION TO 2X660 MW MAITREE STPP, RAMPAL, BAGERHAT, BANGLADESH.”**

**E-Tender No.: PSER:PUR:PMX:423:068( ENQ:21:PP:0015:PUR:86) Date 27/01/2022, TCN-01 Date 01/02/2022.**

Dear Sir/Madam,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the contractor)

## Annexure-Clarification

**Job: “SUPPLY OF RESIN BONDED MINERAL WOOL INSULATION TO 2X660 MW MAITREE STPP, RAMPAL, BAGERTHAT, BANGLADESH”**

**E-Tender No.: PSER:PUR:PMX:423:068( ENQ:21:PP:0015:PUR:86) Date 27/01/2022, TCN-01 Date 01/02/2022.**

SL NO	REFERENCE CLAUSE OF TENDER DOCUMENT	BIDDER'S QUERY	BHEL'S CLARIFICATION
1	Price Schedule	As per the BOQ , it is mentioned that we need to supply the Resin Bonded Mineral wool along with the application Glue and lacing wire. But as per our knowledge Glue and Lacing wire is not required for this insulation work. PLEASE CLARIFY ? IF NEED CONFIRM THE QUANTITY AND GRADE OF THE GLUE & LACIN WIRE?	Lacing wire & Glue is excluded from scope of supply. For detail description, please check below.
2	--	As our standard size of Resin Bonded Mineral wool is 1000mm * 500/600mm . PLEASE CONFIRM	Standard sizes may be acceptable. However thickness, density and other technical parameters to be maintained as per technical specification & BOQ requirement

In line with the above query No 1, the BOQ description shall be revised as below:-		
BOQ SL. NO.	Existing Description	Revised Description
Sl No 1	Supply of non combustible, water repellant grade insulation of resin bonded mineral wool of minimum 60 mm nominal thickness having maximum heat transmission coefficient of 0.75 W/(sqm K) and conforming to relevant BS or equivalent international code having a minimum density of 32 kg/cum glass wool or 48 kg/cum for rock wool, for cladding/under deck insulation including supply of application glue and lacing wire, for glass/rock wool as per manufacturer's recommendations.	Supply of non combustible, water repellant grade insulation of resin bonded mineral wool of minimum 60 mm nominal thickness having maximum heat transmission coefficient of 0.75 W/(sqm K) and conforming to relevant BS or equivalent international code having a minimum density of 32 kg/cum glass wool or 48 kg/cum for rock wool, for cladding/under deck insulation as per manufacturer's recommendations.
Sl No 2	Supply of non combustible, water repellant grade insulation of resin bonded mineral wool of minimum 75 mm nominal thickness having maximum heat transmission coefficient of 0.45 W/(sqm K) and conforming to relevant BS or equivalent international code having a minimum density of 32 kg/cum glass wool or 48 kg/cum for rock wool, for cladding/under deck insulation including supply of application glue and lacing wire, for glass/rock wool as per manufacturer's recommendations.	Supply of non combustible, water repellant grade insulation of resin bonded mineral wool of minimum 75 mm nominal thickness having maximum heat transmission coefficient of 0.45 W/(sqm K) and conforming to relevant BS or equivalent international code having a minimum density of 32 kg/cum glass wool or 48 kg/cum for rock wool, for cladding/under deck insulation for glass/rock wool as per manufacturer's recommendations.

(Signature, date & seal of authorized representative of the contractor)