



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 01

Ref: PSER:SCT:BAR-C2010:20:TCN-01

Date: 31-01-2020

Sub	Tender Change Notice (TCN) - 01.	
Job	Construction of 02 nos. 150 meter high reinforced concrete single steel flue chimney with borosilicate glass block lining system on MS flue-can and other incidentals complete (excluding pile) at 2x660 MW Barh STPP Stage-II, Bihar.	
Ref	1.0	Tender no: PSER:SCT:BAR-C2010:20.
	2.0	BHEL's NIT, vide reference no: PSER:SCT:BAR-C2010:7772, Date: 10-01-2020.
	3.0	Other References, if any.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. Due date of submission of offer is extended from 31-01-2020 to 07-02-2020 (15-00 hrs). Bidders are requested to submit their offer by extended due date positively.
2. Cl no 35.6 under Cl no 35.0- TAXES AND DUTIES of VOLUME-IF-TCC-CML (REV-00) shall be read as follows:

Clause No 35.6: - TDS under GST shall be deducted at applicable rates on gross invoice value from the running bills (RA bills).

3. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
4. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

Dy. Mgr (SCT)

Encl: As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339 8000

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Construction of 02 nos. 150 meter high reinforced concrete single steel flue chimney with borosilicate glass block lining system on MS flue-can and other incidentals complete (excluding pile) at 2x660 MW Barh STPP Stage-II, Bihar.	
Ref	1.0	Tender no PSER:SCT:BAR-C2010:20
	2.0	BHEL's NIT, vide ref no: PSER:SCT:BAR-C2010:7772 Date: 10-01-2020.
	3.0	BHEL's TCN-01, vide ref no: PSER:SCT:BAR-C2010:20:TCN-01 Date: 31-01-2020.
	4.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 033-2339 8000/ 2339 8236