



# Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region

BHEL BHAWAN, PLOT NO. DJ-9/1 , SECOTR II ,

SALT LAKE CITY , KOLKATA ,WEST BENGAL, INDIA

Phone : 033-23398220,033-23211690 FAX : 033-23211960

## **TENDER CHANGE NOTICE**

<b>Sub</b>	<b>TENDER CHANGE NOTICE: TCN-02 dtd. 05/08/2021</b>
<b>Job</b>	Supply of Cladding sheets & Deck sheets at 1 X 250 MW NSPCL Rourkela PP-II Expansion project".
<b>Ref</b>	(i) <b>TENDER NO : PSER:PUR:PMX:374(VIII):020 (ENQ:21:PP:0015:PUR:22) Date:27/07/2021</b>
	(ii) <b>TCN-01 dtd. 02/08/2021</b>

With reference to above, following clarifications, relevant to tender, may please be noted and complied with while submitting the offer.

- 1) **Clarification to bidder's query as per attached Annexure-A**
- 2) Revised 'No deviation certificate' is attached. Bidder to submit their offer along with stamped & signed copy of this TCN & 'No deviation certificate' as per attached format only.
- 3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD.

DY. MGR (PURCHASE)

Encl: As above.

(Signature, date & seal of authorized representative of the contractor)

**NO DEVIATION CERTIFICATE**  
**(TO BE SUBMITTED IN BIDDER'S LETTERHEAD)**

To,  
BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	"Supply of Cladding sheets & Deck sheets at 1 X 250 MW NSPCL Rourkela PP-II Expansion project".	
Ref	1.0	PSER:PUR:PMX:374(VIII):020 (ENQ:21:PP:0015:PUR:22) Date:27/07/2021 and TCN-01 DATED 02/08/2021
	2.0	TCN-01 dtd. 02/08/2021 & TCN-02 dtd. 05/08/2021
	2.0	Other references (if any).

Dear Sir/Madam,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the bidder)

ANNEXURE-A TO TCN-02				
JOB : Supply of Cladding Sheets & Deck Sheets at 1 x 250 MW NSPCL Rourkela PP-II Expansion Project				
Tender No. PSER:PUR:PMX:374(VIII):020 (ENQ:21:PP:0015:PUR:22) dated 27.07.2021				
Sl. No.	Reference clause of tender document	Existing Provision	Bidder's query	BHEL's Clarification
1	A 1506 of SOR Item for Prefabricated PU Panel	In inner sheet painting, it is mentioned RMP colour coating of 25microns on the exposed side over primer.	Commercially RMP coating of 20micron over 5micron primer on exposed side is available. The same paint thickness is also mentioned in other items. Request your clarifications.	as per specification the RMP colour coating of 25 microns on the exposed side is excluding primer.