

भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 02

Ref: PSER:SCT:KLW-C1814:TCN-02

Date: 30-03-2017

Sub	Tender change notice (TCN) 02					
Job	Geo technical investigation and topographical survey at natural gas based					
	Combined Cycle Power Plant, Kilwa Energy Company Limited (KECL),					
	Somanga Mtama Village, kilwa district, linde region in Tanzania.					
Ref	Tender no PSER:SCT:KLW-C1814:17					
	2.0	2.0 BHEL's NIT, vide reference no PSER:SCT: KLW-C1814:5540, Dated 10-				
	03-2017.					
	2.0	BHEL's TCN-01, vide reference no PSER:SCT:KLW-C1814:TCN-01,				
		dated 21-03-2017.				
	4.0	All other pertinent issues till date.				

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Extension of due date of offer submission from **31-03-2017** to **10-04-2017** (**15:00 Hrs**).
- 2.0 Clarification to bidder's query as per attached Annexure-A.
- 3.0 Revised `No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 4.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully, for BHARAT HEAVY ELECTRICALS LTD

SR.ENGR (SCT)

Encl: As above.

FORMAT FOR NO DEVIATION CERTIFICATE (To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED, Power Sector - Eastern Region, Plot no 9/1, DJ Block, Sector - II, Salt Lake City, Kolkata - 700 091

Sub	No Deviation Certificate.				
Job	Geo technical investigation and topographical survey at natural gas based Combined				
	Cycle Power Plant, Kilwa Energy Company Limited (KECL), Somanga Mtama Village, kilwa district, linde region in Tanzania.				
Ref	1.0	Tender no PSER:SCT:KLW-C1814:17			
	2.0	BHEL's NIT, vide reference no PSER:SCT: KLW-C1814:5540, Dated 10-03-			
2017.					
	BHEL's TCN-01, vide reference no PSER:SCT:KLW-C1814:TCN-01, dated 21-				
		03-2017.			
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:KLW-C1814:TCN-02, dated 30-			
		03-2017.			
	5.0	All other pertinent issues till date.			

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

ANNEXURE-A TO TCN-02 Geo technical investigation and topographical survey at natural gas based Combined Cycle Power Plant, Kilwa Energy Company Limited (KECL), Somanga Mtama Village, kilwa district, linde region in Tanzania.								
TENDER NO : PSER:SCT:KLW-C1814:17								
CLARIFICATION/ MODIFICATION								
SL NO	REFERENCE CLAUSE OF TENDER DOCUMENT	EXISTING PROVISION	BIDDER'S QUERY	BHEL'S CLARIFICATION				
1.0	General		Since the company is one year age and account auditing is in progress, please may we submit the Bank Statement signed by the Charted Bank operating the account?	Kindly follow the Serial No. 1(Financial Criteria) of Pre- Qualification Criteria in NIT.				