



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 02

Ref: PSER:SCT:RMM-M1798:TCN-02

Date: 23-02-2017

Sub	Tender change notice (TCN) 02	
Job	Design, engineering, manufacturing, supply, storage, erection & commissioning, O&M etc, of 1 No Double girder EOT crane (125/25/5/5T) for 3x40 MW NTPC Rammam stage-III, HEP, West Bengal.	
Ref	1.0	Tender No. PSER:SCT:RMM-M1798:17
	2.0	BHEL's NIT, vide reference no PSER:SCT:RMM-M1798:5456, Dated 04-02-2017.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:RMM-M1798:TCN-01, dated 16-02-2017.
	4.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Clarifications to bidders queries are attached at **Annexure-A**.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

SR. ENGR (SCT)

Encl

- 1.0 As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
 Power Sector - Eastern Region,
 Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
 Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, engineering, manufacturing, supply, storage, erection & commissioning, O&M etc, of 1 No Double girder EOT crane (125/25/5/5T) for 3x40 MW NTPC Rammam stage-III, HEP, West Bengal.	
Ref	01	Tender No. PSER:SCT:RMM-M1798:17
	02	BHEL's NIT, vide reference no PSER:SCT:RMM-M1798:5456, Dated 04-02-2017.
	03	BHEL's TCN-01, vide reference no PSER:SCT:RMM-M1798:TCN-01, dated 16-02-2017.
	04	BHEL's TCN-02, vide reference no PSER:SCT:RMM-M1798:TCN-02, dated 23-02-2017.
	05	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

ANNEXURE-A TO TCN-02**Design, engineering, manufacturing, supply, storage, erection & commissioning, O&M etc, of 1 No Double girder EOT crane (125/25/5/5T) for 3x40 MW NTPC Rammam stage-III, HEP, West Bengal.****TENDER NO: PSER:SCT:RMM-M1798:17**

SL No	Bidder's query	BHEL's clarification/ reply
1	Dimension shown in drawing no. PE-DG-414-501-A001 VIEW-A can be modified 2600mm to 3200mm	The referred view corresponds to LT wheel base of the crane. It is clarified that the dimensions indicated in the wheel base diagram is tentative and any change to same can be accepted subject to the condition that all hook approaches as shown for main hook and auxiliary hook of the crane must be maintained and also value of wheel load should not exceed the values as indicated in the drawing.
2	<u>Drawing no. PE-DG-414-501-A001:</u> End approach of crane from column B & D shall be achieved by 5T hoist.	Tender specification to be followed. No change in hook approaches is acceptable.
3	<u>Drawing no. PE-DG-414-501-A001:</u> Meaning of DDE kindly clarify (CL of Column to CL of ISMB for 5T Hoist)	DDE stands for 'During detailed engineering'.