



भारत हेवी इलेक्ट्रिकल्स लिमिटेड
(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED
(A Govt. of India Undertaking)

TCN - 02

Ref: PSER:SCT: FKK-S2079:TCN-02

Date: 18-12-2020

Sub	Tender Change Notice (TCN) - 02.	
Job	Dismantling, Material Transportation (Store/Yard To Site) Movement, New Material Erection, Re-Erection of old items, Modification of existing items, Restoration, Commissioning, Testing & PG Test etc. of Combustion Modification System for NOx Mitigation of U#6,1x500 MW, NTPC Farakka STPS, West Bengal.	
Ref	1.0	Tender no: PSER:SCT:FKK-S2079:20.
	2.0	BHEL's NIT, vide reference no: PSER:SCT:FKK-S2079:8284 Date: 26-11-2020.
	3.0	BHEL's TCN-01, vide ref no PSER:SCT: FKK-S2079:TCN-01 Date: 17-12-2020.
	4.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1) Revision/Modification to tender clause attached vide Annexure-A of this TCN-02.
- 2) Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

Dy. Mgr. (SCT)

Encl: As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091
फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339-8000

Dismantling, Material Transportation (Store/Yard To Site) Movement, New Material Erection, Re-Erection of old items, Modification of existing items, Restoration, Commissioning, Testing & PG Test etc. of Combustion Modification System for NOx Mitigation of U#6,1x500 MW, NTPC Farakka STPS, West Bengal.

(Tender no: PSER:SCT:FKK-S2079:20.)

ANNEXURE-A TO TCN-02

MODIFICATION/REVISION

SL. NO.	REFERENCE CLAUSE OF TENDER	EXISTING PROVISION	MODIFIED/REVISED PROVISION
1.0	Clause No 20.1 of VOLUME – IF (Rev-00) TCC-CML	BHEL shall provide construction power on chargeable basis at 415V level at one point. Contractor has to make their own distribution arrangement to draw electricity by arranging all required items e.g power cable, construction cable, ELCB,MCCB, JB's, Switch Borads etc to be arranged by vendor at his own cost.	To meet the construction power requirement of the Combustion Modification package, the Employer shall provide Two Number 415V feeders in LT switchgears. The Contractor shall extend supply from these Construction power feeders to meet the construction power requirements at the various locations included in the Contractor's scope through suitably rated Isolation Transformers along with LT distribution boards as per requirement. LT Packaged Sub-stations with Isolation transformers may also be used for this purpose. Suitable metering arrangement along with associated Instrument transformers and Metering Cubicles meeting the DISCOM requirements shall be provided by the Contractor at each Construction power feeder, for the measurement of actual energy consumed by the Contractor. The charges only for the actual energy consumed by the Contractor shall be recovered by the Employer based on prevalent rate of DISCOM. All necessary statutory requirements for charging construction power of Contractor's network shall be in the Contractor's scope. Construction power supply network is a temporary arrangement which shall be used during the project construction phase. To meet this requirement, the equipments may be arranged by Contractor either by shifting their existing equipments at other installation or by fresh procurement, which may be taken back after commissioning of the project.

ANNEXURE - 2**FORMAT FOR NO DEVIATION CERTIFICATE**
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector - II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Dismantling, Material Transportation (Store/Yard To Site) Movement, New Material Erection, Re-Erection of old items, Modification of existing items, Restoration, Commissioning, Testing & PG Test etc. of Combustion Modification System for NOx Mitigation of U#6,1x500 MW, NTPC Farakka STPS, West Bengal.	
Ref	1.0	Tender no PSER:SCT:FKK-S2079:20.
	2.0	BHEL's NIT, vide reference no PSER:SCT: FKK-S2079:8284 Date:26-11-2020.
	3.0	BHEL's TCN-01, vide ref no PSER:SCT: FKK-S2079:TCN-01 Date: 17-12-2020.
	4.0	BHEL's TCN-02, vide ref no PSER:SCT: FKK-S2079:TCN-02 Date: 18-12-2020.
	5.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification and integrity pact (if applicable).

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALTLAKE CITY, KOLKATA - 700 091
फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 23398000