



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 03

Ref: PSER:SCT:NKP-C1772:TCN-03

Date: 19-10-2016

Sub	Tender Change Notice (TCN) – 03.	
Job	Package A - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 3 for 3x660 MW North Karanpura STPP, Jharkhand. Package B - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 2 for 3x660 MW North Karanpura STPP, Jharkhand. Package C - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 2 & 3 for 3x660 MW North Karanpura STPP, Jharkhand.	
Ref	1.0	Tender no. PSER:SCT:NKP-C1772:16.
	2.0	BHEL's NIT, vide reference no PSER:SCT:NKP-C1772:5231, Dated 19-09-2016.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:NKP-C1772:TCN-01, Dated 28-09-2016.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:NKP-C1772:TCN-02, Dated 07-10-2016.
	5.0	All other pertinent issues till date.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. Bidder's Clarification is attached vide **Annexure-A to TCN-03**.
2. Clause no. 4.0 of NIT shall be revised as follows:
"Unless specifically stated otherwise, bidder shall have to deposit EMD through Demand Draft/ Pay Order in favor of Bharat Heavy Electricals Ltd, payable at Kolkata. For other details please refer General Conditions of Contract.
Bidders may please be noted that "OEMD" provision stands deleted. Hence, bidders who have deposited Rs. 2 Lakh as OEMD are also requested to submit fresh EMD as mentioned in sl no vii under clause no 1.0 of NIT."
3. In sl. no. 5 of Annexure-A (Amendment to GCC/SCC) of NIT, the statement "Security Deposit may be furnished in any one of the following forms" shall be read as "The balance amount to make the required Security Deposit of 5% of the contract value may be accepted in the following forms".
4. Due date of submission of offer is extended from 20-10-2016 to **02-11-2016 (15-00 hrs)**. Bidders are requested to submit their offer by extended due date positively.
5. Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
6. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGR (SCT)

Encl: As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339 8231

ANNEXURE-A TO TCN-03

**JOB: Package A - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 3 for 3x660 MW North Karanpura STPP, Jharkhand.
 Package B - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 2 for 3x660 MW North Karanpura STPP, Jharkhand.
 Package C - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 2 & 3 for 3x660 MW North Karanpura STPP, Jharkhand.**

TENDER NO. PSER:SCT:NKP-C1772:16

Clarification Of Bidder's Query

SL NO	REFERENCE CLAUSE OF TENDER DOCUMENT	EXISTING PROVISION	BIDDER'S QUERY	BHEL'S CLARIFICATION
1	GENERAL	-	GA drawings for the ACC columns.	GA Drawing not yet received from our design section.
2	VOLUME-IF-TCC-CML	-	How many nos. of ACC columns to be constructed for each packages.	Column data (per ACC unit) range shall be as follows: 1. No. of columns: 25 to 30. 2. Diameter of column: 4.5 to 6 meters 3. Thickness of Column: 0.4 to 0.6 meters 4. Height of Column (above zero level): 50 to 65 meters
3	VOLUME-IF-TCC-CML	-	Goods and Service Tax (GST) to be considered in new taxes or not.	All taxes will be subsumed except some specifically mentioned in the Act after the implementation of G.S.T .
4	CLAUSE NO. 35.0 - TAXES AND DUTIES OF VOLUME-IF-TCC-CML	-	As per the clause 35.2, any increase of the taxes except Service Tax, education cess & other cess on service tax will have to be borne by the contractor. Please note that after implementation of GST, all the taxes including service tax will be subsumed in GST. Please confirm that GST will be treated as new tax & we will be compensated for any increase in taxes due to imposition of GST.	Also please take note of the followings: Benefits and or abolition of all existing Taxes must be passed on to BHEL against new Taxes, if any, proposed to be introduced in a later date.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Package A - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 3 for 3x660 MW North Karanpura STPP, Jharkhand. Package B - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 2 for 3x660 MW North Karanpura STPP, Jharkhand. Package C - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 2 & 3 for 3x660 MW North Karanpura STPP, Jharkhand.	
Ref	1.0	Tender no. PSER:SCT:NKP-C1772:16.
	2.0	BHEL's NIT, vide reference no PSER:SCT:NKP-C1772:5231, Dated 19-09-2016.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:NKP-C1772:TCN-01, Dated 28-09-2016.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:NKP-C1772:TCN-02, Dated 07-10-2016.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:NKP-C1772:TCN-03, Dated 19-10-2016.
	6.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALLAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339-8231