



# भारत हेवी इलेक्ट्रिकल्स लिमिटेड

( भारत सरकार का उपक्रम )

## BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

**TCN - 03**

Ref: PSER: SCT: BRM-C1953: TCN-03

Date: 22-04-2019

Sub	Tender Change Notice (TCN)- 03	
Job	BALANCE CIVIL, STRUCTURAL AND ARCHITECTURAL WORKS FOR 2 X 250 MW BARAUNI THERMAL POWER STATION (EXTENSION PROJECT), UNIT # 8 & 9 BEGUSARAI, BIHAR, BARAUNI	
Ref	1.0	Tender no PSER:SCT: BRM-C1953:19
	2.0	BHEL's NIT, vide reference no PSER:SCT: BRM-C1953:7493 Date: 26-03-2019
	3.0	BHEL's TCN-01 ref PSER: SCT: BRM-C1953: TCN-01 dated 16-04-2019
	4.0	BHEL's TCN-02 ref PSER: SCT: BRM-C1953: TCN-02 dated 20-04-2019
	5.0	Other References, if any.

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting the offer.

1. Reply to Bidder's queries vide Annexure-A to TCN-03.
2. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
3. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

Mgr (SCT)

Encl:

1.0 As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 23211798/ 1691

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	BALANCE CIVIL, STRUCTURAL AND ARCHITECTURAL WORKS FOR 2 X 250 MW BARAUNI THERMAL POWER STATION (EXTENSION PROJECT), UNIT # 8 & 9 BEGUSARAI, BIHAR, BARAUNI	
Ref	1.0	Tender no PSER:SCT: BRM-C1953:19
	2.0	BHEL's NIT, vide reference no PSER:SCT: BRM-C1953:7493 Date: 26-03-2019
	3.0	BHEL's TCN-01,vide reference no PSER: SCT: BRM-C1953: TCN-01 Date: 16-04-2019
	4.0	BHEL's TCN-02,vide reference no PSER: SCT: BRM-C1953: TCN-02 Date: 20-04-2019
	5.0	BHEL's TCN-03,vide reference no PSER: SCT: BRM-C1953: TCN-03 Date: 22-04-2019
	6.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer in accordance with tender instructions and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

**ANNEXURE-A TO TCN-03**

**BALANCE CIVIL, STRUCTURAL AND ARCHITECTURAL WORKS FOR 2 X 250 MW BARAUNI THERMAL POWER STATION (EXTENSION PROJECT), UNIT # 8 & 9 BEGUSARAI, BIHAR, BARAUNI**

Sr. No	REFERENCE CLAUSE OF TENDER DOCUMENT			EXISTING PROVISION	BIDDER'S QUERY	BHEL'S REPLY
	Volume No	Section	Serial No .			
1	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.1	Two Nos Crawler /Tyre Mounted Crane40/45 T capacity	Bidder's Proposal :One Nos Crawler /Tyre Mounted Crane40/45 T capacity	Shall be as per tender
2	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.4	Two Nos 20/25 T Capacity Crawler Crane	Bidder's Proposal : One Nos 20/25 T capacity Tyre Mounted crane	Shall be as per tender
3	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.5	4 Nos. Hydra(10/12 T cap)	Bidder's Proposal: 1 Nos Hydra(14 T cap)	Shall be as per tender
4	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.10	40 Nos Welding Rectifier	Bidder's Proposal:20 Nos Welding Rectifier	Shall be as per tender
5	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.17	One Mobile Concrete Boom Placer Atleast 41 M Height Lifting	Bidder's Proposal:No Boom Placer , As already 2 concrete Pump are sufficient for 90 Metres Height capacity Model -1400	Shall be as per tender
6	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.26	Ply Shuttering Board( 4500SQM ) Including propping with Steel Tubular Sections /Acrow Pipes	Bidder's Proposal:2500 Sqm quantity.	Shall be as per tender
7	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.27	Ply Shuttering Board( 4500SQM ) Including propping with Steel Tubular Sections /Acrow Pipes	Bidder's Proposal:2500 Sqm quantity.	Shall be as per tender
8	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.28	8Nos Dumper	Bidder's Proposal:4 Nos. Dumper	Shall be as per tender
9	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.31	40000RM MS scaffolding Pipe / Cup Lock System	Bidder's Proposal:30000RM MS Scaffolding Pipe / cup Lock System	Shall be as per tender
10	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.32	04. Nos Power Driver Earth rammer	Bidder's Proposal:2 Nos of Power Driven Earth Rammer	Shall be as per tender
11	Volume -1F(TCC Service)	26)Tools and Plant (to Be provided by Contractor)	26.4.36	4 Nos Electric Winch with Building Hoist	Bidder's Proposal:2 Nos of Electric Winch with Building Hoist	Shall be as per tender

**ANNEXURE-A TO TCN-03**

**BALANCE CIVIL, STRUCTURAL AND ARCHITECTURAL WORKS FOR 2 X 250 MW BARAUNI THERMAL POWER STATION (EXTENSION PROJECT), UNIT # 8 & 9 BEGUSARAI, BIHAR, BARAUNI**

Sr. No	REFERENCE CLAUSE OF TENDER DOCUMENT			EXISTING PROVISION	BIDDER'S QUERY	BHEL'S REPLY
	Volume No	Section	Serial No.			
12	Volume -1F(TCC Service)	30)Liquidated Damages	30.2.2	If Completion of work goes beyond specified contract period of 20(Twenty) months from date of start of work, as certified by Construction Manager, BHEL, LD will be imposed with maximum LD amount shall be 10 % of total contract value.	Bidder's Proposal:If Completion of work goes beyond specified contract period of 20(Twenty) months from date of start of work, as certified by Construction Manager, BHEL, LD will be imposed with maximum LD amount shall be 5 % of total balance contract value.	Shall be as per tender
13	Volume -1B(GCC service)	1.10) Security Deposit	1.10	<p>1.10 SECURITY DEPOSIT</p> <p>1.10.1 Upon acceptance of Tender, the successful Tenderer should deposit the required amount of Security Deposit for satisfactory completion of work, as per the rates given below:</p> <p>SN Contract Value Security Deposit Amount</p> <p>1 Up to Rs. 10 lakhs 10% of Contract Value</p> <p>2 Above Rs. 10 lakhs upto Rs.50 lakhs</p> <p>1 lakh + 7.5% of the Contract Value exceeding Rs. 10 lakhs.</p> <p>3 Above Rs. 50 lakhs Rs 4 lakhs + 5% of the Contract Value exceeding Rs. 50 lakhs.</p> <p>1.10.2 The security Deposit should be furnished before start of the work by the contractor.</p>	Bidder's Proposal:1% Security Deposit of Contract value at the time of starting of the work and deduct 10% as retention instead of 5% from Running Bills .	Shall be as per tender
14	Volume -III(Price Schedule ) Rev 00	Item No 102		Dewatering using of ground water by well point method as per IS-9759 in wagon tippler and associated structures including all accesories such as discharge pipes etc, necessary manpower, electricians, technicians, pump operators for round the clock operation.The pumps are to be of electrically operated 60 HP or as directed by the engineer incharge.per pump set per month	Bidder's Proposal :The Pump Capacity shall be as per requirement and can not be consider 60HP , It shall be as per site condition Kindly remove the Line 60HP Electrically operated and replace with only Electrically operated Pump as Per Requirement at site . Item Shall be Paid as Per Per Pump /Per Month .	Shall be as per tender