



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

**BHARAT HEAVY ELECTRICALS LIMITED**

(A Govt. of India Undertaking)

**TCN - 04**

Ref: PSER:SCT:NBN-C2026:TCN-04

Date: 03-03-2020

Sub	Tender Change Notice (TCN)- 04.	
Job	LEVELLING GRADING, PILING WORK INCLUDING TESTING OF PILES AND OTHER ASSOCIATED WORKS ETC. OF FGD SYSTEM FOR 4x250 MW BRBCL NABINAGAR TPP, BIHAR.	
Ref	1.0	Tender no: PSER:SCT:NBN-C2026:20
	2.0	BHEL's NIT, vide reference no PSER:SCT:NBN-C2026:7857 Date: 15-02-2020.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT: NBN-C2026:TCN-01 Date: 20-02-2020.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT: NBN-C2026:TCN-02 Date: 22-02-2020.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT: NBN-C2026:TCN-03 Date: 24-02-2020.
	6.0	Other References, if any.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. Clarifications/ Modifications attached vide **Annexure-A of this TCN-04**.
2. Due date of submission of offer is extended from **03-03-2020 to 06-03-2020 (15-00 hrs)**. Bidders are requested to submit their offer by extended due date positively.
3. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
4. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

Dy. Mgr (SCT)

Encl: As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339 8000

LEVELLING GRADING, PILING WORK INCLUDING TESTING OF PILES AND OTHER ASSOCIATED WORKS ETC. OF FGD SYSTEM FOR 4x250 MW BRBCL NABINAGAR TPP, BIHAR.				
TENDER NO: PSER:SCT:NBN-C2026:20.				
ANNEXURE-A TO TCN-04				
CLARIFICATIONS/ MODIFICATIONS				
SL. NO.	REFERENCE CLAUSE OF TENDER	EXISTING PROVISION	BIDDER'S QUERY	BHEL'S CLARIFICATION
1.0	Cl.No.4.2 of VOLUME-IF-TCC-CML-REV-00	-	Location of batching plant & it's distance from pile site (to & fro).	As mentioned in tender. Batching Plant will be located inside the plant premises. Bidders are requested to visit site for further information/ details.
2.0	Cl.No.13.3 of VOLUME-IF-TCC-CML-REV-00	-	Land for labour hutment & hutment is in contractor's scope. Location of labour hutment is required.	As clearly mentioned at 13.3 of VOLUME-IF-TCC-CML " Land for labour colon shall be arranged by successful bidder at their own ". Bidder to make the arrangement accordingly.
3.0	Cl.No.13.1 of VOLUME-IF-TCC-CML-REV-00	-	Location of site office & godown	Land for site office & store will be provided by BHEL inside project premises. However, Bidders are requested to visit site for further information/ details.
4.0	-	-	Requirements for enrolling labour for deployment. Generally how many days are required when we can deploy labour after bringing them to site means time taken for induction program.	Kindly refer cl. no. 2.0 of VOLUME-IF-TCC-CML as stated below: "The contractor should visit project site and acquire full knowledge and information about conditions prevailing at site and in & around the plant premises, together with all the statutory, obligatory, mandatory requirements of various authorities before submission of the bid."
5.0	-	-	Location & distance of muck disposal land.	Bidders are requested to visit site for details.
6.0	-	-	Water & electricity is in BHEL's scope but for labour hutment it is in contractor's scope.	Please refer Cl. No. 13.3, Cl.No.14 & Cl.No.15 of VOLUME-IF-TCC-CML (REV-00) for details.
7.0	-	-	Reinforcement may also be issued at BHEL's store. Distance between store and site required to ascertain the cost of transportation.	Please refer sl no 3.0 above .
8.0	Cl.No.28 of VOLUME-IF-TCC-CML-REV-00	-	When we are not supplying any material then do we still require to establish the quality laboratory? If yes, then why?	To ensure quality, minimum lab equipments requirement is kept in the scope of piling agency also.
9.0	Cl.No.30 of VOLUME-IF-TCC-CML-REV-00	-	Completion period is 8 months & mobilization period is 15 days. Is this period is applicable as a whole? Under which conditions it will be allowed to increase? For example in case of delay of drawing for one area will it not effect the overall progress? Will additional deployment required to meet this delay is payable?	As per tender
10.0	Cl. No. 19.4.16 of VOLUME-IF-TCC-CML(REV-00)	1 no Compression Testing Machine (200 T cap) to be deployed "within 30 days" from the date of written intimation.	-	Cl. No. 19.4.16 of VOLUME-IF-TCC-CML(REV-00) shall be revised as below: "1 no Compression Testing Machine (200 T cap) to be deployed as per site requirement".
11.0	Cl. No. 19.4.19 of VOLUME-IF-TCC-CML(REV-00)	60 nos. Concrete Cube Moulds to be deployed "within 30 days" from the date of written intimation	-	Cl. No. 19.4.19 of VOLUME-IF-TCC-CML(REV-00) "Concrete Cube Moulds to be deployed as per site requirement".

**ANNEXURE - 2**

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector - II, Salt Lake City,  
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	LEVELLING GRADING, PILING WORK INCLUDING TESTING OF PILES AND OTHER ASSOCIATED WORKS ETC. OF FGD SYSTEM FOR 4x250 MW BRBCL NABINAGAR TPP, BIHAR.	
Ref	1.0	Tender no PSER:SCT:NBN-C2026:20.
	2.0	BHEL's NIT, vide reference no PSER:SCT:NBN-C2026:7857 Date: 15-02-2020
	3.0	BHEL's TCN-01, vide reference no PSER:SCT: NBN-C2026:TCN-01 Date: 20-02-2020.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT: NBN-C2026:TCN-02 Date: 22-02-2020.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT: NBN-C2026:TCN-03 Date: 24-02-2020.
	6.0	BHEL's TCN-04, vide reference no PSER:SCT: NBN-C2026:TCN-04 Date: 03-03-2020.
	7.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALTLAKE CITY, KOLKATA - 700 091  
फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 033-2339 8000/ 2339 8236