



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 05

Ref: PSER:SCT:BAR-C2170:TCN-05

Date: 18-10-2022

Sub	Tender Change Notice (TCN) - 05	
Job	Construction of 01 no 150 Meter high reinforced concrete single steel flue Chimney(including piling) with borosilicate glass block lining and other incidentals works all complete for FGD system of unit-2 at 3x660 MW Barh STPP Stage-I, Bihar.	
Ref	1.0	Tender no PSER:SCT:BAR-C2170:22
	2.0	BHEL's NIT, vide reference no PSER:SCT:BAR-C2170:9451 Date: 29-09-2022
	3.0	BHEL's TCN-01, vide reference no PSER:SCT: BAR-C2170:TCN-01, dated 30-09-2022
	4.0	BHEL's TCN-02, vide reference no PSER:SCT: BAR-C2170:TCN-02, dated 12-10-2022
	5.0	BHEL's TCN-03, vide reference no PSER:SCT: BAR-C2170:TCN-03, dated 12-10-2022
	6.0	BHEL's TCN-04, vide reference no PSER:SCT: BAR-C2170:TCN-04, dated 17-10-2022
	7.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Bid/ offer submission start date is extended from 18-10-2022 to **20-10-2022 (13-00 hrs IST)**.
- 2.0 Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY. MGR (SCT)

Encl: As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211691, 23211798, 23211796

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Construction of 01 no 150 Meter high reinforced concrete single steel flue Chimney(including piling) with borosilicate glass block lining and other incidentals works all complete for FGD system of unit-2 at 3x660 MW Barh STPP Stage-I, Bihar.	
Ref	1.0	Tender no PSER:SCT:BAR-C2170:22
	2.0	BHEL's NIT, vide reference no PSER:SCT:BAR-C2170:9451 Date: 29-09-2022
	3.0	BHEL's TCN-01, vide reference no PSER:SCT: BAR-C2170:TCN-01, dated 30-09-2022
	4.0	BHEL's TCN-02, vide reference no PSER:SCT: BAR-C2170:TCN-02, dated 12-10-2022
	5.0	BHEL's TCN-03, vide reference no PSER:SCT: BAR-C2170:TCN-03, dated 12-10-2022
	6.0	BHEL's TCN-04, vide reference no PSER:SCT: BAR-C2170:TCN-04, dated 17-10-2022
	7.0	BHEL's TCN-05, vide reference no PSER:SCT: BAR-C2170:TCN-05, dated 18-10-2022
	8.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)