



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 05

Ref: PSER:SCT:NKP-C1772:TCN-05

Date: 28-10-2016

Sub	Tender Change Notice (TCN) – 05.	
Job	Package A - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 3 for 3x660 MW North Karanpura STPP, Jharkhand. Package B - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 2 for 3x660 MW North Karanpura STPP, Jharkhand. Package C - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 2 & 3 for 3x660 MW North Karanpura STPP, Jharkhand.	
Ref	1.0	Tender no. PSER:SCT:NKP-C1772:16.
	2.0	BHEL's NIT, vide reference no PSER:SCT:NKP-C1772:5231, Dated 19-09-2016.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:NKP-C1772:TCN-01, Dated 28-09-2016.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:NKP-C1772:TCN-02, Dated 07-10-2016.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:NKP-C1772:TCN-03, Dated 19-10-2016.
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:NKP-C1772:TCN-04, Dated 21-10-2016.
	7.0	All other pertinent issues till date.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. Bidder's Clarification is attached vide **Annexure-A to TCN-05**.
2. Fifth para of Point No 2 under Annexure-A-Amendment to GCC/SCC of NIT shall be modified as below:

Sl. No.	Existing Provision	Modified Provision
(i)	In case total EMD amount is more than Rs. 20 Lakh, the amount in excess of Rs. 20 lakh may be accepted in the form of Bank Guarantee from scheduled bank. The Bank Guarantee in such cases shall be valid for atleast six months from the date of bid submission as per NIT/TCN. EMD of successful tenderer will be retained as part of Security Deposit.	In case total EMD amount is more than Rs. 20 Lakh, the amount in excess of Rs. 20 lakh may be accepted in the form of Bank Guarantee from scheduled bank. The Bank Guarantee in such cases shall be valid for atleast six months. EMD of successful tenderer will be retained as part of Security Deposit.

3. Due date of submission of offer is extended from 02-11-2016 to **10-11-2016 (15-00 hrs)**. Bidders are requested to submit their offer by extended due date positively.
4. Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
5. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

ENGR (SCT)

Encl: As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339 8231

ANNEXURE-A TO TCN-05

**JOB: Package A - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 3 for 3x660 MW North Karanpura STPP, Jharkhand.
 Package B - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 2 for 3x660 MW North Karanpura STPP, Jharkhand.
 Package C - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 2 & 3 for 3x660 MW North Karanpura STPP, Jharkhand.**

TENDER NO. PSER:SCT:NKP-C1772:16

Clarification Of Bidder's Query

SL NO	REFERENCE CLAUSE OF TENDER DOCUMENT	EXISTING PROVISION	BIDDER'S QUERY	BHEL'S CLARIFICATION
1	CLAUSE NO. 24.4.9 OF VOLUME-IF-TCC-CML-REV-01	Slip form / Jump form equipment safety ropes etc complete – 10 Sets.	As per TCC, Vpl IF-CML-Rev-01, pg 19/32, cl no 24.4.9:- Slipform/Jumpform equipment.....etc complete-10 sets. As per BOQ & scope of work, Slipform/jumpform along with passanger hoist may not be required for this type of job. Please confirm.	Slipform/jumpform etc as indicted in Tender along with passanger hoist, is required for accessing 60 / 65 m height.
2	CLAUSE NO. 24.4.21 OF VOLUME-IF-TCC-CML-REV-01	1 Nos Tower Crane with 70 m Boom	As per TCC, Vpl IF-CML-Rev-01, pg 19/32, cl no 24.4.21:- 1 nos tower crane with 70 m boom. As per scope of work this may not be required for this type of job we may use lower capacity tower crane if reqd. Please confirm.	ACC area for 01 unit is approx. 110 /120 m x 100 m and Tower Crane has to cover the total area from one end. Hence, 70m boom is required.
3	GENERAL		We will mobilize Dozer, earth compacter as and when required for smooth execution of projects.	Dozer is required for stacking the excavated earth and the earth compacter is required during backfilling. Hence, both the equipments required as mentioned in the TCC for smooth execution of projects.

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Package A - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 3 for 3x660 MW North Karanpura STPP, Jharkhand. Package B - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 1 & 2 for 3x660 MW North Karanpura STPP, Jharkhand. Package C - Civil works of AIR COOLED CONDENSER OF 50% of UNIT 2 & 3 for 3x660 MW North Karanpura STPP, Jharkhand.	
Ref	1.0	Tender no. PSER:SCT:NKP-C1772:16.
	2.0	BHEL's NIT, vide reference no PSER:SCT:NKP-C1772:5231, Dated 19-09-2016.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:NKP-C1772:TCN-01, Dated 28-09-2016.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:NKP-C1772:TCN-02, Dated 07-10-2016.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:NKP-C1772:TCN-03, Dated 19-10-2016.
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:NKP-C1772:TCN-04, Dated 21-10-2016.
	7.0	BHEL's TCN-05, vide reference no PSER:SCT:NKP-C1772:TCN-05, Dated 28-10-2016.
	8.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

<p>पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय) POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091 फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339-8231</p>
