

Bharat Heavy Electricals Limited

(A Govt. Of India Undertaking)

Power Sector, Eastern Region BHEL BHAWAN, PLOT NO. DJ-9/1, SECOTR II, SALT LAKE CITY, KOLKATA, WEST BENGAL, INDIA

Phone: 033-23398220,033-23211690 FAX: 033-23211960

TENDER CHANGE NOTICE

Sub	TENDER CHANGE NOTICE: TCN-06 dtd. 11/08/2021				
Job	Supply of Cladding sheets & Deck sheets at 1 X 250 MW NSPCL Rourkela PP-II Expansion project".				
Ref	(i) TENDER NO: PSER:PUR:PMX:374(VIII):020 (ENQ:21:PP:0015:PUR:22) Date:27/07/2021				
	(ii) TCN-01 dtd. 02/08/2021				
	(iii) TCN-02 dtd. 05/08/2021				
	(iv) TCN-03 dtd 06/08/2021				
	(v) TCN-04 dtd. 09/08/2021				
	(vi) TCN-05 dtd. 11/08/2021				

With reference to above, following clarifications, relevant to tender, may please be noted and complied with while submitting the offer.

- 1) Clarification to bidder's query as per attached Annexure-A
- 2) Revised 'No deviation certificate' is attached. Bidder to submit their offer along with stamped & signed copy of this TCN & 'No deviation certificate' as per attached format only
- All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully, for BHARAT HEAVY ELECTRICALS LTD.

DY. MGR (PURCHASE)

Encl: As above.

(Signature, date & seal of authorized representative of the contractor)

NO DEVIATION CERTIFICATE (TO BE SUBMITTED IN BIDDER'S LETTERHEAD)

To,
BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector - II, Salt Lake City,
Kolkata - 700 091

Sub	No D	No Deviation Certificate.					
Job	"Supply of Cladding sheets & Deck sheets at 1 X 250 MW NSPCL Rourkela PP-II Expansion project".						
Ref	1.0 PSER:PUR:PMX:374(VIII):020 (ENQ:21:PP:0015:PUR:22) Date:27/07/2021and TCN-01 DATED 02/08/2021						
	2.0	2.0 (i) TCN-01 dtd. 02/08/2021, (ii) TCN-02 dtd. 05/08/2021, (iii) TCN-03 dtd 06/08/2021, (iv) TCN-04 dtd 09/08/2021, (v) TCN-05 dtd. 11/08/2021 & (vi) TCN-06					
	dtd 11/08/2021						
	3.0	Other references (if any).					

Dear Sir/Madam,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void. We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

ANNEXURE-A TO TCN-06								
JOB: Supply of Cladding Sheets & Deck Sheets at 1 x 250 MW NSPCL Rourkela PP-II Expansion Project								
Tender No. PSER:PUR:PMX:374(VIII):020 (ENQ:21:PP:0015:PUR:22) dated 27.07.2021								
S.NO.	Reference Clause No of tender	Existing Provision	Bidder's Query	BHEL Reply				
1	1)Vol IF- Technical Conditions of Contract, & 2) Sl. 2 of SCC, Vol IC	Provisions pertaining to specification & list of approved manufaturer of BHEL/Customer Provisions pertaining delivery schedule	We would also like to inform you that there are lack steel supplier defined in your tender documents that meet the steel supply criteria as per specifications if your material. The list specified is given below: - Union Steel now is call Dongkuk they don't have BIS certificate for AZ150. Based in Korea and can't supply for long period. - Dongbu Steel is hardly supplying material to India and long term delivery term. - Bhushan Steel and Strip is now Tata Steel BSL Ltd They are producing the spec. - Essar Steel - Now is ArcelorMittal Nippon Steel - They don't produce this product. - National Steel - They can produce but haven minimum 3 months backlog. - JSW Steel Coated - They are producing the material - with lead time of 6-8 weeks minimum - Bhusan Steel - Is not also JSW - JSW- Kamleshwar, Thane are one company - Tata Bluescope - They have not offer to give PVDF Please note with the list in India we have only Jindal and Tata that can supply this raw material and they have very long period delays in the supply. This list of producer provided at very short and this material is not so easily available as it is PVDF and AZ 150 coating. If alternative coating of SMP and SDP with AZ150/Z275 is considered then more supplier would be available. This specification is also acceptable on other NTPC project.					