



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 07

Ref: PSER:SCT:NBN-M2092:TCN-07

Date: 20-01-2021

Sub	Tender Change Notice (TCN) - 07.	
Job	REPAIR & RENOVATION WORK OF EXISTING STORE AND OPEN STORAGE YARD FOR 3 X 660 MW NPGCL NABINAGAR FGD , BIHAR.	
Ref	1.0	Tender no PSER:SCT:NBN-M2092:20
	2.0	BHEL's NIT, vide reference no.: PSER:SCT:NBN-M2092:8308 Date: 09-12-2020.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:NBN-M2092:TCN-01 Date: 22-12-2020
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:NBN-M2092:TCN-02 Date: 30-12-2020
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:NBN-M2092:TCN-03 Date: 05-01-2021
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:NBN-M2092:TCN-04 Date: 11-01-2021
	7.0	BHEL's TCN-05, vide reference no PSER:SCT:NBN-M2092:TCN-05 Date: 15-01-2021
	8.0	BHEL's TCN-06, vide reference no PSER:SCT:NBN-M2092:TCN-06 Date: 16-01-2021
	9.0	Other References, if any.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. The clarifications to bidder's queries are attached at **Annexure-A**.
2. Due date of submission of offer is extended from 20-01-2021 to **22-01-2021 (15-00 hrs. IST)**.
3. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
4. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

Dy. Manager / (SCT)

Encl.: As Above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339 8000

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
 Power Sector - Eastern Region,
 Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
 Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	REPAIR & RENOVATION WORK OF EXISTING STORE AND OPEN STORAGE YARD FOR 3 X 660 MW NPGCL NABINAGAR FGD , BIHAR.	
Ref	1.0	Tender no PSER:SCT:NBN-M2092:20
	2.0	BHEL's NIT, vide reference no.: PSER:SCT:NBN-M2092:8308 Date: 09-12-2020.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:NBN-M2092:TCN-01 Date: 22-12-2020
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:NBN-M2092:TCN-02 Date: 30-12-2020
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:NBN-M2092:TCN-03 Date: 05-01-2021
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:NBN-M2092:TCN-04 Date: 11-01-2021
	7.0	BHEL's TCN-05, vide reference no PSER:SCT:NBN-M2092:TCN-05 Date: 15-01-2021
	8.0	BHEL's TCN-06, vide reference no PSER:SCT:NBN-M2092:TCN-06 Date: 16-01-2021
	9.0	BHEL's TCN-07, vide reference no PSER:SCT:NBN-M2092:TCN-07 Date: 20-01-2021
	10.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

Job: REPAIR & RENOVATION WORK OF EXISTING STORE AND OPEN STORAGE YARD FOR 3 X 660 MW NPGCL NABINAGAR FGD , BIHAR.				
Tender no. PSER:SCT:NBN-M2092:20				
TCN-07 (ANNEXURE-A)				
Sl. No	Reference Clause of Tender Document	Existing Provision	Bidder's Query	BHEL's Clarification
1	Sl. no. 3 of Sch-2 (Price Break Up) of Price Schedule (Volume-III)	ITEM DESCRIPTION: LAYING 50/75/100 MM OF PLAIN CEMENT CONCRETE ANY GRADE INCLUDING SHUTTERING, CURING, CONSOLIDATION ETC. COMPLETE AS PER STANDARD SPECIFICATIONS AND AS DIRECTED BY BHEL ENGINEER (CONCRETE WILL BE PROVIDED BY BHEL).	Kindly clarify whether concrete has to be poured upto plinth or above plinth level?	Concrete has to be poured upto plinth level.
2	Sl. no. 5 of Sch-2 (Price Break Up) of Price Schedule (Volume-III)	RECTIFICATION OF APPROACH ROAD IN EXISTING OPEN YARD BY LAYING, SPREADING AND COMPACTING STONE AGGREGATE OF 90MM TO 45MM SIZE STONE TO WBM SPECIFICATIONS IN UNIFORM THICKNESS, HAND PICKING, ROLLING WITH 3 WHEELED ROAD/VIBRATORY ROLLER 8-10 TONNE CAPACITY IN STAGES TO PROPER GRADE AND CAMBER, APPLYING AND BROOMING REQUISITE TYPE OF SCRSENING/BINDING MATERIAL. TO FILL UP INTERSTICES OF COARSE AGGREGATE, WATERING AND COMPACTING TO THE REQUIRED DENSITY.	In this particular item whether BHEL will provide WBM materials like aggregate moorum etc (as providing word is not mentioned in this item)? Kindly clarify.	WBM material supply in Bidder's scope.
3	Sl. no. 16 of Sch-2 (Price Break Up) of Price Schedule (Volume-III)	REPAIRING OF COVERED SHED BY SUPPLYING AND FIXING OF CLADDING SHEET, SELF TAPPING SCREW AND MANPOWER WITH T&P.	Kindly provide details of the cladding sheet with colour & thickness, because without this detail its not possible to fill the rates of the cladding sheet with specified make/brand & specs.	Cladding with Galvalume Sheet confirming to ASTM A 792 of thickness 0.47mm with zinc coating not less than 150gm/Sq.m (both side mass) of 550Mpa (min). Colour of cladding will be intimated in erection stage.