



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 09

Ref: PSER:SCT:SDG-C2137:TCN-09

Date: 15-03-2022

| Sub | Tender Change Notice (TCN) – 09. | |
|-----|---|---|
| Job | Construction of 01 no. 275 M height RCC wet chimney with one(1) internal steel flue, having minimum 38 mm thick Borosilicate lining on internal surface of steel flue (excluding pile & pile cap) at 1x660 MW, Unit no. 5, WBDCL Sagardighi TPP Extension Project, West Bengal. | |
| Ref | 1.0 | Tender no PSER:SCT:SDG-C2137:22. |
| | 2.0 | BHEL's NIT, vide reference no PSER:SCT:SDG-C2137:8974, Date: 10-02-2022. |
| | 3.0 | BHEL's TCN-01, vide reference no PSER:SCT:SDG-C2137:TCN-01, Date: 15-02-2022. |
| | 4.0 | BHEL's TCN-02, vide reference no PSER:SCT:SDG-C2137:TCN-02, Date: 17-02-2022. |
| | 5.0 | BHEL's TCN-03, vide reference no PSER:SCT:SDG-C2137:TCN-03, Date: 19-02-2022. |
| | 6.0 | BHEL's TCN-04, vide reference no PSER:SCT:SDG-C2137:TCN-04, Date: 01-03-2022. |
| | 7.0 | BHEL's TCN-05, vide reference no PSER:SCT:SDG-C2137:TCN-05, Date: 03-03-2022. |
| | 8.0 | BHEL's TCN-06, vide reference no PSER:SCT:SDG-C2137:TCN-06, Date: 04-03-2022. |
| | 9.0 | BHEL's TCN-07, vide reference no PSER:SCT:SDG-C2137:TCN-07, Date: 05-03-2022. |
| | 10.0 | BHEL's TCN-08, vide reference no PSER:SCT:SDG-C2137:TCN-08, Date: 08-03-2022. |
| | 11.0 | All other pertinent issues till date. |

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

- Clarification of bidder's queries attached vide Annexure-A to TCN-09.
- Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.
- All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DY. MGR. (SCT)

Encl : As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339 8231

ANNEXURE-A TO TCN-09

JOB: Construction of 01 no. 275 M height RCC wet chimney with one(1) internal steel flue, having minimum 38 mm thick Borosilicate lining on internal surface of steel flue (excluding pile & pile cap) at 1x660 MW, Unit no. 5, WBPDCL Sagardighi TPP Extension Project, West Bengal.

TENDER NO - PSER:SCT:SDG-C2137:22

CLARIFICATION OF BIDDER'S QUERIES

| Sl. No | Reference clause of tender document | Existing Provision | Bidder's Query | BHEL's Clarification |
|---------------|---|---|---|--|
| 1 | Chimney GA Drawing (Dwg no. PE-DG-489-620-C001, Rev. 0) attached with TCN-04. | - | <p>As per GA drawing No. PE-DG-489-620-C001, 7 nos. external platforms have been provided for Aviation Warning Lights. We request BHEL to remove external platform as in all projects these have been removed as for installation of AWL retractable type arrangement is being adopted & maintenance can be done from inside.</p> <p>The construction of external platform is time taking & more over it slows the slipforming thereby increasing the construction time of Chimney shell.</p> | Shall be as per Tender Specifications. |
| 2 | Clause No. 33.0 of VOL-IF-TCC CML | <p>Cl. no. 33.0 - COMPLETION PERIOD:</p> <p>Cl. no. 33.1:</p> <p>The entire work under this scope shall be successfully completed in all respect within 13 (Thirteen) months from the date of start of work as certified by Construction Manager, BHEL.</p> | If external platform are required then please extend the contractual time of completion to 21 months. | Completion schedule shall be as per Tender. |
| 3 | General | - | Please allow construction of electrical room & CEMS room inside Chimney shell by pre-cast method. | Construction will be as per specification given in tender and approved drawing which will be provided to the successful bidder during execution. |
| 4 | General | - | Please specify the MOC of flue duct & specification of lining if required. | Flue gas duct will be supplied by BHEL with glass flake lining. |
| 5 | Clause No. 37.0 of VOL-IF-TCC CML | <p>Cl. no. 37.0 - INTEREST BEARING RECOVERABLE ADVANCE/ MOBILISATION ADVANCE:</p> <p>Not applicable for this tender.</p> | <p>REQUEST FOR INITIAL ADVANCE OF 5% AND MOBILISATION ADVANCE OF 5%:</p> <p>As you are kindly aware chimney is highly specialised job and mobilisation of Slipform set, batching plant and other equipment require heavy expenditure at the start of job. We once again request you to include 5% initial advance and 5% mobilisation advance to smoothly execute project.</p> | Shall be as per tender. |

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
 Power Sector - Eastern Region,
 Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
 Kolkata – 700 091

| | | |
|-----|---|---|
| Sub | No Deviation Certificate. | |
| Job | Construction of 01 no. 275 M height RCC wet chimney with one(1) internal steel flue, having minimum 38 mm thick Borosilicate lining on internal surface of steel flue (excluding pile & pile cap) at 1x660 MW, Unit no. 5, WBPCL Sagardighi TPP Extension Project, West Bengal. | |
| Ref | 1.0 | Tender no PSER:SCT:SDG-C2137:22. |
| | 2.0 | BHEL's NIT, vide reference no PSER:SCT:SDG-C2137:8974, Date: 10-02-2022. |
| | 3.0 | BHEL's TCN-01, vide reference no PSER:SCT:SDG-C2137:TCN-01, Date: 15-02-2022. |
| | 4.0 | BHEL's TCN-02, vide reference no PSER:SCT:SDG-C2137:TCN-02, Date: 17-02-2022. |
| | 5.0 | BHEL's TCN-03, vide reference no PSER:SCT:SDG-C2137:TCN-03, Date: 19-02-2022. |
| | 6.0 | BHEL's TCN-04, vide reference no PSER:SCT:SDG-C2137:TCN-04, Date: 01-03-2022. |
| | 7.0 | BHEL's TCN-05, vide reference no PSER:SCT:SDG-C2137:TCN-05, Date: 03-03-2022. |
| | 8.0 | BHEL's TCN-06, vide reference no PSER:SCT:SDG-C2137:TCN-06, Date: 04-03-2022. |
| | 9.0 | BHEL's TCN-07, vide reference no PSER:SCT:SDG-C2137:TCN-07, Date: 05-03-2022. |
| | 10.0 | BHEL's TCN-08, vide reference no PSER:SCT:SDG-C2137:TCN-08, Date: 08-03-2022. |
| | 11.0 | BHEL's TCN-09, vide reference no PSER:SCT:SDG-C2137:TCN-09, Date: 15-03-2022. |
| | 12.0 | All other pertinent issues till date. |

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALTLAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 23398000