



# भारत हेवी इलेक्ट्रिकल्स लिमिटेड

( भारत सरकार का उपक्रम )

## BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

**TCN - 12**

Page 1 of 2

Ref: PSER:SCT:SDG-C1970:TCN-12

Date: 27-08-2019

Sub	<b>Tender Change Notice (TCN)- 12.</b>	
Job	Levelling grading, piling work including testing of piles and other associated works etc. of 1X660MW, UNIT-5, Sagardighi TPP Extension, West Bengal.	
Ref	1.0	Tender no PSER:SCT:SDG-C1970:19.
	2.0	BHEL's NIT, vide reference no: PSER:SCT:SDG-C1970:7610 Date: 28-06-2019.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:SDG-C1970:TCN-01 Date: 05-07-2019.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:SDG-C1970:TCN-02 Date: 10-07-2019.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:SDG-C1970:TCN-03 Date: 17-07-2019.
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:SDG-C1970:TCN-04 Date: 18-07-2019.
	7.0	BHEL's TCN-05, vide reference no PSER:SCT:SDG-C1970:TCN-05 Date: 19-07-2019.
	8.0	BHEL's TCN-06, vide reference no PSER:SCT:SDG-C1970:TCN-06 Date: 24-07-2019.
	9.0	BHEL's TCN-07, vide reference no PSER:SCT:SDG-C1970:TCN-07 Date: 29-07-2019.
	10.0	BHEL's TCN-08, vide reference no PSER:SCT:SDG-C1970:TCN-08 Date: 05-08-2019.
	11.0	BHEL's TCN-09, vide reference no PSER:SCT:SDG-C1970:TCN-09 Date: 12-08-2019.
	12.0	BHEL's TCN-10, vide reference no PSER:SCT:SDG-C1970:TCN-10 Date: 19-08-2019.
	13.0	BHEL's TCN-11, vide reference no PSER:SCT:SDG-C1970:TCN-11 Date: 26-08-2019.
	14.0	Other References, if any.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. The clarifications to bidder's queries are attached at **Annexure-A**.
2. Clause no 44.5 under Clause no 44.0 (INTERIM PAYMENTS) of Volume-IF-TCC-CML-REV-00 (Technical Conditions of Contract) shall be read as below:

CL NO	EXISTING PROVISION	MODIFIED PROVISION
44.5	The contractor shall submit his running bill, once in a month at the end of each month. The RA bill complete in all respect, accompanied by BHEL engineers certified measurement sheets, jointly signed, will be paid after 30 days of submission of bill, subject to completeness and correctness. Income Tax at the prevailing rates on gross value of work done & applicable surcharge shall be deducted from contractor's bill, unless exempted by Income Tax Authority.	The contractor shall submit his running bill, once in a month at the end of each month. The RA bill complete in all respect, accompanied by BHEL engineers certified measurement sheets, jointly signed, will be paid after 45 days of submission of bill, subject to completeness and correctness. Income Tax at the prevailing rates on gross value of work done & applicable surcharge shall be deducted from contractor's bill, unless exempted by Income Tax Authority.

पावर सेक्टर पूर्वी क्षेत्र ( मुख्यालय )

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339 8000



# भारत हेवी इलेक्ट्रिकल्स लिमिटेड

( भारत सरकार का उपक्रम )

## BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

**TCN - 12**

Page 2 of 2

3. This has reference to clause no 34.0 of NIT, you are requested to note the following:

Since tenure of Ms. Pravin Tripathi, IA&AS (Retd.) as IEM of BHEL has been expired on 11<sup>th</sup> Aug 2019, subject tender will now be overseen by following Independent External Monitor(s) (IEMs):

SI No.	IEM	Address	Email
1.0	Shri Arun Chandra Verma, IPS (Retd.)	Flat No. C -1204, C Tower, Amrapali, Platinum Complex, Sector 119, Noida (U.P.)	<a href="mailto:acverma1@gmail.com">acverma1@gmail.com</a>
2.0	Shri Virendra Bahadur Singh, IPS (Retd.)	H. No. B-5/64, Vineet Khand, Gomti Nagar, Lucknow - 226010	<a href="mailto:vbsinghips@gmail.com">vbsinghips@gmail.com</a>

4. Revised 'No deviation certificate' as per enclosed Annexure-2. Bidder shall submit no deviation certificate as per enclosed format only.

5. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,  
for BHARAT HEAVY ELECTRICALS LTD

Dy. Mgr (SCT)

Encl: As Above.

पावर सेक्टर पूर्वी क्षेत्र ( मुख्यालय )

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339 8000

Sl. No.	Reference clause of tender document	Existing provision	Bidder's query	BHEL's clarification
1.	Item no A2511 of SCH-2-PRICE BREAK UP, PRICE SCHEDULE, VOL-III	Conducting initial load test upto a maximum test load of 3 (Three) times the safe load capacity on single pile as specified in accordance with IS 2911 Part-4 including preparation of pile head for testing, necessary excavation, all arrangements of loading, unloading, test equipments/ accessories, jacks, recording of results, labour, submission of test report but excluding the cost of installation of pile ( installation of pile shall be paid separately) etc. all complete as per specification, drawing and as directed by engineer in - charge	kindly provide the safe load capacity for the pile load test for the following BOQ item Item no A2511.	<p>The tentative Safe load capacity of job pile are as below:</p> <ol style="list-style-type: none"> <li>1. For 600 mm dia Safe load capacity of pile in vertical compression = 150 MT in lateral = 10 MT in uplift = 50 MT</li> <li>2. For 760 mm dia Safe load capacity of pile in vertical compression = 220 MT in lateral = 13 MT in uplift = 80 MT</li> </ol> <p>It is to be noted that the above mentioned safe load capacity of piles are tentative and as per tender stage geotechnical data. The final safe load capacity of pile shall be as per approved Geotechnical Investigation report.</p>
2.			Request for cancellation of Reverse Auction.	Shall be as per Tender.

**FORMAT FOR NO DEVIATION CERTIFICATE**  
**(To be submitted in the bidder's letter head)**

BHARAT HEAVY ELECTRICALS LIMITED,  
Power Sector - Eastern Region,  
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,  
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Levelling grading, piling work including testing of piles and other associated works etc. of 1X660MW, UNIT-5, Sagardighi TPP Extension, West Bengal.	
Ref	1.0	Tender no PSER:SCT:SDG-C1970:19.
	2.0	BHEL's NIT, vide reference no: PSER:SCT:SDG-C1970:7610 Date: 28-06-2019.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:SDG-C1970:TCN-01 Date: 05-07-2019.
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:SDG-C1970:TCN-02 Date: 10-07-2019.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:SDG-C1970:TCN-03 Date: 17-07-2019.
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:SDG-C1970:TCN-04 Date: 18-07-2019.
	7.0	BHEL's TCN-05, vide reference no PSER:SCT:SDG-C1970:TCN-05 Date: 19-07-2019.
	8.0	BHEL's TCN-06, vide reference no PSER:SCT:SDG-C1970:TCN-06 Date: 24-07-2019.
	9.0	BHEL's TCN-07, vide reference no PSER:SCT:SDG-C1970:TCN-07 Date: 29-07-2019.
	10.0	BHEL's TCN-08, vide reference no PSER:SCT:SDG-C1970:TCN-08 Date: 05-08-2019.
	11.0	BHEL's TCN-09, vide reference no PSER:SCT:SDG-C1970:TCN-09 Date: 12-08-2019.
	12.0	BHEL's TCN-10, vide reference no PSER:SCT:SDG-C1970:TCN-10 Date: 19-08-2019.
	13.0	BHEL's TCN-11, vide reference no PSER:SCT:SDG-C1970:TCN-11 Date: 26-08-2019.
	14.0	BHEL's TCN-12, vide reference no PSER:SCT:SDG-C1970:TCN-12 Date: 27-08-2019.
	15.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized  
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : 033-2339 8000/ 2339 8236