



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 13

Ref: PSER:SCT:RKL-M1797:TCN-13

Date: 07-04-2017

Sub	Tender Change Notice (TCN) - 13	
Job	Design, Engineering, Manufacturing, Supply, Erection, Testing, Commissioning, Etc Of Air Conditioning System For 1x250 MW Units At PP-II Expansion, NSPCL, Rourkela, Odisha.	
Ref	1.0	Tender no PSER:SCT: RKL-M1797:16
	2.0	BHEL's NIT, vide reference no PSER:SCT: RKL-M1797:17:5427, Dated 19/01/17
	3.0	BHEL's TCN-01 ref PSER:SCT:RKL-M1797:TCN-01 Date: 08-02-2017
	4.0	BHEL's TCN-02 ref PSER:SCT:RKL-M1797:TCN-02 Date: 14-02-2017
	5.0	BHEL's TCN-03 ref PSER:SCT:RKL-M1797:TCN-03 Date: 20-02-2017
	6.0	BHEL's TCN-04 ref PSER:SCT:RKL-M1797:TCN-04 Date: 20-02-2017
	7.0	BHEL's TCN-05 ref PSER:SCT:RKL-M1797:TCN-05 Date: 27-02-2017
	8.0	BHEL's TCN-06 ref PSER:SCT:RKL-M1797:TCN-06 Date: 07-03-17
	9.0	BHEL's TCN-07 ref PSER:SCT:RKL-M1797:TCN-07 Date: 10-03-17
	10.0	BHEL's TCN-08 ref PSER:SCT:RKL-M1797:TCN-08 Date: 14-03-17
	11.0	BHEL's TCN-09 ref PSER:SCT:RKL-M1797:TCN-09 Date: 17-03-17
	12.0	BHEL's TCN-10 ref PSER:SCT:RKL-M1797:TCN-10 Date: 20-03-17
	13.0	BHEL's TCN-11 ref PSER:SCT:RKL-M1797:TCN-11 Date: 28-03-17
	14.0	BHEL's TCN-12 ref PSER:SCT:RKL-M1797:TCN-12 Date:04-04-17
	15.0	All other pertinent issues till date.

With reference to above, following points/ documents, relevant to tender, may please be noted and complied with while submitting the offer.

- 1) Clarification to bidder's queries is attached as per Annexure-A to TCN -13.
- 2) Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
- 3) All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

Dy Mgr (SCT)

Encl: As above.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 23398000/ 23398229

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Design, Engineering, Manufacturing, Supply, Erection, Testing, Commissioning, Etc Of Air Conditioning System For 1x250 MW Units At PP-II Expansion, NSPCL, Rourkela, Odisha.	
Ref	1.0	Tender no PSER:SCT: RKL-M1797:16
	2.0	BHEL's NIT, vide reference no PSER:SCT: RKL-M1797:17:5427, Dated 19/01/17
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:RKL-M1797:TCN-01, Dated 08/02/17
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:RKL-M1797:TCN-02, Dated 14/02/17
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:RKL-M1797:TCN-03, Dated 20/02/17
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:RKL-M1797:TCN-04, Dated 20/02/17
	7.0	BHEL's TCN-05, vide reference no PSER:SCT:RKL-M1797:TCN-05, Dated 27/02/17
	8.0	BHEL's TCN-06, vide reference no PSER:SCT:RKL-M1797:TCN-06, Dated 07/03/17
	9.0	BHEL's TCN-07, vide reference no PSER:SCT:RKL-M1797:TCN-07, Dated 10/03/17
	10.0	BHEL's TCN-08, vide reference no PSER:SCT:RKL-M1797:TCN-08, Dated 14/03/17
	11.0	BHEL's TCN-09, vide reference no PSER:SCT:RKL-M1797:TCN-09, Dated 17/03/17
	12.0	BHEL's TCN-10, vide reference no PSER:SCT:RKL-M1797:TCN-10, Dated 20/03/17
	13.0	BHEL's TCN-11, vide reference no PSER:SCT:RKL-M1797:TCN-11 Dated 28/03/17
	14.0	BHEL's TCN-12, vide reference no PSER:SCT:RKL-M1797:TCN-12 Dated 04/04/17
	15.0	BHEL's TCN-13, vide reference no PSER:SCT:RKL-M1797:TCN-13 Dated 07/04/17
	16.0	All other pertinent issues till date.

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALLAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : (033) 2339-8000/ 2339-8229

Design, Engineering, Manufacturing, Supply, Erection, Testing, Commissioning, Etc Of Air Conditioning System For 1x250 MW Units At PP-II Expansion, NSPCL, Rourkela, Odisha.			
ANNEXURE-A TO TCN-13			
Tender No : PSER:SCT:M1797:16			
SI No.	Reference Clause of Tender document	Bidder Query	BHEL's reply
1	Vol-II, Technical Specification	The ESP building area heat load is coming 30 TR and the condensing unit capacity is 150TR and which tonnage we have to consider for AHU selection	Please check calculation, for heat dissipation data refer Addendum-1 to Technical Specification No PE-TS-427-553-A001 issued alongwith TCN-03
2	Page number 70 ,Volume -II ,Technical Spec	It is given that 550 CFM/TR and kindly clarify the TR is heat load TR or the TR given in the BOQ	CFM Shall be finalized DDE as per the heat load calculation.
3	Vol-II, Technical Specification	Kindly provide the load of equipments in ESP and main power house buildings and ESP buildings	Refer Addendum-1 to Technical Specification No PE-TS-427-553-A001 issued alongwith TCN-03